

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Humbolt Elementary School

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 001-WS8-75A Water Spigot 8 | 6/8/2016 23:38 | 6/14/2016 12:25 | 606093175 | Lead | 23.3 | 15 | ppb |
| 001-WS8-75A Water Spigot 8 | 6/8/2016 23:38 | 6/14/2016 12:25 | 606093175 | Copper | 0.3 | 1.3 | ppm |
| 001-WS7-74A Water Spigot 7 | 6/8/2016 23:14 | 6/14/2016 12:25 | 606093174 | Lead | 61.8 | 15 | ppb |
| 001-WS7-74A Water Spigot 7 | 6/8/2016 23:14 | 6/14/2016 12:25 | 606093174 | Copper | 0.0 | 1.3 | ppm |
| 001-WS6-73A Water Spigot 6 | 6/8/2016 23:07 | 6/14/2016 12:25 | 606093173 | Lead | 18.8 | 15 | ppb |
| 001-WS6-73A Water Spigot 6 | 6/8/2016 23:07 | 6/14/2016 12:25 | 606093173 | Copper | 0.0 | 1.3 | ppm |
| 001-WS5-72A Water Spigot 5 | 6/8/2016 23:03 | 6/14/2016 13:21 | 606093172 | Lead | 19.1 | 15 | ppb |
| 001-WS5-72A Water Spigot 5 | 6/8/2016 23:03 | 6/14/2016 13:21 | 606093172 | Copper | 0.0 | 1.3 | ppm |
| 001-WS4-71A Water Spigot 4 | 6/8/2016 23:00 | 6/14/2016 13:32 | 606093171 | Lead | 926.0 | 15 | ppb |
| 001-WS4-71A Water Spigot 4 | 6/8/2016 23:00 | 6/14/2016 13:32 | 606093171 | Copper | 4.9 | 1.3 | ppm |
| 001-WS3-70A Water Spigot 3 | 6/8/2016 23:57 | 6/14/2016 12:25 | 606093170 | Lead | 69.8 | 15 | ppb |
| 001-WS3-70A Water Spigot 3 | 6/8/2016 23:57 | 6/14/2016 12:25 | 606093170 | Copper | 0.1 | 1.3 | ppm |
| 001-WS2-69A Water Spigot 2 | 6/8/2016 22:54 | 6/14/2016 13:17 | 606093169 | Lead | 52.6 | 15 | ppb |
| 001-WS2-69A Water Spigot 2 | 6/8/2016 22:54 | 6/14/2016 13:17 | 606093169 | Copper | 0.1 | 1.3 | ppm |
| 001-WS1-68A Water Spigot 1 | 6/8/2016 22:51 | 6/14/2016 12:24 | 606093168 | Lead | 28.4 | 15 | ppb |
| 001-WS1-68A Water Spigot 1 | 6/8/2016 22:51 | 6/14/2016 12:24 | 606093168 | Copper | 0.3 | 1.3 | ppm |
| 001-P4-84A P4 Drinking Faucet | 6/8/2016 23:53 | 6/14/2016 12:29 | 606093184 | Lead | 10.3 | 15 | ppb |
| 001-P4-84A P4 Drinking Faucet | 6/8/2016 23:53 | 6/14/2016 13:31 | 606093184 | Copper | 0.8 | 1.3 | ppm |
| 001-P4-83A P4 Sink Faucet | 6/8/2016 23:50 | 6/14/2016 12:28 | 606093183 | Lead | 25.5 | 15 | ppb |
| 001-P4-83A P4 Sink Faucet | 6/8/2016 23:50 | 6/14/2016 13:30 | 606093183 | Copper | 1.4 | 1.3 | ppm |
| 001-P3-82A P3 Drinking Faucet | 6/8/2016 23:46 | 6/14/2016 12:28 | 606093182 | Lead | 44.8 | 15 | ppb |
| 001-P3-82A P3 Drinking Faucet | 6/8/2016 23:46 | 6/14/2016 13:30 | 606093182 | Copper | 3.6 | 1.3 | ppm |
| 001-P3-81A P3 Sink Faucet | 6/8/2016 23:45 | 6/14/2016 12:28 | 606093181 | Lead | 16.2 | 15 | ppb |
| 001-P3-81A P3 Sink Faucet | 6/8/2016 23:45 | 6/14/2016 12:28 | 606093181 | Copper | 0.4 | 1.3 | ppm |
| 001-P2-78A P2 Drinking Faucet | 6/8/2016 23:26 | 6/14/2016 12:26 | 606093178 | Lead | 2.6 | 15 | ppb |
| 001-P2-78A P2 Drinking Faucet | 6/8/2016 23:26 | 6/14/2016 12:26 | 606093178 | Copper | 0.4 | 1.3 | ppm |
| 001-P2-77A P2 Bathroom Faucet | 6/8/2016 23:24 | 6/14/2016 12:26 | 606093177 | Lead | 4.3 | 15 | ppb |
| 001-P2-77A P2 Bathroom Faucet | 6/8/2016 23:24 | 6/14/2016 12:26 | 606093177 | Copper | 0.0 | 1.3 | ppm |
| 001-P2-76A P2 Sink Faucet | 6/8/2016 23:22 | 6/14/2016 12:26 | 606093176 | Lead | 3.3 | 15 | ppb |
| 001-P2-76A P2 Sink Faucet | 6/8/2016 23:22 | 6/14/2016 12:26 | 606093176 | Copper | 0.0 | 1.3 | ppm |
| 001-P1-80A P1 Sink Faucet | 6/8/2016 23:33 | 6/14/2016 12:27 | 606093180 | Lead | 1.3 | 15 | ppb |
| 001-P1-80A P1 Sink Faucet | 6/8/2016 23:33 | 6/14/2016 12:27 | 606093180 | Copper | 0.1 | 1.3 | ppm |
| 001-P1/P2-79A P1/P2 Bthrm Faucet | 6/8/2016 23:30 | 6/14/2016 12:26 | 606093179 | Lead | 6.6 | 15 | ppb |
| 001-P1/P2-79A P1/P2 Bthrm Faucet | 6/8/2016 23:30 | 6/14/2016 12:26 | 606093179 | Copper | 0.1 | 1.3 | ppm |
| 001-NS-20A Nurses Station | 6/8/2016 20:17 | 6/14/2016 13:15 | 606093120 | Lead | 117.0 | 15 | ppb |
| 001-NS-20A Nurses Station | 6/8/2016 20:17 | 6/14/2016 13:15 | 606093120 | Copper | 0.0 | 1.3 | ppm |
| 001-KS3-13A Kitchen Faucet (3) | 6/8/2016 19:42 | 6/14/2016 12:09 | 606093113 | Lead | 16.0 | 15 | ppb |
| 001-KS3-13A Kitchen Faucet (3) | 6/8/2016 19:42 | 6/14/2016 12:09 | 606093113 | Copper | 0.0 | 1.3 | ppm |
| 001-KS2-12A Kitchen Faucet (2) Food Prep | 6/8/2016 19:37 | 6/14/2016 12:08 | 606093112 | Lead | 43.6 | 15 | ppb |
| 001-KS2-12A Kitchen Faucet (2) Food Prep | 6/8/2016 19:37 | 6/14/2016 12:08 | 606093112 | Copper | 0.0 | 1.3 | ppm |
| 001-KS1-11A Kitchen Faucet (1) | 6/8/2016 19:33 | 6/14/2016 14:47 | 606093111 | Lead | 57.0 | 15 | ppb |
| 001-KS1-11A Kitchen Faucet (1) | 6/8/2016 19:33 | 6/14/2016 14:47 | 606093111 | Copper | 0.2 | 1.3 | ppm |
| 001-GB-66A Girls Bthrm Faucet | 6/8/2016 22:38 | 6/14/2016 13:17 | 606093166 | Lead | 13.9 | 15 | ppb |
| 001-GB-66A Girls Bthrm Faucet | 6/8/2016 22:38 | 6/14/2016 13:17 | 606093166 | Copper | 0.1 | 1.3 | ppm |
| 001-ELI-10A Employee Lockers Sink F | 6/8/2016 19:29 | 6/15/2016 12:57 | 606093110 | Lead | 86.7 | 15 | ppb |
| 001-ELI-10A Employee Lockers Sink F | 6/8/2016 19:29 | 6/15/2016 12:57 | 606093110 | Copper | 0.1 | 1.3 | ppm |
| 001-DFB3-41A Drinking Frntn Bottle Ref | 6/8/2016 21:17 | 6/14/2016 12:16 | 606093141 | Lead | 1.3 | 15 | ppb |
| 001-DFB3-41A Drinking Frntn Bottle Ref | 6/8/2016 21:17 | 6/14/2016 12:16 | 606093141 | Copper | 0.1 | 1.3 | ppm |
| 001-DFB1-08A Drinking Fountain Bottle Refill | 6/8/2016 19:20 | 6/14/2016 13:28 | 606093108 | Lead | 0.3 | 15 | ppb |
| 001-DFB1-08A Drinking Fountain Bottle Refill | 6/8/2016 19:20 | 6/14/2016 13:28 | 606093108 | Copper | 0.0 | 1.3 | ppm |
| 001-DF3-42A Drinking Fountain | 6/8/2016 21:20 | 6/14/2016 12:16 | 606093142 | Lead | 1.8 | 15 | ppb |
| 001-DF3-42A Drinking Fountain | 6/8/2016 21:20 | 6/14/2016 12:16 | 606093142 | Copper | 0.0 | 1.3 | ppm |
| 001-DF2-21A Drinking Fountain | 6/8/2016 20:19 | 6/14/2016 12:11 | 606093121 | Lead | 4.8 | 15 | ppb |
| 001-DF2-21A Drinking Fountain | 6/8/2016 20:19 | 6/14/2016 12:11 | 606093121 | Copper | 0.0 | 1.3 | ppm |
| 001-DF1-09A Drinking Fountain | 6/8/2016 19:24 | 6/14/2016 12:01 | 606093109 | Lead | 0.7 | 15 | ppb |
| 001-DF1-09A Drinking Fountain | 6/8/2016 19:24 | 6/14/2016 12:01 | 606093109 | Copper | 0.0 | 1.3 | ppm |

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Humbolt Elementary School

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 001-CU5-14A Custodial at Exit H | 6/8/2016 19:50 | 6/14/2016 13:11 | 606093114 | Lead | 36.1 | 15 | ppb |
| 001-CU5-14A Custodial at Exit H | 6/8/2016 19:50 | 6/14/2016 13:11 | 606093114 | Copper | 0.1 | 1.3 | ppm |
| 001-BB-67A Boys Bthrm Faucet | 6/8/2016 22:41 | 6/14/2016 12:24 | 606093167 | Lead | 14.9 | 15 | ppb |
| 001-BB-67A Boys Bthrm Faucet | 6/8/2016 22:41 | 6/14/2016 12:24 | 606093167 | Copper | 0.0 | 1.3 | ppm |
| 001-9-29A 9-Staff Unisex Bathroom | 6/8/2016 20:40 | 6/14/2016 12:12 | 606093129 | Lead | 4.6 | 15 | ppb |
| 001-9-29A 9-Staff Unisex Bathroom | 6/8/2016 20:40 | 6/14/2016 12:12 | 606093129 | Copper | 0.0 | 1.3 | ppm |
| 001-8-28A 8-Staff Bathroom | 6/8/2016 20:38 | 6/14/2016 12:12 | 606093128 | Lead | 4.7 | 15 | ppb |
| 001-8-28A 8-Staff Bathroom | 6/8/2016 20:38 | 6/14/2016 12:12 | 606093128 | Copper | 0.0 | 1.3 | ppm |
| 001-6-26A 6-Teachers Lounge | 6/8/2016 20:31 | 6/14/2016 13:16 | 606093126 | Lead | 59.3 | 15 | ppb |
| 001-6-26A 6-Teachers Lounge | 6/8/2016 20:31 | 6/14/2016 13:16 | 606093126 | Copper | 0.2 | 1.3 | ppm |
| 001-5-25A Classroom 5 Drinking Fountain | 6/8/2016 20:29 | 6/14/2016 12:12 | 606093125 | Lead | 10.5 | 15 | ppb |
| 001-5-25A Classroom 5 Drinking Fountain | 6/8/2016 20:29 | 6/14/2016 12:12 | 606093125 | Copper | 0.0 | 1.3 | ppm |
| 001-5-24A Classroom 5 Sink Faucet | 6/8/2016 20:27 | 6/14/2016 13:15 | 606093124 | Lead | 41.2 | 15 | ppb |
| 001-5-24A Classroom 5 Sink Faucet | 6/8/2016 20:27 | 6/14/2016 13:15 | 606093124 | Copper | 0.0 | 1.3 | ppm |
| 001-4-23A Classroom 4 Drinking Fountain | 6/8/2016 20:25 | 6/14/2016 12:11 | 606093123 | Lead | 1.8 | 15 | ppb |
| 001-4-23A Classroom 4 Drinking Fountain | 6/8/2016 20:25 | 6/14/2016 12:11 | 606093123 | Copper | 0.0 | 1.3 | ppm |
| 001-4-22A Classroom 4 Sink Faucet | 6/8/2016 20:22 | 6/14/2016 12:11 | 606093122 | Lead | 64.6 | 15 | ppb |
| 001-4-22A Classroom 4 Sink Faucet | 6/8/2016 20:22 | 6/14/2016 12:11 | 606093122 | Copper | 0.0 | 1.3 | ppm |
| 001-40-63A 40 Drinking Faucet | 6/8/2016 22:27 | 6/14/2016 12:22 | 606093163 | Lead | 3.2 | 15 | ppb |
| 001-40-63A 40 Drinking Faucet | 6/8/2016 22:27 | 6/14/2016 12:22 | 606093163 | Copper | 0.0 | 1.3 | ppm |
| 001-40-62A 40 Classroom Faucet | 6/8/2016 22:25 | 6/14/2016 12:22 | 606093162 | Lead | 30.2 | 15 | ppb |
| 001-40-62A 40 Classroom Faucet | 6/8/2016 22:25 | 6/14/2016 12:22 | 606093162 | Copper | 0.0 | 1.3 | ppm |
| 001-37-65A 37 Drinking Faucet | 6/8/2016 22:32 | 6/14/2016 12:23 | 606093165 | Lead | 6.4 | 15 | ppb |
| 001-37-65A 37 Drinking Faucet | 6/8/2016 22:32 | 6/14/2016 12:23 | 606093165 | Copper | 0.0 | 1.3 | ppm |
| 001-37-64A 37 Classroom Faucet | 6/8/2016 22:30 | 6/14/2016 12:23 | 606093164 | Lead | 86.3 | 15 | ppb |
| 001-37-64A 37 Classroom Faucet | 6/8/2016 22:30 | 6/14/2016 12:23 | 606093164 | Copper | 0.3 | 1.3 | ppm |
| 001-35-02A Classroom 35 Drinking Fountain | 6/8/2016 18:20 | 6/14/2016 12:00 | 606093102 | Lead | 0.9 | 15 | ppb |
| 001-35-02A Classroom 35 Drinking Fountain | 6/8/2016 18:20 | 6/14/2016 12:00 | 606093102 | Copper | ND | 1.3 | ppm |
| 001-35-01A Classroom 35 Sink Faucet | 6/8/2016 18:18 | 6/14/2016 11:59 | 606093101 | Lead | 1.4 | 15 | ppb |
| 001-35-01A Classroom 35 Sink Faucet | 6/8/2016 18:18 | 6/14/2016 11:59 | 606093101 | Copper | 0.0 | 1.3 | ppm |
| 001-34-04A Girls Bathroom 34 Sink Faucet (2) | 6/8/2016 18:54 | 6/14/2016 12:00 | 606093104 | Lead | 3.6 | 15 | ppb |
| 001-34-04A Girls Bathroom 34 Sink Faucet (2) | 6/8/2016 18:54 | 6/14/2016 12:00 | 606093104 | Copper | 0.1 | 1.3 | ppm |
| 001-34-03A Girls Bathroom 34 Sink Faucet (1) | 6/8/2016 18:50 | 6/14/2016 12:00 | 606093103 | Lead | 3.6 | 15 | ppb |
| 001-34-03A Girls Bathroom 34 Sink Faucet (1) | 6/8/2016 18:50 | 6/14/2016 12:00 | 606093103 | Copper | 0.1 | 1.3 | ppm |
| 001-33-05A Custodial 33 Sink Faucet | 6/8/2016 18:58 | 6/14/2016 13:27 | 606093105 | Lead | 7.0 | 15 | ppb |
| 001-33-05A Custodial 33 Sink Faucet | 6/8/2016 18:58 | 6/14/2016 13:27 | 606093105 | Copper | 0.0 | 1.3 | ppm |
| 001-32-07A Boys Bathroom 32 Sink Faucet (1) | 6/8/2016 19:11 | 6/14/2016 12:01 | 606093107 | Lead | 6.4 | 15 | ppb |
| 001-32-07A Boys Bathroom 32 Sink Faucet (1) | 6/8/2016 19:11 | 6/14/2016 12:01 | 606093107 | Copper | 0.0 | 1.3 | ppm |
| 001-32-06A Boys Bathroom 32 Sink Faucet (1) | 6/8/2016 19:07 | 6/14/2016 13:11 | 606093106 | Lead | 12.2 | 15 | ppb |
| 001-32-06A Boys Bathroom 32 Sink Faucet (1) | 6/8/2016 19:07 | 6/14/2016 13:11 | 606093106 | Copper | 0.1 | 1.3 | ppm |
| 001-31A-17A Library Work Room | 6/8/2016 20:07 | 6/14/2016 12:09 | 606093117 | Lead | 35.5 | 15 | ppb |
| 001-31A-17A Library Work Room | 6/8/2016 20:07 | 6/14/2016 12:09 | 606093117 | Copper | 0.1 | 1.3 | ppm |
| 001-3-19A Front Workroom | 6/8/2016 20:14 | 6/14/2016 13:28 | 606093119 | Lead | 36.5 | 15 | ppb |
| 001-3-19A Front Workroom | 6/8/2016 20:14 | 6/14/2016 13:28 | 606093119 | Copper | 0.0 | 1.3 | ppm |
| 001-30D-16A 30D Laundry Spigot | 6/8/2016 20:00 | 6/14/2016 13:31 | 606093116 | Lead | 1,660.0 | 15 | ppb |
| 001-30D-16A 30D Laundry Spigot | 6/8/2016 20:00 | 6/14/2016 13:12 | 606093116 | Copper | 0.4 | 1.3 | ppm |
| 001-30D-15A 30D Shower Head | 6/8/2016 19:55 | 6/14/2016 12:09 | 606093115 | Lead | 49.9 | 15 | ppb |
| 001-30D-15A 30D Shower Head | 6/8/2016 19:55 | 6/14/2016 12:09 | 606093115 | Copper | 0.0 | 1.3 | ppm |
| 001-2A-18A Office Bathroom | 6/8/2016 20:11 | 6/14/2016 13:13 | 606093118 | Lead | 9.8 | 15 | ppb |
| 001-2A-18A Office Bathroom | 6/8/2016 20:11 | 6/14/2016 13:13 | 606093118 | Copper | 0.0 | 1.3 | ppm |
| 001-28-27A 28-Boiler Room | 6/8/2016 20:36 | 6/14/2016 12:12 | 606093127 | Lead | 4.6 | 15 | ppb |
| 001-28-27A 28-Boiler Room | 6/8/2016 20:36 | 6/14/2016 12:12 | 606093127 | Copper | 0.0 | 1.3 | ppm |
| 001-27-38A 27-Custodial Sink Faucet | 6/8/2016 21:05 | 6/14/2016 12:15 | 606093138 | Lead | 16.4 | 15 | ppb |
| 001-27-38A 27-Custodial Sink Faucet | 6/8/2016 21:05 | 6/14/2016 12:15 | 606093138 | Copper | 0.0 | 1.3 | ppm |

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Humbolt Elementary School

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 001-23-44A 23 Drinking Faucet | 6/8/2016 21:26 | 6/14/2016 12:16 | 606093144 | Lead | 2.7 | 15 | ppb |
| 001-23-44A 23 Drinking Faucet | 6/8/2016 21:26 | 6/14/2016 12:16 | 606093144 | Copper | 0.0 | 1.3 | ppm |
| 001-23-43A 23 Classroom Faucet | 6/8/2016 21:23 | 6/14/2016 13:17 | 606093143 | Lead | 14.3 | 15 | ppb |
| 001-23-43A 23 Classroom Faucet | 6/8/2016 21:23 | 6/14/2016 13:17 | 606093143 | Copper | 0.0 | 1.3 | ppm |
| 001-22-48A 22 Drinking Faucet | 6/8/2016 21:34 | 6/14/2016 12:18 | 606093148 | Lead | 21.3 | 15 | ppb |
| 001-22-48A 22 Drinking Faucet | 6/8/2016 21:34 | 6/14/2016 12:18 | 606093148 | Copper | 0.1 | 1.3 | ppm |
| 001-22-47A 22 Classroom Faucet | 6/8/2016 21:32 | 6/14/2016 12:18 | 606093147 | Lead | 17.6 | 15 | ppb |
| 001-22-47A 22 Classroom Faucet | 6/8/2016 21:32 | 6/14/2016 12:18 | 606093147 | Copper | 0.0 | 1.3 | ppm |
| 001-21-52A 21 Drinking Faucet | 6/8/2016 22:00 | 6/14/2016 12:19 | 606093152 | Lead | 8.1 | 15 | ppb |
| 001-21-52A 21 Drinking Faucet | 6/8/2016 22:00 | 6/14/2016 12:19 | 606093152 | Copper | 0.0 | 1.3 | ppm |
| 001-21-51A 21 Classroom Faucet | 6/8/2016 21:57 | 6/14/2016 12:18 | 606093151 | Lead | 34.7 | 15 | ppb |
| 001-21-51A 21 Classroom Faucet | 6/8/2016 21:57 | 6/14/2016 12:18 | 606093151 | Copper | 0.0 | 1.3 | ppm |
| 001-19-57A 19 Drinking Faucet | 6/8/2016 22:14 | 6/14/2016 12:21 | 606093157 | Lead | 34.3 | 15 | ppb |
| 001-19-57A 19 Drinking Faucet | 6/8/2016 22:14 | 6/14/2016 12:21 | 606093157 | Copper | 0.1 | 1.3 | ppm |
| 001-19-56A 19 Classroom Faucet | 6/8/2016 22:11 | 6/14/2016 12:21 | 606093156 | Lead | 37.7 | 15 | ppb |
| 001-19-56A 19 Classroom Faucet | 6/8/2016 22:11 | 6/14/2016 12:21 | 606093156 | Copper | 0.1 | 1.3 | ppm |
| 001-18-59A 18 Drinking Faucet | 6/8/2016 22:19 | 6/14/2016 12:21 | 606093159 | Lead | 1.0 | 15 | ppb |
| 001-18-59A 18 Drinking Faucet | 6/8/2016 22:19 | 6/14/2016 12:21 | 606093159 | Copper | 0.0 | 1.3 | ppm |
| 001-17-61A 17 Drinking Faucet | 6/8/2016 22:23 | 6/14/2016 12:22 | 606093161 | Lead | 4.3 | 15 | ppb |
| 001-17-61A 17 Drinking Faucet | 6/8/2016 22:23 | 6/14/2016 12:22 | 606093161 | Copper | 0.0 | 1.3 | ppm |
| 001-17-60A 17 Classroom Faucet | 6/8/2016 22:20 | 6/14/2016 12:21 | 606093160 | Lead | 14.5 | 15 | ppb |
| 001-17-60A 17 Classroom Faucet | 6/8/2016 22:20 | 6/14/2016 12:21 | 606093160 | Copper | 0.0 | 1.3 | ppm |
| 001-16-55A 16 Drinking Faucet | 6/8/2016 22:08 | 6/14/2016 12:19 | 606093155 | Lead | 5.7 | 15 | ppb |
| 001-16-55A 16 Drinking Faucet | 6/8/2016 22:08 | 6/14/2016 12:19 | 606093155 | Copper | 0.0 | 1.3 | ppm |
| 001-16-54A 16 Classroom Faucet | 6/8/2016 22:06 | 6/14/2016 12:19 | 606093154 | Lead | 24.4 | 15 | ppb |
| 001-16-54A 16 Classroom Faucet | 6/8/2016 22:06 | 6/14/2016 12:19 | 606093154 | Copper | 0.1 | 1.3 | ppm |
| 001-15-58A 18 Classroom Faucet | 6/8/2016 22:17 | 6/14/2016 12:21 | 606093158 | Lead | 19.6 | 15 | ppb |
| 001-15-58A 18 Classroom Faucet | 6/8/2016 22:17 | 6/14/2016 12:21 | 606093158 | Copper | 0.0 | 1.3 | ppm |
| 001-15-53A 15 Classroom Faucet | 6/8/2016 22:04 | 6/14/2016 12:19 | 606093153 | Lead | 35.5 | 15 | ppb |
| 001-15-53A 15 Classroom Faucet | 6/8/2016 22:04 | 6/14/2016 12:19 | 606093153 | Copper | 0.3 | 1.3 | ppm |
| 001-14-50A 14 Drinking Faucet | 6/8/2016 21:54 | 6/14/2016 12:18 | 606093150 | Lead | 3.7 | 15 | ppb |
| 001-14-50A 14 Drinking Faucet | 6/8/2016 21:54 | 6/14/2016 12:18 | 606093150 | Copper | 0.0 | 1.3 | ppm |
| 001-14-49A 14 Classroom Faucet | 6/8/2016 21:37 | 6/14/2016 12:18 | 606093149 | Lead | 17.1 | 15 | ppb |
| 001-14-49A 14 Classroom Faucet | 6/8/2016 21:37 | 6/14/2016 12:18 | 606093149 | Copper | 0.0 | 1.3 | ppm |
| 001-13-46A 13 Drinking Faucet | 6/8/2016 21:30 | 6/14/2016 12:17 | 606093146 | Lead | 4.5 | 15 | ppb |
| 001-13-46A 13 Drinking Faucet | 6/8/2016 21:30 | 6/14/2016 12:17 | 606093146 | Copper | 0.0 | 1.3 | ppm |
| 001-13-45A 13 Classroom Faucet | 6/8/2016 21:28 | 6/14/2016 12:17 | 606093145 | Lead | 24.9 | 15 | ppb |
| 001-13-45A 13 Classroom Faucet | 6/8/2016 21:28 | 6/14/2016 12:17 | 606093145 | Copper | 0.0 | 1.3 | ppm |
| 001-12-40A 12 Drinking Faucet | 6/8/2016 21:12 | 6/14/2016 12:16 | 606093140 | Lead | 17.0 | 15 | ppb |
| 001-12-40A 12 Drinking Faucet | 6/8/2016 21:12 | 6/14/2016 12:16 | 606093140 | Copper | 0.0 | 1.3 | ppm |
| 001-12-39A 12-Sink Faucet | 6/8/2016 21:09 | 6/14/2016 12:15 | 606093139 | Lead | 14.5 | 15 | ppb |
| 001-12-39A 12-Sink Faucet | 6/8/2016 21:09 | 6/14/2016 12:15 | 606093139 | Copper | 0.0 | 1.3 | ppm |
| 001-11-37A 11-Girls Bthrm Sink (4) | 6/8/2016 21:03 | 6/14/2016 12:15 | 606093137 | Lead | 4.9 | 15 | ppb |
| 001-11-37A 11-Girls Bthrm Sink (4) | 6/8/2016 21:03 | 6/14/2016 12:15 | 606093137 | Copper | 0.0 | 1.3 | ppm |
| 001-11-36A 11-Girls Bthrm Sink (3) | 6/8/2016 21:00 | 6/14/2016 12:15 | 606093136 | Lead | 5.8 | 15 | ppb |
| 001-11-36A 11-Girls Bthrm Sink (3) | 6/8/2016 21:00 | 6/14/2016 12:15 | 606093136 | Copper | 0.1 | 1.3 | ppm |
| 001-11-35A 11-Girls Bthrm Sink (2) | 6/8/2016 20:57 | 6/14/2016 12:14 | 606093135 | Lead | 3.9 | 15 | ppb |
| 001-11-35A 11-Girls Bthrm Sink (2) | 6/8/2016 20:57 | 6/14/2016 12:14 | 606093135 | Copper | 0.0 | 1.3 | ppm |
| 001-11-34A 11-Girls Bthrm Sink (1) | 6/8/2016 20:54 | 6/14/2016 12:13 | 606093134 | Lead | 7.9 | 15 | ppb |
| 001-11-34A 11-Girls Bthrm Sink (1) | 6/8/2016 20:54 | 6/14/2016 12:13 | 606093134 | Copper | 0.0 | 1.3 | ppm |
| 001-10-33A 10-Boys Bthrm Sink (4) | 6/8/2016 20:48 | 6/14/2016 12:13 | 606093133 | Lead | 7.1 | 15 | ppb |
| 001-10-33A 10-Boys Bthrm Sink (4) | 6/8/2016 20:48 | 6/14/2016 12:13 | 606093133 | Copper | 0.0 | 1.3 | ppm |

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Humbolt Elementary School

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 001-10-32A 10-Boys Bthrm Sink (3) | 6/8/2016 20:45 | 6/14/2016 13:17 | 606093132 | Lead | 10.9 | 15 | ppb |
| 001-10-32A 10-Boys Bthrm Sink (3) | 6/8/2016 20:45 | 6/14/2016 13:17 | 606093132 | Copper | 0.1 | 1.3 | ppm |
| 001-10-31A 10-Boys Bthrm Sink (2) | 6/8/2016 20:43 | 6/14/2016 12:13 | 606093131 | Lead | 6.1 | 15 | ppb |
| 001-10-31A 10-Boys Bthrm Sink (2) | 6/8/2016 20:43 | 6/14/2016 12:13 | 606093131 | Copper | 0.1 | 1.3 | ppm |
| 001-10-30A 10-Boys Bthrm Sink (1) | 6/8/2016 20:42 | 6/14/2016 13:16 | 606093130 | Lead | 7.9 | 15 | ppb |
| 001-10-30A 10-Boys Bthrm Sink (1) | 6/8/2016 20:42 | 6/14/2016 13:16 | 606093130 | Copper | 0.1 | 1.3 | ppm |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance. Based on the EPA guidance, lead concentrations in exceedance of the 15 ppb action level and copper concentrations in exceedance of the 1.3 ppm action level in more than 10% of the outlets sampled require additional actions.

Therefore, additional actions are required for the outlets with lead exceedances and no further action is required for the outlets with copper exceedances.