

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Pioneer at Holladay Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
068-01A Room 6 Sink Faucet	6/22/2016 8:47:00 PM	6/28/2016 4:52:00 PM	BB66375	Copper	0.0	1.3	ppm
068-01A Room 6 Sink Faucet	6/22/2016 8:47:00 PM	6/28/2016 4:52:00 PM	BB66375	Lead	1	15	ppb
068-02A Bathroom Sink Faucet	6/22/2016 8:52:00 PM	6/28/2016 4:55:00 PM	BB66376	Copper	0.5	1.3	ppm
068-02A Bathroom Sink Faucet	6/22/2016 8:52:00 PM	6/28/2016 4:55:00 PM	BB66376	Lead	4	15	ppb
068-03A Bathroom Tub	6/22/2016 8:54:00 PM	6/28/2016 4:58:00 PM	BB66377	Copper	0.2	1.3	ppm
068-03A Bathroom Tub	6/22/2016 8:54:00 PM	6/28/2016 4:58:00 PM	BB66377	Lead	2	15	ppb
068-04A Lunchroom Sink Faucet	6/22/2016 8:58:00 PM	6/28/2016 5:01:00 PM	BB66378	Copper	0.2	1.3	ppm
068-04A Lunchroom Sink Faucet	6/22/2016 8:58:00 PM	6/28/2016 5:01:00 PM	BB66378	Lead	8	15	ppb
068-05A Therapist Office Sink Faucet	6/22/2016 9:04:00 PM	6/28/2016 5:04:00 PM	BB66379	Copper	0.5	1.3	ppm
068-05A Therapist Office Sink Faucet	6/22/2016 9:04:00 PM	6/28/2016 5:04:00 PM	BB66379	Lead	12	15	ppb
068-06A Room 11 Sink Faucet	6/22/2016 9:09:00 PM	6/28/2016 5:07:00 PM	BB66380	Copper	0.5	1.3	ppm
068-06A Room 11 Sink Faucet	6/22/2016 9:09:00 PM	6/28/2016 5:07:00 PM	BB66380	Lead	4	15	ppb
068-07A Room 11 Drinking Fountain	6/22/2016 9:11:00 PM	6/28/2016 5:10:00 PM	BB66381	Copper	0.1	1.3	ppm
068-07A Room 11 Drinking Fountain	6/22/2016 9:11:00 PM	6/28/2016 5:10:00 PM	BB66381	Lead	3	15	ppb
068-08A Room 13 Sink Faucet	6/22/2016 9:15:00 PM	6/28/2016 5:31:00 PM	BB66382	Copper	0.5	1.3	ppm
068-08A Room 13 Sink Faucet	6/22/2016 9:15:00 PM	6/28/2016 5:31:00 PM	BB66382	Lead	3	15	ppb
068-09A Room 13 Drinking Fountain	6/22/2016 9:17:00 PM	6/28/2016 5:34:00 PM	BB66383	Copper	0.6	1.3	ppm
068-09A Room 13 Drinking Fountain	6/22/2016 9:17:00 PM	6/28/2016 5:34:00 PM	BB66383	Lead	3	15	ppb
068-10A Room 14 Sink Faucet	6/22/2016 9:20:00 PM	6/28/2016 5:37:00 PM	BB66384	Copper	0.4	1.3	ppm
068-10A Room 14 Sink Faucet	6/22/2016 9:20:00 PM	6/28/2016 5:37:00 PM	BB66384	Lead	3	15	ppb
068-11A Room 14 Drinking Fountain	6/22/2016 9:22:00 PM	6/28/2016 5:40:00 PM	BB66385	Copper	0.6	1.3	ppm
068-11A Room 14 Drinking Fountain	6/22/2016 9:22:00 PM	6/28/2016 5:40:00 PM	BB66385	Lead	3	15	ppb
068-12A Room 16 Sink Faucet	6/22/2016 9:25:00 PM	6/28/2016 5:43:00 PM	BB66386	Copper	0.5	1.3	ppm
068-12A Room 16 Sink Faucet	6/22/2016 9:25:00 PM	6/28/2016 5:43:00 PM	BB66386	Lead	5	15	ppb
068-13A Room 16 Drinking Fountain	6/22/2016 9:27:00 PM	6/28/2016 5:46:00 PM	BB66387	Copper	0.2	1.3	ppm
068-13A Room 16 Drinking Fountain	6/22/2016 9:27:00 PM	6/28/2016 5:46:00 PM	BB66387	Lead	1	15	ppb
068-14A Center Room Sink Faucet	6/22/2016 9:35:00 PM	6/28/2016 5:49:00 PM	BB66388	Copper	0.7	1.3	ppm
068-14A Center Room Sink Faucet	6/22/2016 9:35:00 PM	6/28/2016 5:49:00 PM	BB66388	Lead	1	15	ppb
068-15A Room 17 Sink Faucet	6/22/2016 9:38:00 PM	6/28/2016 5:52:00 PM	BB66389	Copper	0.3	1.3	ppm
068-15A Room 17 Sink Faucet	6/22/2016 9:38:00 PM	6/28/2016 5:52:00 PM	BB66389	Lead	3	15	ppb
068-16A Room 19 Women's Bathroom Sink Faucet	6/22/2016 9:43:00 PM	6/28/2016 5:55:00 PM	BB66390	Copper	0.4	1.3	ppm
068-16A Room 19 Women's Bathroom Sink Faucet	6/22/2016 9:43:00 PM	6/28/2016 5:55:00 PM	BB66390	Lead	2	15	ppb
068-17A Room 20 Men's Bathroom Sink Faucet	6/22/2016 9:46:00 PM	6/28/2016 5:59:00 PM	BB66391	Copper	0.4	1.3	ppm
068-17A Room 20 Men's Bathroom Sink Faucet	6/22/2016 9:46:00 PM	6/28/2016 5:59:00 PM	BB66391	Lead	2	15	ppb
068-18A Entry Drinking Fountain	6/22/2016 9:50:00 PM	6/28/2016 6:14:00 PM	BB66392	Copper	0.4	1.3	ppm
068-18A Entry Drinking Fountain	6/22/2016 9:50:00 PM	6/28/2016 6:14:00 PM	BB66392	Lead	2	15	ppb
068-19A Kitchen Janitor Sink Faucet	6/22/2016 9:53:00 PM	6/28/2016 6:17:00 PM	BB66393	Copper	0.3	1.3	ppm
068-19A Kitchen Janitor Sink Faucet	6/22/2016 9:53:00 PM	6/28/2016 6:17:00 PM	BB66393	Lead	5	15	ppb
068-20A Kitchen Sink Faucet 1	6/22/2016 10:00:00 PM	7/5/2016 7:34:00 PM	BB66394	Copper	2.3	1.3	ppm
068-20A Kitchen Sink Faucet 1	6/22/2016 10:00:00 PM	7/5/2016 1:14:00 PM	BB66394	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Pioneer at Holladay Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
068-21A Kitchen Sink Faucet 2	6/22/2016 10:04:00 PM	7/5/2016 7:37:00 PM	BB66395	Copper	2.7	1.3	ppm
068-21A Kitchen Sink Faucet 2	6/22/2016 10:04:00 PM	7/5/2016 1:18:00 PM	BB66395	Lead	6	15	ppb
068-22A Room 40 Janitor Closet Sink Faucet	6/22/2016 10:07:00 PM	6/28/2016 6:20:00 PM	BB66396	Copper	0.5	1.3	ppm
068-22A Room 40 Janitor Closet Sink Faucet	6/22/2016 10:07:00 PM	6/28/2016 6:20:00 PM	BB66396	Lead	6	15	ppb
068-23A Room 1 Sink Faucet	6/22/2016 10:10:00 PM	6/28/2016 6:23:00 PM	BB66397	Copper	0.5	1.3	ppm
068-23A Room 1 Sink Faucet	6/22/2016 10:10:00 PM	6/28/2016 6:23:00 PM	BB66397	Lead	4	15	ppb
068-24A Room 1 Drinking Fountain	6/22/2016 10:12:00 PM	6/28/2016 6:26:00 PM	BB66398	Copper	0.6	1.3	ppm
068-24A Room 1 Drinking Fountain	6/22/2016 10:12:00 PM	6/28/2016 6:26:00 PM	BB66398	Lead	2	15	ppb
068-25A Room 3 Sink Faucet	6/22/2016 10:15:00 PM	6/28/2016 6:29:00 PM	BB66399	Copper	0.5	1.3	ppm
068-25A Room 3 Sink Faucet	6/22/2016 10:15:00 PM	6/28/2016 6:29:00 PM	BB66399	Lead	4	15	ppb
068-26A Room 3 Drinking Fountain	6/22/2016 10:17:00 PM	6/28/2016 6:32:00 PM	BB66400	Copper	0.1	1.3	ppm
068-26A Room 3 Drinking Fountain	6/22/2016 10:17:00 PM	6/28/2016 6:32:00 PM	BB66400	Lead	2	15	ppb
068-27A Boys Bathroom Sink Faucet 1 (Mop)	6/22/2016 10:22:00 PM	6/28/2016 6:35:00 PM	BB66401	Copper	0.3	1.3	ppm
068-27A Boys Bathroom Sink Faucet 1 (Mop)	6/22/2016 10:22:00 PM	6/28/2016 6:35:00 PM	BB66401	Lead	0	15	ppb
068-28A Boys Bathroom Sink Faucet 2	6/22/2016 10:24:00 PM	6/28/2016 6:38:00 PM	BB66402	Copper	0.4	1.3	ppm
068-28A Boys Bathroom Sink Faucet 2	6/22/2016 10:24:00 PM	6/28/2016 6:38:00 PM	BB66402	Lead	4	15	ppb
068-29A Boys Bathroom Sink Faucet 3	6/22/2016 10:26:00 PM	6/28/2016 6:41:00 PM	BB66403	Copper	0.2	1.3	ppm
068-29A Boys Bathroom Sink Faucet 3	6/22/2016 10:26:00 PM	6/28/2016 6:41:00 PM	BB66403	Lead	4	15	ppb
068-30A Boys Bathroom Sink Faucet 4	6/22/2016 10:28:00 PM	6/29/2016 5:18:00 PM	BB66404	Copper	0.2	1.3	ppm
068-30A Boys Bathroom Sink Faucet 4	6/22/2016 10:28:00 PM	6/29/2016 5:18:00 PM	BB66404	Lead	1	15	ppb
068-31A Girls Bathroom Sink Faucet 1	6/22/2016 10:30:00 PM	6/28/2016 7:05:00 PM	BB66405	Copper	0.4	1.3	ppm
068-31A Girls Bathroom Sink Faucet 1	6/22/2016 10:30:00 PM	6/28/2016 7:05:00 PM	BB66405	Lead	0	15	ppb
068-32A Girls Bathroom Sink Faucet 2	6/22/2016 10:32:00 PM	6/28/2016 7:08:00 PM	BB66406	Copper	0.4	1.3	ppm
068-32A Girls Bathroom Sink Faucet 2	6/22/2016 10:32:00 PM	6/28/2016 7:08:00 PM	BB66406	Lead	0	15	ppb
068-33A Girls Bathroom Sink Faucet 3 (Mop)	6/22/2016 10:24:00 PM	6/28/2016 7:11:00 PM	BB66407	Copper	0.6	1.3	ppm
068-33A Girls Bathroom Sink Faucet 3 (Mop)	6/22/2016 10:24:00 PM	6/28/2016 7:11:00 PM	BB66407	Lead	0	15	ppb
068-34A Group Room Sink Faucet	6/22/2016 10:36:00 PM	6/29/2016 5:21:00 PM	BB66408	Copper	0.4	1.3	ppm
068-34A Group Room Sink Faucet	6/22/2016 10:36:00 PM	6/29/2016 5:21:00 PM	BB66408	Lead	4	15	ppb
068-35A Room 4 Sink Faucet	6/22/2016 10:40:00 PM	6/28/2016 7:17:00 PM	BB66409	Copper	0.3	1.3	ppm
068-35A Room 4 Sink Faucet	6/22/2016 10:40:00 PM	6/28/2016 7:17:00 PM	BB66409	Lead	5	15	ppb
068-36A Room 4 Drinking Fountain	6/22/2016 10:42:00 PM	6/28/2016 7:20:00 PM	BB66410	Copper	0.6	1.3	ppm
068-36A Room 4 Drinking Fountain	6/22/2016 10:42:00 PM	6/28/2016 7:20:00 PM	BB66410	Lead	2	15	ppb
068-37A Exterior Water Spigot 1	6/22/2016 10:50:00 PM	6/28/2016 7:23:00 PM	BB66411	Copper	0.1	1.3	ppm
068-37A Exterior Water Spigot 1	6/22/2016 10:50:00 PM	6/28/2016 7:23:00 PM	BB66411	Lead	0	15	ppb
068-38A Exterior Water Spigot 2	6/22/2016 10:54:00 PM	6/28/2016 7:26:00 PM	BB66412	Copper	0.1	1.3	ppm
068-38A Exterior Water Spigot 2	6/22/2016 10:54:00 PM	6/28/2016 7:26:00 PM	BB66412	Lead	0	15	ppb
068-39A Exterior Water Spigot 3	6/22/2016 10:57:00 PM	6/29/2016 5:24:00 PM	BB66413	Copper	0.1	1.3	ppm
068-39A Exterior Water Spigot 3	6/22/2016 10:57:00 PM	6/29/2016 5:24:00 PM	BB66413	Lead	0	15	ppb
068-40A Exterior Water Spigot 11	6/22/2016 11:00:00 PM	6/28/2016 7:45:00 PM	BB66414	Copper	0.1	1.3	ppm
068-40A Exterior Water Spigot 11	6/22/2016 11:00:00 PM	6/28/2016 7:45:00 PM	BB66414	Lead	0	15	ppb

Portland Public Schools
 Lead and Copper Water Sampling Results
 A (First Draw) Sample Data
 Pioneer at Holladay Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
068-41A Exterior Water Spigot 5	6/22/2016 11:03:00 PM	6/28/2016 7:48:00 PM	BB66415	Copper	0.1	1.3	ppm
068-41A Exterior Water Spigot 5	6/22/2016 11:03:00 PM	6/28/2016 7:48:00 PM	BB66415	Lead	1	15	ppb
068-42A Exterior Water Spigot 6	6/22/2016 11:07:00 PM	6/28/2016 7:51:00 PM	BB66416	Copper	0.1	1.3	ppm
068-42A Exterior Water Spigot 6	6/22/2016 11:07:00 PM	6/28/2016 7:51:00 PM	BB66416	Lead	0	15	ppb
068-43A Exterior Water Spigot 7	6/22/2016 11:09:00 PM	6/28/2016 7:54:00 PM	BB66417	Copper	0.1	1.3	ppm
068-43A Exterior Water Spigot 7	6/22/2016 11:09:00 PM	6/28/2016 7:54:00 PM	BB66417	Lead	0	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.