

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ainsworth Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
003-BR-01A Boiler Room Water Spigot	6/16/2016 9:23	6/23/2016 12:24	606171401	Copper	0.0	1.3	ppm
003-BR-01A Boiler Room Water Spigot	6/16/2016 9:23	6/23/2016 12:24	606171401	Lead	2	15	ppb
003-BRO-02A Boiler Room Office Sink	6/16/2016 9:27	6/23/2016 12:24	606171402	Copper	0.0	1.3	ppm
003-BRO-02A Boiler Room Office Sink	6/16/2016 9:27	6/23/2016 12:24	606171402	Lead	1	15	ppb
003-BBF-03A Boys Bathroom Faucet	6/16/2016 9:36	6/23/2016 12:24	606171403	Copper	0.0	1.3	ppm
003-BBF-03A Boys Bathroom Faucet	6/16/2016 9:36	6/23/2016 12:24	606171403	Lead	1	15	ppb
003-BBF-04A Boys Bathroom Faucet	6/16/2016 9:38	6/23/2016 12:24	606171404	Copper	0.0	1.3	ppm
003-BBF-04A Boys Bathroom Faucet	6/16/2016 9:38	6/23/2016 12:24	606171404	Lead	3	15	ppb
003-TL-05A Teachers Lounge Sink	6/16/2016 9:43	6/23/2016 12:25	606171405	Copper	0.0	1.3	ppm
003-TL-05A Teachers Lounge Sink	6/16/2016 9:43	6/23/2016 12:25	606171405	Lead	1	15	ppb
003-TS-06A Teachers Storage Sink	6/16/2016 9:45	6/23/2016 12:26	606171406	Copper	0.1	1.3	ppm
003-TS-06A Teachers Storage Sink	6/16/2016 9:45	6/23/2016 12:26	606171406	Lead	22	15	ppb
003-K-07A Kitchen Dish Washer Sink	6/16/2016 9:51	6/23/2016 12:26	606171407	Copper	0.1	1.3	ppm
003-K-07A Kitchen Dish Washer Sink	6/16/2016 9:51	6/23/2016 12:26	606171407	Lead	1	15	ppb
003-K-08A Kitchen Sink	6/16/2016 9:54	6/23/2016 12:26	606171408	Copper	0.1	1.3	ppm
003-K-08A Kitchen Sink	6/16/2016 9:54	6/23/2016 12:26	606171408	Lead	1	15	ppb
003-K-09A Kitchen Bathroom Sink	6/16/2016 10:00	6/23/2016 12:26	606171409	Copper	0.1	1.3	ppm
003-K-09A Kitchen Bathroom Sink	6/16/2016 10:00	6/23/2016 12:26	606171409	Lead	3	15	ppb
003-K-10A Kitchen Eye Wash Sink	6/16/2016 10:02	6/23/2016 12:26	606171410	Copper	0.1	1.3	ppm
003-K-10A Kitchen Eye Wash Sink	6/16/2016 10:02	6/23/2016 12:26	606171410	Lead	0	15	ppb
003-K-11A Kitchen Janitors Sink	6/16/2016 10:06	6/23/2016 12:26	606171411	Copper	0.1	1.3	ppm
003-K-11A Kitchen Janitors Sink	6/16/2016 10:06	6/23/2016 12:26	606171411	Lead	2	15	ppb
003-GBF-12A Girls Bathroom Sink	6/16/2016 10:11	6/23/2016 12:26	606171412	Copper	0.1	1.3	ppm
003-GBF-12A Girls Bathroom Sink	6/16/2016 10:11	6/23/2016 12:26	606171412	Lead	3	15	ppb
003-GBF-13A Girls Bathroom Sink	6/16/2016 10:12	6/23/2016 12:26	606171413	Copper	0.1	1.3	ppm
003-GBF-13A Girls Bathroom Sink	6/16/2016 10:12	6/23/2016 12:26	606171413	Lead	3	15	ppb
003-GBF-14A Girls Bathroom Sink	6/16/2016 10:14	6/23/2016 12:26	606171414	Copper	0.2	1.3	ppm
003-GBF-14A Girls Bathroom Sink	6/16/2016 10:14	6/23/2016 12:26	606171414	Lead	2	15	ppb
003-DF-15A Drinking Fountain Hallway	6/16/2016 10:21	6/23/2016 12:27	606171415	Copper	0.2	1.3	ppm
003-DF-15A Drinking Fountain Hallway	6/16/2016 10:21	6/23/2016 12:27	606171415	Lead	5	15	ppb
003-DF-16A Drinking Fountain Cafeteria	6/16/2016 10:23	6/23/2016 12:27	606171416	Copper	0.2	1.3	ppm
003-DF-16A Drinking Fountain Cafeteria	6/16/2016 10:23	6/23/2016 12:27	606171416	Lead	0	15	ppb
003-HS-17A Hallway Sink	6/16/2016 10:29	6/23/2016 12:27	606171417	Copper	0.2	1.3	ppm
003-HS-17A Hallway Sink	6/16/2016 10:29	6/23/2016 12:27	606171417	Lead	7	15	ppb
003-DF-18A Drinking Fountain Hallway	6/16/2016 10:31	6/23/2016 12:27	606171418	Copper	0.2	1.3	ppm
003-DF-18A Drinking Fountain Hallway	6/16/2016 10:31	6/23/2016 12:27	606171418	Lead	2	15	ppb
003-CR2-19A Classroom 2 Sink	6/16/2016 10:39	6/23/2016 12:27	606171419	Copper	0.2	1.3	ppm
003-CR2-19A Classroom 2 Sink	6/16/2016 10:39	6/23/2016 12:27	606171419	Lead	4	15	ppb
003-DF-20A Drinking Fountain Hallway	6/16/2016 10:41	6/23/2016 12:27	606171420	Copper	0.2	1.3	ppm
003-DF-20A Drinking Fountain Hallway	6/16/2016 10:41	6/23/2016 12:27	606171420	Lead	12	15	ppb
003-JC-21A Janitors Closet Sink	6/16/2016 10:44	6/23/2016 12:27	606171421	Copper	0.2	1.3	ppm
003-JC-21A Janitors Closet Sink	6/16/2016 10:44	6/23/2016 12:27	606171421	Lead	17	15	ppb
003-PO-22A Principles Office Sink	6/16/2016 10:47	6/23/2016 12:28	606171422	Copper	0.3	1.3	ppm
003-PO-22A Principles Office Sink	6/16/2016 10:47	6/23/2016 12:28	606171422	Lead	3	15	ppb
003-PO-23A Drinking Dispenser Mailroom	6/16/2016 10:48	6/23/2016 12:28	606171423	Copper	0.3	1.3	ppm
003-PO-23A Drinking Dispenser Mailroom	6/16/2016 10:48	6/23/2016 12:28	606171423	Lead	ND	15	ppb
003-DF-24A Drinking Fountain Left	6/16/2016 10:53	6/23/2016 12:28	606171424	Copper	0.3	1.3	ppm
003-DF-24A Drinking Fountain Left	6/16/2016 10:53	6/23/2016 12:28	606171424	Lead	1	15	ppb
003-DF-25A Drinking Fountain Center	6/16/2016 10:55	6/23/2016 12:29	606171425	Copper	0.3	1.3	ppm
003-DF-25A Drinking Fountain Center	6/16/2016 10:55	6/23/2016 12:29	606171425	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ainsworth Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
003-DF-26A Drinking Fountain Right	6/16/2016 10:56	6/23/2016 12:29	606171426	Copper	0.3	1.3	ppm
003-DF-26A Drinking Fountain Right	6/16/2016 10:56	6/23/2016 12:29	606171426	Lead	2	15	ppb
003-BGB-27A Boys/Girls Bathroom Sink Left	6/16/2016 11:49	6/23/2016 12:29	606171427	Copper	0.3	1.3	ppm
003-BGB-27A Boys/Girls Bathroom Sink Left	6/16/2016 11:49	6/23/2016 12:29	606171427	Lead	4	15	ppb
003-CR6-28A Classroom 6 Sink	6/16/2016 11:11	6/23/2016 12:29	606171428	Copper	0.3	1.3	ppm
003-CR6-28A Classroom 6 Sink	6/16/2016 11:11	6/23/2016 12:29	606171428	Lead	2	15	ppb
003-CR6-29A Classroom 6 Drinking Fountain	6/16/2016 11:12	6/23/2016 12:29	606171429	Copper	0.3	1.3	ppm
003-CR6-29A Classroom 6 Drinking Fountain	6/16/2016 11:12	6/23/2016 12:29	606171429	Lead	11	15	ppb
003-CR5-30A Classroom 5 Sink	6/16/2016 11:16	6/23/2016 12:29	606171430	Copper	0.3	1.3	ppm
003-CR5-30A Classroom 5 Sink	6/16/2016 11:16	6/23/2016 12:29	606171430	Lead	3	15	ppb
003-CR5-31A Classroom 5 Drinking Fountain	6/16/2016 11:16	6/23/2016 12:31	606171431	Copper	0.3	1.3	ppm
003-CR5-31A Classroom 5 Drinking Fountain	6/16/2016 11:16	6/23/2016 12:31	606171431	Lead	3	15	ppb
003-DF-32A Drinking Fountain Hallway 2nd F Left	6/16/2016 11:26	6/23/2016 12:29	606171432	Copper	0.3	1.3	ppm
003-DF-32A Drinking Fountain Hallway 2nd F Left	6/16/2016 11:26	6/23/2016 12:29	606171432	Lead	9	15	ppb
003-DF-33A Drinking Fountain Hallway 2nd F Right	6/16/2016 11:28	6/23/2016 12:29	606171433	Copper	0.3	1.3	ppm
003-DF-33A Drinking Fountain Hallway 2nd F Right	6/16/2016 11:28	6/23/2016 12:29	606171433	Lead	7	15	ppb
003-CR9-34A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:29	606171434	Copper	0.4	1.3	ppm
003-CR9-34A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:29	606171434	Lead	39	15	ppb
003-CR9-35A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:29	606171435	Copper	0.4	1.3	ppm
003-CR9-35A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:29	606171435	Lead	26	15	ppb
003-CR9-36A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:31	606171436	Copper	0.4	1.3	ppm
003-CR9-36A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:31	606171436	Lead	20	15	ppb
003-CR9-37A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:31	606171437	Copper	0.4	1.3	ppm
003-CR9-37A Classroom 9 Sink	6/16/2016 11:31	6/23/2016 12:31	606171437	Lead	6	15	ppb
003-DF-38A Library Sink	6/16/2016 11:44	6/23/2016 12:31	606171438	Copper	0.5	1.3	ppm
003-DF-38A Library Sink	6/16/2016 11:44	6/23/2016 12:31	606171438	Lead	7	15	ppb
003-CR34-39A Classroom 34 Sink	6/16/2016 12:10	6/23/2016 12:31	606171439	Copper	0.5	1.3	ppm
003-CR34-39A Classroom 34 Sink	6/16/2016 12:10	6/23/2016 12:31	606171439	Lead	3	15	ppb
003-CR34-40A Classroom 34 Drinking Fountain	6/16/2016 12:10	6/23/2016 12:31	606171440	Copper	0.5	1.3	ppm
003-CR34-40A Classroom 34 Drinking Fountain	6/16/2016 12:10	6/23/2016 12:31	606171440	Lead	6	15	ppb
003-GBF-41A Girls Bathroom Faucet Left	6/16/2016 12:12	6/23/2016 12:31	606171441	Copper	0.6	1.3	ppm
003-GBF-41A Girls Bathroom Faucet Left	6/16/2016 12:12	6/23/2016 12:31	606171441	Lead	9	15	ppb
003-GBF-42A Girls Bathroom Faucet Right	6/16/2016 12:12	6/23/2016 12:48	606171442	Copper	0.6	1.3	ppm
003-GBF-42A Girls Bathroom Faucet Right	6/16/2016 12:12	6/23/2016 12:48	606171442	Lead	12	15	ppb
003-BGBF-43A Boys/Girls Bathroom Faucet	6/16/2016 12:15	6/23/2016 12:48	606171443	Copper	0.0	1.3	ppm
003-BGBF-43A Boys/Girls Bathroom Faucet	6/16/2016 12:15	6/23/2016 12:48	606171443	Lead	6	15	ppb
003-JCS-44A Janitors Closet Sink	6/16/2016 12:18	6/23/2016 12:48	606171444	Copper	0.0	1.3	ppm
003-JCS-44A Janitors Closet Sink	6/16/2016 12:18	6/23/2016 12:48	606171444	Lead	15.2	15	ppb
003-BBF-45A Boys Bathroom Faucet Left	6/16/2016 12:21	6/23/2016 12:49	606171445	Copper	0.0	1.3	ppm
003-BBF-45A Boys Bathroom Faucet Left	6/16/2016 12:21	6/23/2016 12:49	606171445	Lead	20	15	ppb
003-BBF-46A Boys Bathroom Faucet Right	6/16/2016 12:21	6/23/2016 12:49	606171446	Copper	0.0	1.3	ppm
003-BBF-46A Boys Bathroom Faucet Right	6/16/2016 12:21	6/23/2016 12:49	606171446	Lead	16	15	ppb
003-CR33-47A Classroom 33 Sink	6/16/2016 12:24	6/23/2016 12:49	606171447	Copper	0.0	1.3	ppm
003-CR33-47A Classroom 33 Sink	6/16/2016 12:24	6/23/2016 12:49	606171447	Lead	10	15	ppb
003-CR33-48A Classroom 33 Drinking Fountain	6/16/2016 12:24	6/23/2016 12:49	606171448	Copper	0.0	1.3	ppm
003-CR33-48A Classroom 33 Drinking Fountain	6/16/2016 12:24	6/23/2016 12:49	606171448	Lead	9	15	ppb
003-CR32-49A Classroom 32 Sink	6/16/2016 12:28	6/23/2016 12:49	606171449	Copper	0.0	1.3	ppm
003-CR32-49A Classroom 32 Sink	6/16/2016 12:28	6/23/2016 12:49	606171449	Lead	15.3	15	ppb
003-CR32-50A Classroom 32 Drinking Fountain	6/16/2016 12:28	6/23/2016 12:49	606171450	Copper	0.0	1.3	ppm
003-CR32-50A Classroom 32 Drinking Fountain	6/16/2016 12:28	6/23/2016 12:49	606171450	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ainsworth Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
003-CR31-51A Classroom 31 Sink	6/16/2016 12:26	6/23/2016 12:49	606171451	Copper	0.0	1.3	ppm
003-CR31-51A Classroom 31 Sink	6/16/2016 12:26	6/23/2016 12:49	606171451	Lead	7	15	ppb
003-CR31-52A Classroom 31 Drinking Fountain	6/16/2016 12:26	6/23/2016 12:49	606171452	Copper	0.0	1.3	ppm
003-CR31-52A Classroom 31 Drinking Fountain	6/16/2016 12:26	6/23/2016 12:49	606171452	Lead	7	15	ppb
003-CR21-53A Classroom 21 Sink	6/16/2016 12:39	6/23/2016 12:49	606171453	Copper	0.0	1.3	ppm
003-CR21-53A Classroom 21 Sink	6/16/2016 12:39	6/23/2016 12:49	606171453	Lead	30	15	ppb
003-CR21-54A Classroom 21 Drinking Fountain	6/16/2016 12:39	6/23/2016 12:49	606171454	Copper	0.0	1.3	ppm
003-CR21-54A Classroom 21 Drinking Fountain	6/16/2016 12:39	6/23/2016 12:49	606171454	Lead	24	15	ppb
003-CR22-55A Classroom 22 Sink	6/16/2016 12:42	6/23/2016 12:50	606171455	Copper	0.0	1.3	ppm
003-CR22-55A Classroom 22 Sink	6/16/2016 12:42	6/23/2016 12:50	606171455	Lead	18	15	ppb
003-BBF-58A Boys Bathroom Faucet Right	6/16/2016 12:51	6/23/2016 12:51	606171456	Copper	0.0	1.3	ppm
003-BBF-58A Boys Bathroom Faucet Right	6/16/2016 12:51	6/23/2016 12:51	606171456	Lead	6	15	ppb
003-JCS-59A Janitors Closet Sink	6/16/2016 12:47	6/23/2016 12:51	606171457	Copper	0.0	1.3	ppm
003-JCS-59A Janitors Closet Sink	6/16/2016 12:47	6/23/2016 12:51	606171457	Lead	7	15	ppb
003-GBF-60A Girls Bathroom Faucet Left	6/16/2016 12:57	6/23/2016 12:51	606171458	Copper	0.0	1.3	ppm
003-GBF-60A Girls Bathroom Faucet Left	6/16/2016 12:57	6/23/2016 12:51	606171458	Lead	9	15	ppb
003-GBF-61A Girls Bathroom Faucet Right	6/16/2016 12:58	6/23/2016 12:51	606171459	Copper	0.0	1.3	ppm
003-GBF-61A Girls Bathroom Faucet Right	6/16/2016 12:58	6/23/2016 12:51	606171459	Lead	8	15	ppb
003-GBF-62A Girls Bathroom Spigot	6/16/2016 12:59	6/23/2016 10:56	606171460	Copper	0.0	1.3	ppm
003-GBF-62A Girls Bathroom Spigot	6/16/2016 12:59	6/23/2016 10:56	606171460	Lead	17	15	ppb
003-TBF-63A Teachers Bathroom Faucet	6/16/2016 12:55	6/23/2016 12:51	606171461	Copper	0.0	1.3	ppm
003-TBF-63A Teachers Bathroom Faucet	6/16/2016 12:55	6/23/2016 12:51	606171461	Lead	11	15	ppb
003-CR23-64A Classroom 23 Sink	6/16/2016 13:01	6/23/2016 12:51	606171462	Copper	0.0	1.3	ppm
003-CR23-64A Classroom 23 Sink	6/16/2016 13:01	6/23/2016 12:51	606171462	Lead	5	15	ppb
003-CR23-65A Classroom 23 Drinking Fountain	6/16/2016 13:01	6/23/2016 12:51	606171463	Copper	0.0	1.3	ppm
003-CR23-65A Classroom 23 Drinking Fountain	6/16/2016 13:01	6/23/2016 12:51	606171463	Lead	8	15	ppb
003-CR24-66A Classroom 24 Sink	6/16/2016 12:54	6/23/2016 12:51	606171464	Copper	0.0	1.3	ppm
003-CR24-66A Classroom 24 Sink	6/16/2016 12:54	6/23/2016 12:51	606171464	Lead	6	15	ppb
003-CR24-67A Classroom 24 Drinking Fountain	6/16/2016 12:54	6/23/2016 12:51	606171465	Copper	0.0	1.3	ppm
003-CR24-67A Classroom 24 Drinking Fountain	6/16/2016 12:54	6/23/2016 12:51	606171465	Lead	5	15	ppb
003-CR25-68A Classroom 25 Sink	6/16/2016 13:15	6/23/2016 13:52	606171466	Copper	0.0	1.3	ppm
003-CR25-68A Classroom 25 Sink	6/16/2016 13:15	6/23/2016 13:52	606171466	Lead	88	15	ppb
003-CR25-69A Classroom 25 Drinking Fountain	6/16/2016 13:15	6/23/2016 13:59	606171467	Copper	0.0	1.3	ppm
003-CR25-69A Classroom 25 Drinking Fountain	6/16/2016 13:15	6/23/2016 13:59	606171467	Lead	9	15	ppb
003-GBF-70A Girls Bathroom Faucet	6/16/2016 13:19	6/23/2016 13:59	606171468	Copper	0.0	1.3	ppm
003-GBF-70A Girls Bathroom Faucet	6/16/2016 13:19	6/23/2016 13:59	606171468	Lead	39	15	ppb
003-BBF-71A Boys Bathroom Faucet	6/16/2016 13:23	6/23/2016 13:59	606171469	Copper	0.0	1.3	ppm
003-BBF-71A Boys Bathroom Faucet	6/16/2016 13:23	6/23/2016 13:59	606171469	Lead	76	15	ppb
003-BBF-72A Boys Bathroom Spigot	6/16/2016 13:24	6/23/2016 13:59	606171470	Copper	0.0	1.3	ppm
003-BBF-72A Boys Bathroom Spigot	6/16/2016 13:24	6/23/2016 13:59	606171470	Lead	21	15	ppb
003-CR26-73A Classroom 26 Sink	6/16/2016 13:25	6/23/2016 13:59	606171471	Copper	0.0	1.3	ppm
003-CR26-73A Classroom 26 Sink	6/16/2016 13:25	6/23/2016 13:59	606171471	Lead	84	15	ppb
003-CR26-74A Classroom 26 Drinking Fountain	6/16/2016 13:25	6/23/2016 13:59	606171472	Copper	0.0	1.3	ppm
003-CR26-74A Classroom 26 Drinking Fountain	6/16/2016 13:25	6/23/2016 13:59	606171472	Lead	29	15	ppb
003-DF-75A Drinking Fountain East Side	6/16/2016 13:41	6/23/2016 13:59	606171473	Copper	0.0	1.3	ppm
003-DF-75A Drinking Fountain East Side	6/16/2016 13:41	6/23/2016 13:59	606171473	Lead	0	15	ppb
003-SF-76A Spigot East Side	6/16/2016 13:41	6/23/2016 13:59	606171474	Copper	0.0	1.3	ppm
003-SF-76A Spigot East Side	6/16/2016 13:41	6/23/2016 13:59	606171474	Lead	3	15	ppb
003-SF-77A Spigot Southeast	6/16/2016 13:51	6/23/2016 14:00	606171475	Copper	0.0	1.3	ppm
003-SF-77A Spigot Southeast	6/16/2016 13:51	6/23/2016 14:00	606171475	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ainsworth Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
003-OSF-78A Spigot South Between B	6/16/2016 13:58	6/23/2016 14:45	606171476	Copper	0.0	1.3	ppm
003-OSF-78A Spigot South Between B	6/16/2016 13:58	6/23/2016 14:45	606171476	Lead	30	15	ppb
003-OSF-79A Spigot South Main	6/16/2016 13:59	6/23/2016 14:46	606171477	Copper	0.0	1.3	ppm
003-OSF-79A Spigot South Main	6/16/2016 13:59	6/23/2016 14:46	606171477	Lead	13	15	ppb
003-OSF-80A Spigot West	6/16/2016 14:07	6/23/2016 14:46	606171478	Copper	0.0	1.3	ppm
003-OSF-80A Spigot West	6/16/2016 14:07	6/23/2016 14:46	606171478	Lead	5	15	ppb
003-R17-82A Room 17 Sink	6/16/2016 14:14	6/23/2016 14:46	606171479	Copper	0.0	1.3	ppm
003-R17-82A Room 17 Sink	6/16/2016 14:14	6/23/2016 14:46	606171479	Lead	2	15	ppb
003-R17-83A Room 17 Drinking Fountain	6/16/2016 14:14	6/23/2016 14:46	606171480	Copper	0.0	1.3	ppm
003-R17-83A Room 17 Drinking Fountain	6/16/2016 14:14	6/23/2016 14:46	606171480	Lead	1	15	ppb
003-JC-84A Janitors Closet 2nd Floor	6/16/2016 11:44	6/23/2016 14:46	606171481	Copper	0.0	1.3	ppm
003-JC-84A Janitors Closet 2nd Floor	6/16/2016 11:44	6/23/2016 14:46	606171481	Lead	13	15	ppb
003-CL4-85A Classroom 4 Faucet Sink	6/16/2016 11:48	6/23/2016 14:46	606171482	Copper	0.0	1.3	ppm
003-CL4-85A Classroom 4 Faucet Sink	6/16/2016 11:48	6/23/2016 14:46	606171482	Lead	6	15	ppb
003-BGB-86A Boys/Girls Bath 1st Floor Right BR2	6/16/2016 11:50	6/23/2016 14:47	606171483	Copper	0.0	1.3	ppm
003-BGB-86A Boys/Girls Bath 1st Floor Right BR2	6/16/2016 11:50	6/23/2016 14:47	606171483	Lead	3	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm