

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Ainsworth Elementary School Annex

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
003A-AR-01A Art Room Sink	6/16/2016 15:08	6/23/2016 12:17	606171101	Copper	0.1	1.3	ppm
003A-AR-01A Art Room Sink	6/16/2016 15:08	6/23/2016 12:17	606171101	Lead	3	15	ppb
003A-AR-02A Art Room Drinking Fountain	6/16/2016 15:08	6/23/2016 12:17	606171102	Copper	0.3	1.3	ppm
003A-AR-02A Art Room Drinking Fountain	6/16/2016 15:08	6/23/2016 12:17	606171102	Lead	13	15	ppb
003A-BBF-05A Boys Bathroom Faucet Left	6/16/2016 15:10	6/23/2016 12:18	606171105	Copper	0.3	1.3	ppm
003A-BBF-05A Boys Bathroom Faucet Left	6/16/2016 15:10	6/23/2016 12:18	606171105	Lead	3	15	ppb
003A-MBF-04A Mens Bathroom Faucet	6/16/2016 14:57	6/23/2016 12:18	606171104	Copper	0.4	1.3	ppm
003A-MBF-04A Mens Bathroom Faucet	6/16/2016 14:57	6/23/2016 12:18	606171104	Lead	12	15	ppb
003A-WBF-03A Womens Bathroom Faucet	6/16/2016 14:59	6/23/2016 12:18	606171103	Copper	0.4	1.3	ppm
003A-WBF-03A Womens Bathroom Faucet	6/16/2016 14:59	6/23/2016 12:18	606171103	Lead	12	15	ppb
003A-BBF-06A Boys Bathroom Faucet Right	6/16/2016 15:01	6/23/2016 12:22	606171106	Copper	0.4	1.3	ppm
<b>003A-BBF-06A Boys Bathroom Faucet Right</b>	<b>6/16/2016 15:01</b>	<b>6/23/2016 12:22</b>	<b>606171106</b>	<b>Lead</b>	<b>61</b>	<b>15</b>	<b>ppb</b>
003A-CRA1-11A Classroom A1 Sink	6/16/2016 15:12	6/23/2016 12:22	606171111	Copper	0.5	1.3	ppm
003A-CRA1-11A Classroom A1 Sink	6/16/2016 15:12	6/23/2016 12:22	606171111	Lead	15	15	ppb
003A-CRA1-12A Classroom A1 Drinking Fountain	6/16/2016 15:12	6/23/2016 12:22	606171112	Copper	0.5	1.3	ppm
003A-CRA1-12A Classroom A1 Drinking Fountain	6/16/2016 15:12	6/23/2016 12:22	606171112	Lead	1	15	ppb
003A-CRA2-13A Classroom A2 Sink Faucet	6/16/2016 15:13	6/23/2016 12:22	606171113	Copper	0.6	1.3	ppm
003A-CRA2-13A Classroom A2 Sink Faucet	6/16/2016 15:13	6/23/2016 12:22	606171113	Lead	10	15	ppb
003A-CRA2-14A Classroom A2 Drinking Fountain	6/16/2016 15:13	6/23/2016 12:22	606171114	Copper	0.7	1.3	ppm
003A-CRA2-14A Classroom A2 Drinking Fountain	6/16/2016 15:13	6/23/2016 12:22	606171114	Lead	3	15	ppb
003A-CRA3-15A Classroom A3 Sink Faucet	6/16/2016 15:15	6/23/2016 12:22	606171115	Copper	2.3	1.3	ppm
003A-CRA3-15A Classroom A3 Sink Faucet	6/16/2016 15:15	6/23/2016 12:22	606171115	Lead	6	15	ppb
003A-DF-09A Drinking Fountain	6/16/2016 15:06	6/23/2016 12:22	606171109	Copper	0.0	1.3	ppm
003A-DF-09A Drinking Fountain	6/16/2016 15:06	6/23/2016 12:22	606171109	Lead	7	15	ppb
003A-GBF-07A Girls Bathroom Faucet Left	6/16/2016 15:01	6/23/2016 12:22	606171107	Copper	0.0	1.3	ppm
003A-GBF-07A Girls Bathroom Faucet Left	6/16/2016 15:01	6/23/2016 12:22	606171107	Lead	4	15	ppb
003A-GBF-08A Girls Bathroom Faucet Right	6/16/2016 15:06	6/23/2016 12:22	606171108	Copper	0.0	1.3	ppm
003A-GBF-08A Girls Bathroom Faucet Right	6/16/2016 15:06	6/23/2016 12:22	606171108	Lead	9	15	ppb
003A-JC-10A Janitor Closet Sink	6/16/2016 15:04	6/23/2016 12:22	606171110	Copper	0.0	1.3	ppm
<b>003A-JC-10A Janitor Closet Sink</b>	<b>6/16/2016 15:04</b>	<b>6/23/2016 12:22</b>	<b>606171110</b>	<b>Lead</b>	<b>20</b>	<b>15</b>	<b>ppb</b>
003A-055-21A Outside Spigot	6/16/2016 15:20	6/23/2016 12:24	606171121	Copper	0.0	1.3	ppm
003A-055-21A Outside Spigot	6/16/2016 15:20	6/23/2016 12:24	606171121	Lead	5	15	ppb
003A-CRA3-16A Classroom A3 Drinking Fountain	6/16/2016 15:15	6/23/2016 12:24	606171116	Copper	0.0	1.3	ppm
003A-CRA3-16A Classroom A3 Drinking Fountain	6/16/2016 15:15	6/23/2016 12:24	606171116	Lead	3	15	ppb
003A-CRA4-17A Classroom A4 Sink Faucet	6/16/2016 15:15	6/23/2016 12:24	606171117	Copper	0.0	1.3	ppm
003A-CRA4-17A Classroom A4 Sink Faucet	6/16/2016 15:15	6/23/2016 12:24	606171117	Lead	7	15	ppb
003A-CRA4-18A Classroom A4 Drinking Fountain	6/16/2016 15:15	6/23/2016 12:24	606171118	Copper	0.0	1.3	ppm
003A-CRA4-18A Classroom A4 Drinking Fountain	6/16/2016 15:15	6/23/2016 12:24	606171118	Lead	2	15	ppb
003A-CRA5-19A Classroom A5 Sink Faucet	6/16/2016 15:18	6/23/2016 12:24	606171119	Copper	0.0	1.3	ppm
<b>003A-CRA5-19A Classroom A5 Sink Faucet</b>	<b>6/16/2016 15:18</b>	<b>6/23/2016 12:24</b>	<b>606171119</b>	<b>Lead</b>	<b>31</b>	<b>15</b>	<b>ppb</b>

Portland Public Schools  
 Lead and Copper Water Sampling Results  
 A (First Draw) Sample Data  
 Ainsworth Elementary School Annex

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
003A-CRA5-20A Classroom A5 Drinking Fountain	6/16/2016 15:18	6/23/2016 12:24	606171120	Copper	0.0	1.3	ppm
003A-CRA5-20A Classroom A5 Drinking Fountain	6/16/2016 15:18	6/23/2016 12:24	606171120	Lead	3	15	ppb

EPA Action Level for Lead of 15 ppb  
 EPA Action Level for Copper of 1.3 ppm