

Portland Public Schools  
Lead and Copper Results  
A (First Draw) Sample Data (Revised)  
Chapman Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units
023-CRBIBR-01A Classroom B1 Bathroom Sink	6/16/2016 15:46	6/22/2016 16:48	606170601	Copper	0.1	1.3	ppm
023-CRBIBR-01A Classroom B1 Bathroom Sink	6/16/2016 15:46	6/22/2016 16:48	606170601	Lead	19	15	ppb
023-CRBI-02A Classroom B1 Sink	6/16/2016 15:49	6/22/2016 16:48	606170602	Copper	0.1	1.3	ppm
023-CRBI-02A Classroom B1 Sink	6/16/2016 15:49	6/22/2016 16:48	606170602	Lead	6	15	ppb
023-CRBI-03A Classroom B1 Drinking Fountain	6/16/2016 15:51	6/22/2016 16:48	606170603	Copper	0.0	1.3	ppm
023-CRBI-03A Classroom B1 Drinking Fountain	6/16/2016 15:51	6/22/2016 16:48	606170603	Lead	9	15	ppb
023-BBF-04A Boys Bathroom Faucet 1 Left	6/16/2016 15:54	6/22/2016 16:49	606170604	Copper	0.2	1.3	ppm
023-BBF-04A Boys Bathroom Faucet 1 Left	6/16/2016 15:54	6/22/2016 16:49	606170604	Lead	5	15	ppb
023-BBF-05A Boys Bathroom Faucet 2 Right	6/16/2016 15:56	6/22/2016 16:49	606170605	Copper	0.2	1.3	ppm
023-BBF-05A Boys Bathroom Faucet 2 Right	6/16/2016 15:56	6/22/2016 16:49	606170605	Lead	5	15	ppb
023-BBF-06A Boys Bathroom Faucet 3	6/16/2016 15:58	6/22/2016 16:49	606170606	Copper	0.2	1.3	ppm
023-BBF-06A Boys Bathroom Faucet 3	6/16/2016 15:58	6/22/2016 16:49	606170606	Lead	4	15	ppb
023-BBF-07A Boys Bathroom Faucet Spigot	6/16/2016 16:04	6/24/2016 8:23	606170607	Copper	2.1	1.3	ppm
023-BBF-07A Boys Bathroom Faucet Spigot	6/16/2016 16:04	6/24/2016 8:23	606170607	Lead	8010	15	ppb
023-GBF-08A Girls Bathroom Faucet 1 Left	6/16/2016 16:06	6/22/2016 16:52	606170608	Copper	0.3	1.3	ppm
023-GBF-08A Girls Bathroom Faucet 1 Left	6/16/2016 16:06	6/22/2016 16:52	606170608	Lead	23	15	ppb
023-GBF-09A Girls Bathroom Faucet 2 Left	6/16/2016 16:07	6/22/2016 16:52	606170609	Copper	0.4	1.3	ppm
023-GBF-09A Girls Bathroom Faucet 2 Left	6/16/2016 16:07	6/23/2016 10:14	606170609	Lead	70	15	ppb
023-GBF-10A Girls Bathroom Faucet 3 Right	6/16/2016 16:08	6/22/2016 17:19	606170610	Copper	0.3	1.3	ppm
023-GBF-10A Girls Bathroom Faucet 3 Right	6/16/2016 16:08	6/22/2016 17:19	606170610	Lead	8	15	ppb
023-GBF-11A Girls Bathroom Faucet 4	6/16/2016 16:10	6/22/2016 17:19	606170611	Copper	0.6	1.3	ppm
023-GBF-11A Girls Bathroom Faucet 4	6/16/2016 16:10	6/22/2016 17:19	606170611	Lead	23	15	ppb
023-PR1-12A Playroom 1 Sink	6/16/2016 16:11	6/22/2016 17:19	606170612	Copper	0.5	1.3	ppm
023-PR1-12A Playroom 1 Sink	6/16/2016 16:11	6/22/2016 17:19	606170612	Lead	9	15	ppb
023-PR2-13A Playroom 2 Sink N	6/16/2016 16:18	6/24/2016 10:04	606170613	Copper	0.9	1.3	ppm
023-PR2-13A Playroom 2 Sink N	6/16/2016 16:18	6/23/2016 10:54	606170613	Lead	45	15	ppb
023-PR2-14A Playroom 2 Sink S	6/16/2016 16:18	6/24/2016 8:24	606170614	Copper	0.8	1.3	ppm
023-PR2-14A Playroom 2 Sink S	6/16/2016 16:18	6/23/2016 10:55	606170614	Lead	26	15	ppb
023-PR2-15A Playroom 2 Drinking Fountain	6/16/2016 16:21	6/22/2016 17:19	606170615	Copper	0.5	1.3	ppm
023-PR2-15A Playroom 2 Drinking Fountain	6/16/2016 16:21	6/22/2016 17:19	606170615	Lead	14	15	ppb
023-BR-16A Boiler Room Sink Left	6/16/2016 16:27	6/22/2016 17:19	606170616	Copper	0.0	1.3	ppm
023-BR-16A Boiler Room Sink Left	6/16/2016 16:27	6/22/2016 17:19	606170616	Lead	3	15	ppb
023-BR-17A Boiler Room Sink Right	6/16/2016 16:27	6/23/2016 9:20	606170617	Copper	0.0	1.3	ppm
023-BR-17A Boiler Room Sink Right	6/16/2016 16:27	6/23/2016 9:20	606170617	Lead	3	15	ppb
023-DF-18A Drinking Fountain Hallway 1st Left	6/16/2016 16:34	6/23/2016 10:14	606170618	Copper	1.1	1.3	ppm
023-DF-18A Drinking Fountain Hallway 1st Left	6/16/2016 16:34	6/22/2016 17:19	606170618	Lead	10	15	ppb
023-DF-19A Drinking Fountain Hallway 1st Right	6/16/2016 16:34	6/22/2016 17:20	606170619	Copper	0.3	1.3	ppm
023-DF-19A Drinking Fountain Hallway 1st Right	6/16/2016 16:34	6/22/2016 17:20	606170619	Lead	5	15	ppb
023-CR2-20A Classroom 2 Sink	6/16/2016 16:36	6/22/2016 17:20	606170620	Copper	0.1	1.3	ppm
023-CR2-20A Classroom 2 Sink	6/16/2016 16:36	6/22/2016 17:20	606170620	Lead	5	15	ppb
023-CR2-21A Classroom 2 Fountain Drinking	6/16/2016 16:38	6/22/2016 17:20	606170621	Copper	0.1	1.3	ppm
023-CR2-21A Classroom 2 Fountain Drinking	6/16/2016 16:38	6/22/2016 17:20	606170621	Lead	1	15	ppb
023-K-22A Kitchen Sink	6/16/2016 16:45	6/22/2016 17:20	606170622	Copper	0.1	1.3	ppm
023-K-22A Kitchen Sink	6/16/2016 16:45	6/22/2016 17:20	606170622	Lead	5	15	ppb
023-K-23A Kitchen Small Sink	6/16/2016 16:47	6/22/2016 17:22	606170623	Copper	0.2	1.3	ppm
023-K-23A Kitchen Small Sink	6/16/2016 16:47	6/23/2016 10:14	606170623	Lead	75	15	ppb
023-K-24A Kitchen Dishwashing Sink	6/16/2016 16:43	6/22/2016 17:22	606170624	Copper	0.3	1.3	ppm
023-K-24A Kitchen Dishwashing Sink	6/16/2016 16:43	6/22/2016 17:22	606170624	Lead	16	15	ppb
023-K-25A Kitchen White Large Sink	6/16/2016 16:42	6/22/2016 17:22	606170625	Copper	0.1	1.3	ppm
023-K-25A Kitchen White Large Sink	6/16/2016 16:42	6/22/2016 17:22	606170625	Lead	26	15	ppb

Portland Public Schools  
Lead and Copper Results  
A (First Draw) Sample Data (Revised)  
Chapman Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units
023-K-26A Kitchen Bathroom Sink	6/16/2016 16:42	6/22/2016 17:22	606170626	Copper	0.1	1.3	ppm
023-K-26A Kitchen Bathroom Sink	6/16/2016 16:42	6/22/2016 17:22	606170626	Lead	12	15	ppb
023-CR3-27A Classroom 3 Sink	6/16/2016 16:48	6/22/2016 17:22	606170627	Copper	0.1	1.3	ppm
023-CR3-27A Classroom 3 Sink	6/16/2016 16:48	6/22/2016 17:22	606170627	Lead	5	15	ppb
023-CR3-28A Classroom 3 Drinking Fountain	6/16/2016 16:48	6/22/2016 17:22	606170628	Copper	0.2	1.3	ppm
023-CR3-28A Classroom 3 Drinking Fountain	6/16/2016 16:48	6/22/2016 17:22	606170628	Lead	3	15	ppb
023-CR5-29A Classroom 5 Sink	6/16/2016 16:50	6/22/2016 17:22	606170629	Copper	0.2	1.3	ppm
<b>023-CR5-29A Classroom 5 Sink</b>	<b>6/16/2016 16:50</b>	<b>6/22/2016 17:22</b>	<b>606170629</b>	<b>Lead</b>	<b>17</b>	<b>15</b>	<b>ppb</b>
023-CR5-30A Classroom 5 Drinking Fountain	6/16/2016 16:52	6/22/2016 17:54	606170630	Copper	0.0	1.3	ppm
023-CR5-30A Classroom 5 Drinking Fountain	6/16/2016 16:52	6/22/2016 17:54	606170630	Lead	2	15	ppb
023-CR6-31A Classroom 6 Sink	6/16/2016 16:52	6/22/2016 17:54	606170631	Copper	0.1	1.3	ppm
023-CR6-31A Classroom 6 Sink	6/16/2016 16:52	6/22/2016 17:54	606170631	Lead	4	15	ppb
023-CR6-32A Classroom 6 Drinking Fountain	6/16/2016 16:52	6/22/2016 17:54	606170632	Copper	0.0	1.3	ppm
023-CR6-32A Classroom 6 Drinking Fountain	6/16/2016 16:52	6/22/2016 17:54	606170632	Lead	2	15	ppb
023-FR5-33A Faculty Restroom Sink	6/16/2016 16:54	6/22/2016 17:54	606170633	Copper	0.1	1.3	ppm
023-FR5-33A Faculty Restroom Sink	6/16/2016 16:54	6/22/2016 17:54	606170633	Lead	12	15	ppb
023-A-34A Auditorium Sink	6/16/2016 17:03	6/22/2016 17:55	606170634	Copper	0.1	1.3	ppm
023-A-34A Auditorium Sink	6/16/2016 17:03	6/22/2016 17:55	606170634	Lead	11	15	ppb
023-FR-35A Faculty Room Sink	6/16/2016 16:57	6/22/2016 17:55	606170635	Copper	0.0	1.3	ppm
023-FR-35A Faculty Room Sink	6/16/2016 16:57	6/22/2016 17:55	606170635	Lead	6	15	ppb
023-JC-36A Janitors Closet Sink N Hallway	6/16/2016 17:05	6/22/2016 17:55	606170636	Copper	0.1	1.3	ppm
023-JC-36A Janitors Closet Sink N Hallway	6/16/2016 17:05	6/22/2016 17:55	606170636	Lead	3	15	ppb
023-DF-37A Drinking Fountain by Office	6/16/2016 17:07	6/22/2016 17:55	606170637	Copper	0.5	1.3	ppm
023-DF-37A Drinking Fountain by Office	6/16/2016 17:07	6/22/2016 17:55	606170637	Lead	ND	15	ppb
023-DF-38A Drinking Fountain Bottom	6/16/2016 17:08	6/22/2016 17:56	606170638	Copper	0.2	1.3	ppm
023-DF-38A Drinking Fountain Bottom	6/16/2016 17:08	6/22/2016 17:56	606170638	Lead	0	15	ppb
023-WRTB-39A Workroom 7B Sink	6/16/2016 17:12	6/22/2016 17:56	606170639	Copper	0.1	1.3	ppm
023-WRTB-39A Workroom 7B Sink	6/16/2016 17:12	6/22/2016 17:56	606170639	Lead	1	15	ppb
023-WRTB-40A Workroom 7B Drinking Fountain	6/16/2016 17:12	6/22/2016 18:00	606170640	Copper	0.0	1.3	ppm
023-WRTB-40A Workroom 7B Drinking Fountain	6/16/2016 17:12	6/22/2016 18:00	606170640	Lead	2	15	ppb
023-PD-41A Principles Office Sink	6/16/2016 17:14	6/22/2016 18:00	606170641	Copper	0.0	1.3	ppm
023-PD-41A Principles Office Sink	6/16/2016 17:14	6/22/2016 18:00	606170641	Lead	9	15	ppb
023-CR9-42A Classroom 9 Sink	6/16/2016 17:10	6/22/2016 18:00	606170642	Copper	0.3	1.3	ppm
<b>023-CR9-42A Classroom 9 Sink</b>	<b>6/16/2016 17:10</b>	<b>6/22/2016 18:00</b>	<b>606170642</b>	<b>Lead</b>	<b>16</b>	<b>15</b>	<b>ppb</b>
023-DF-43A Drinking Fountain Hallway South	6/16/2016 17:12	6/22/2016 18:01	606170643	Copper	0.0	1.3	ppm
023-DF-43A Drinking Fountain Hallway South	6/16/2016 17:12	6/22/2016 18:01	606170643	Lead	3	15	ppb
023-CR10-44A Classroom 10 Sink	6/16/2016 17:14	6/22/2016 18:01	606170644	Copper	0.3	1.3	ppm
023-CR10-44A Classroom 10 Sink	6/16/2016 17:14	6/22/2016 18:01	606170644	Lead	9	15	ppb
023-CR10-45A Classroom 10 Drinking Fountain	6/16/2016 17:14	6/22/2016 18:01	606170645	Copper	0.0	1.3	ppm
023-CR10-45A Classroom 10 Drinking Fountain	6/16/2016 17:14	6/22/2016 18:01	606170645	Lead	6	15	ppb
023-JC-46A Janitors Closet Sink South Hall	6/16/2016 17:17	6/22/2016 18:01	606170646	Copper	0.0	1.3	ppm
023-JC-46A Janitors Closet Sink South Hall	6/16/2016 17:17	6/22/2016 18:01	606170646	Lead	3	15	ppb
023-GBG-47A Girls Bathroom Gym Left	6/16/2016 17:19	6/22/2016 18:02	606170647	Copper	0.2	1.3	ppm
<b>023-GBG-47A Girls Bathroom Gym Left</b>	<b>6/16/2016 17:19</b>	<b>6/22/2016 18:02</b>	<b>606170647</b>	<b>Lead</b>	<b>49</b>	<b>15</b>	<b>ppb</b>
023-GBG-48A Girls Bathroom Gym	6/16/2016 17:19	6/22/2016 18:02	606170648	Copper	0.3	1.3	ppm
<b>023-GBG-48A Girls Bathroom Gym</b>	<b>6/16/2016 17:19</b>	<b>6/22/2016 18:02</b>	<b>606170648</b>	<b>Lead</b>	<b>17</b>	<b>15</b>	<b>ppb</b>
023-GBG-49A Girls Bathroom Gym Right	6/16/2016 17:22	6/22/2016 18:02	606170649	Copper	0.3	1.3	ppm
<b>023-GBG-49A Girls Bathroom Gym Right</b>	<b>6/16/2016 17:22</b>	<b>6/22/2016 18:02</b>	<b>606170649</b>	<b>Lead</b>	<b>35</b>	<b>15</b>	<b>ppb</b>
023-GBG-50A Girls Bathroom Gym	6/16/2016 17:22	6/22/2016 18:04	606170650	Copper	0.7	1.3	ppm
<b>023-GBG-50A Girls Bathroom Gym</b>	<b>6/16/2016 17:22</b>	<b>6/23/2016 10:15</b>	<b>606170650</b>	<b>Lead</b>	<b>61</b>	<b>15</b>	<b>ppb</b>

Portland Public Schools  
Lead and Copper Results  
A (First Draw) Sample Data (Revised)  
Chapman Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units
023-BBG-51A Boys Bathroom Gym 2	6/16/2016 17:22	6/22/2016 18:04	606170651	Copper	0.1	1.3	ppm
023-BBG-51A Boys Bathroom Gym 2	6/16/2016 17:22	6/22/2016 18:04	606170651	Lead	6	15	ppb
023-BBG-52A Boys Bathroom Left Most Gym 1	6/16/2016 17:20	6/22/2016 18:05	606170652	Copper	0.1	1.3	ppm
023-BBG-52A Boys Bathroom Left Most Gym 1	6/16/2016 17:20	6/22/2016 18:05	606170652	Lead	8	15	ppb
023-BBG-53A Boys Bathroom Gym 3	6/16/2016 17:23	6/23/2016 9:50	606170653	Copper	0.1	1.3	ppm
<b>023-BBG-53A Boys Bathroom Gym 3</b>	<b>6/16/2016 17:23</b>	<b>6/23/2016 10:15</b>	<b>606170653</b>	<b>Lead</b>	<b>62</b>	<b>15</b>	<b>ppb</b>
023-BBG-54A Boys Bathroom Gym 4	6/16/2016 17:25	6/22/2016 18:05	606170654	Copper	0.2	1.3	ppm
<b>023-BBG-54A Boys Bathroom Gym 4</b>	<b>6/16/2016 17:25</b>	<b>6/22/2016 18:05</b>	<b>606170654</b>	<b>Lead</b>	<b>23</b>	<b>15</b>	<b>ppb</b>
023-BBG-55A Boys Bathroom Gym 5	6/16/2016 17:27	6/22/2016 18:05	606170655	Copper	0.3	1.3	ppm
<b>023-BBG-55A Boys Bathroom Gym 5</b>	<b>6/16/2016 17:27</b>	<b>6/22/2016 18:05</b>	<b>606170655</b>	<b>Lead</b>	<b>15</b>	<b>15</b>	<b>ppb</b>
023-BBG-56A Boys Bathroom Gym Spigot	6/16/2016 17:28	6/24/2016 8:25	606170656	Copper	1.6	1.3	ppm
<b>023-BBG-56A Boys Bathroom Gym Spigot</b>	<b>6/16/2016 17:28</b>	<b>6/23/2016 10:55</b>	<b>606170656</b>	<b>Lead</b>	<b>149</b>	<b>15</b>	<b>ppb</b>
023-CR12-57A Classroom 12 Sink	6/16/2016 17:30	6/22/2016 18:05	606170657	Copper	0.2	1.3	ppm
023-CR12-57A Classroom 12 Sink	6/16/2016 17:30	6/22/2016 18:05	606170657	Lead	10	15	ppb
023-JC-58A Janitors Closet Sink 2nd F	6/16/2016 17:33	6/23/2016 10:55	606170658	Copper	0.1	1.3	ppm
023-JC-58A Janitors Closet Sink 2nd F	6/16/2016 17:33	6/23/2016 10:55	606170658	Lead	10	15	ppb
023-CR15-59A Classroom 15 Sink	6/16/2016 17:34	6/22/2016 18:06	606170659	Copper	0.1	1.3	ppm
023-CR15-59A Classroom 15 Sink	6/16/2016 17:34	6/22/2016 18:06	606170659	Lead	5	15	ppb
023-CR15-60A Classroom 15 Drinking Fountain	6/16/2016 17:34	6/22/2016 18:06	606170660	Copper	0.1	1.3	ppm
023-CR15-60A Classroom 15 Drinking Fountain	6/16/2016 17:34	6/22/2016 18:06	606170660	Lead	3	15	ppb
023-CR15B-61A Classroom 15B Sink	6/16/2016 17:39	6/22/2016 18:06	606170661	Copper	0.0	1.3	ppm
<b>023-CR15B-61A Classroom 15B Sink</b>	<b>6/16/2016 17:39</b>	<b>6/22/2016 18:06</b>	<b>606170661</b>	<b>Lead</b>	<b>19</b>	<b>15</b>	<b>ppb</b>
023-DF-62A Drinking Fountain 2nd Floor South	6/16/2016 17:38	6/22/2016 18:41	606170662	Copper	0.0	1.3	ppm
023-DF-62A Drinking Fountain 2nd Floor South	6/16/2016 17:38	6/22/2016 18:41	606170662	Lead	10	15	ppb
023-CR16-63A Classroom 16 Sink	6/16/2016 17:43	6/22/2016 18:41	606170663	Copper	0.1	1.3	ppm
023-CR16-63A Classroom 16 Sink	6/16/2016 17:43	6/22/2016 18:41	606170663	Lead	4	15	ppb
023-DF-64A Drinking Fountain NE Hallway	6/16/2016 17:52	6/22/2016 18:41	606170664	Copper	0.0	1.3	ppm
023-DF-64A Drinking Fountain NE Hallway	6/16/2016 17:52	6/22/2016 18:41	606170664	Lead	13	15	ppb
023-CR18-65A Classroom 18 West Sink	6/16/2016 17:43	6/22/2016 18:42	606170665	Copper	0.1	1.3	ppm
<b>023-CR18-65A Classroom 18 West Sink</b>	<b>6/16/2016 17:43</b>	<b>6/22/2016 18:42</b>	<b>606170665</b>	<b>Lead</b>	<b>16</b>	<b>15</b>	<b>ppb</b>
023-CR18-66A Classroom 18 North Sink	6/16/2016 17:43	6/22/2016 18:42	606170666	Copper	0.1	1.3	ppm
023-CR18-66A Classroom 18 North Sink	6/16/2016 17:43	6/22/2016 18:42	606170666	Lead	3	15	ppb
023-CR22-67A Classroom 22 Sink	6/16/2016 17:51	6/22/2016 18:42	606170667	Copper	0.2	1.3	ppm
023-CR22-67A Classroom 22 Sink	6/16/2016 17:51	6/22/2016 18:42	606170667	Lead	2	15	ppb
023-CR22-68A Classroom Drinking Fountain	6/16/2016 17:51	6/22/2016 18:42	606170668	Copper	0.5	1.3	ppm
023-CR22-68A Classroom Drinking Fountain	6/16/2016 17:51	6/22/2016 18:42	606170668	Lead	1	15	ppb
023-DF-69A Drinking Fountain North 3rd	6/16/2016 17:57	6/22/2016 18:42	606170669	Copper	0.1	1.3	ppm
023-DF-69A Drinking Fountain North 3rd	6/16/2016 17:57	6/22/2016 18:42	606170669	Lead	10	15	ppb
023-FMB-70A Faculty Mens Restroom	6/16/2016 17:57	6/22/2016 18:43	606170670	Copper	0.2	1.3	ppm
<b>023-FMB-70A Faculty Mens Restroom</b>	<b>6/16/2016 17:57</b>	<b>6/22/2016 18:43</b>	<b>606170670</b>	<b>Lead</b>	<b>15</b>	<b>15</b>	<b>ppb</b>
023-R23A-71A Restroom 23A Sink	6/16/2016 17:49	6/22/2016 18:43	606170671	Copper	0.0	1.3	ppm
023-R23A-71A Restroom 23A Sink	6/16/2016 17:49	6/22/2016 18:43	606170671	Lead	13	15	ppb
023-CR23-72A Classroom 23 Sink	6/16/2016 18:00	6/22/2016 18:44	606170672	Copper	0.2	1.3	ppm
023-CR23-72A Classroom 23 Sink	6/16/2016 18:00	6/22/2016 18:44	606170672	Lead	3	15	ppb
023-CR23-73A Classroom 23 Drinking Fountain	6/16/2016 18:00	6/22/2016 18:45	606170673	Copper	0.4	1.3	ppm
023-CR23-73A Classroom 23 Drinking Fountain	6/16/2016 18:00	6/22/2016 18:45	606170673	Lead	3	15	ppb
023-JC-74A Janitors Closet Sink	6/16/2016 18:02	6/23/2016 10:56	606170674	Copper	0.3	1.3	ppm
<b>023-JC-74A Janitors Closet Sink</b>	<b>6/16/2016 18:02</b>	<b>6/23/2016 10:56</b>	<b>606170674</b>	<b>Lead</b>	<b>17</b>	<b>15</b>	<b>ppb</b>
023-CR14-75A Classroom 14 Sink	6/16/2016 17:57	6/22/2016 18:45	606170675	Copper	0.0	1.3	ppm
023-CR14-75A Classroom 14 Sink	6/16/2016 17:57	6/22/2016 18:45	606170675	Lead	3	15	ppb

Portland Public Schools  
Lead and Copper Results  
A (First Draw) Sample Data (Revised)  
Chapman Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units
023-CR14-76A Classroom 14 Drinking Fountain	6/16/2016 17:56	6/22/2016 18:46	606170676	Copper	0.0	1.3	ppm
023-CR14-76A Classroom 14 Drinking Fountain	6/16/2016 17:56	6/22/2016 18:46	606170676	Lead	3	15	ppb
023-CR27-77A Classroom 27 Sink	6/16/2016 18:10	6/22/2016 18:46	606170677	Copper	0.1	1.3	ppm
<b>023-CR27-77A Classroom 27 Sink</b>	<b>6/16/2016 18:10</b>	<b>6/22/2016 18:46</b>	<b>606170677</b>	<b>Lead</b>	<b>18</b>	<b>15</b>	<b>ppb</b>
023-CR27-78A Classroom 27 Drinking Fountain	6/16/2016 18:11	6/22/2016 18:47	606170678	Copper	0.0	1.3	ppm
023-CR27-78A Classroom 27 Drinking Fountain	6/16/2016 18:11	6/22/2016 18:47	606170678	Lead	10	15	ppb
023-CR26-79A Classroom 26 Sink	6/16/2016 18:11	6/22/2016 18:47	606170679	Copper	0.1	1.3	ppm
023-CR26-79A Classroom 26 Sink	6/16/2016 18:11	6/22/2016 18:47	606170679	Lead	6	15	ppb
023-CR26-80A Classroom 26 Drinking Fountain	6/16/2016 18:11	6/22/2016 18:47	606170680	Copper	0.0	1.3	ppm
023-CR26-80A Classroom 26 Drinking Fountain	6/16/2016 18:11	6/22/2016 18:47	606170680	Lead	3	15	ppb
023-CR25-81A Classroom 25 Sink	6/16/2016 18:14	6/22/2016 18:47	606170681	Copper	0.0	1.3	ppm
023-CR25-81A Classroom 25 Sink	6/16/2016 18:14	6/22/2016 18:47	606170681	Lead	5	15	ppb
023-CR25-82A Classroom 25 Drinking Fountain	6/16/2016 18:17	6/22/2016 18:48	606170682	Copper	0.0	1.3	ppm
023-CR25-82A Classroom 25 Drinking Fountain	6/16/2016 18:17	6/22/2016 18:48	606170682	Lead	1	15	ppb
023-055-83A Outside Spigot SE	6/16/2016 18:32	6/24/2016 9:50	606170683	Copper	0.0	1.3	ppm
<b>023-055-83A Outside Spigot SE</b>	<b>6/16/2016 18:32</b>	<b>6/24/2016 9:50</b>	<b>606170683</b>	<b>Lead</b>	<b>31</b>	<b>15</b>	<b>ppb</b>
023-DF-84A Drinking Fountain Back of School	6/16/2016 18:23	6/23/2016 12:17	606170684	Copper	0.2	1.3	ppm
023-DF-84A Drinking Fountain Back of School	6/16/2016 18:23	6/23/2016 12:17	606170684	Lead	7	15	ppb
023-DF-85A Drinking Fountain Back of School	6/16/2016 18:23	6/23/2016 12:17	606170685	Copper	0.1	1.3	ppm
023-DF-85A Drinking Fountain Back of School	6/16/2016 18:23	6/23/2016 12:17	606170685	Lead	5	15	ppb
023-055-86A Outside Spigot Back	6/16/2016 18:30	6/23/2016 12:17	606170686	Copper	0.0	1.3	ppm
<b>023-055-86A Outside Spigot Back</b>	<b>6/16/2016 18:30</b>	<b>6/23/2016 12:17</b>	<b>606170686</b>	<b>Lead</b>	<b>87</b>	<b>15</b>	<b>ppb</b>
023-055-87A Outside Spigot Northeast	6/16/2016 18:26	6/23/2016 12:17	606170687	Copper	0.0	1.3	ppm
<b>023-055-87A Outside Spigot Northeast</b>	<b>6/16/2016 18:26</b>	<b>6/23/2016 12:17</b>	<b>606170687</b>	<b>Lead</b>	<b>19</b>	<b>15</b>	<b>ppb</b>

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance action levels.