

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
East Sylvan Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	ContainerID	Analyte	Results	EPA Action Level	Units
033-01A	Basement Kitchen SF 1	6/20/16 19:16	6/28/2016	1606C16-01A	Copper	0.3	1.3	ppm
033-01A	Basement Kitchen SF 1	6/20/16 19:16	6/28/2016	1606C16-01A	Lead	15	15	ppb
033-02A	Basement Kitchen SF 2	6/20/16 19:16	6/28/2016	1606C16-02A	Copper	0.1	1.3	ppm
033-02A	Basement Kitchen SF 2	6/20/16 19:16	6/28/2016	1606C16-02A	Lead	13	15	ppb
033-03A	Basement Bath JC	6/20/16 19:20	6/28/2016	1606C16-03A	Copper	0.0	1.3	ppm
033-03A	Basement Bath JC	6/20/16 19:20	6/28/2016	1606C16-03A	Lead	2	15	ppb
033-04A	Basement Bath SF	6/20/16 19:22	6/28/2016	1606C16-04A	Copper	0.2	1.3	ppm
033-04A	Basement Bath SF	6/20/16 19:22	6/28/2016	1606C16-04A	Lead	17	15	ppb
033-05A	Basement Kitchen Dish SF	6/20/16 19:20	6/28/2016	1606C16-05A	Copper	0.0	1.3	ppm
033-05A	Basement Kitchen Dish SF	6/20/16 19:20	6/28/2016	1606C16-05A	Lead	10	15	ppb
033-06A	Basement Gym WS	6/20/16 19:26	6/29/2016	1606C16-06A	Copper	0.4	1.3	ppm
033-06A	Basement Gym WS	6/20/16 19:26	6/29/2016	1606C16-06A	Lead	76	15	ppb
033-07A	Room 23 SF	6/20/16 19:31	6/29/2016	1606C16-07A	Copper	0.4	1.3	ppm
033-07A	Room 23 SF	6/20/16 19:31	6/29/2016	1606C16-07A	Lead	120	15	ppb
033-08A	Compressor Room WS	6/20/16 19:35	6/28/2016	1606C16-08A	Copper	0.0	1.3	ppm
033-08A	Compressor Room WS	6/20/16 19:35	6/28/2016	1606C16-08A	Lead	12	15	ppb
033-09A	17 Boys SF	6/20/16 19:45	6/28/2016	1606C16-09A	Copper	0.0	1.3	ppm
033-09A	17 Boys SF	6/20/16 19:45	6/28/2016	1606C16-09A	Lead	9	15	ppb
033-10A	34 Staff Bathroom	6/20/16 19:49	6/28/2016	1606C16-10A	Copper	0.1	1.3	ppm
033-10A	34 Staff Bathroom	6/20/16 19:49	6/28/2016	1606C16-10A	Lead	10	15	ppb
033-11A	Hall DF	6/20/16 19:53	6/28/2016	1606C16-11A	Copper	0.3	1.3	ppm
033-11A	Hall DF	6/20/16 19:53	6/28/2016	1606C16-11A	Lead	15	15	ppb
033-12A	Room 4 SF	6/20/16 19:58	6/28/2016	1606C16-12A	Copper	0.0	1.3	ppm
033-12A	Room 4 SF	6/20/16 19:58	6/28/2016	1606C16-12A	Lead	24	15	ppb
033-13A	Room 3 SF	6/20/16 20:01	6/28/2016	1606C16-13A	Copper	0.0	1.3	ppm
033-13A	Room 3 SF	6/20/16 20:01	6/28/2016	1606C16-13A	Lead	6	15	ppb
033-14A	Women's Bath SF 1	6/20/16 20:06	6/28/2016	1606C16-14A	Copper	0.1	1.3	ppm
033-14A	Women's Bath SF 1	6/20/16 20:06	6/28/2016	1606C16-14A	Lead	15	15	ppb
033-15A	Women's Bath SF 2	6/20/16 20:08	6/28/2016	1606C16-15A	Copper	0.1	1.3	ppm
033-15A	Women's Bath SF 2	6/20/16 20:08	6/28/2016	1606C16-15A	Lead	6	15	ppb
033-16A	Women's Bath SF 3	6/20/16 20:10	6/28/2016	1606C16-16A	Copper	0.5	1.3	ppm
033-16A	Women's Bath SF 3	6/20/16 20:10	6/28/2016	1606C16-16A	Lead	35	15	ppb
033-17A	Nurse Office 15	6/20/16 20:14	6/28/2016	1606C16-17A	Copper	0.1	1.3	ppm
033-17A	Nurse Office 15	6/20/16 20:14	6/28/2016	1606C16-17A	Lead	9	15	ppb
033-18A	Room 2 SF	6/20/16 20:19	6/28/2016	1606C16-18A	Copper	0.1	1.3	ppm
033-18A	Room 2 SF	6/20/16 20:19	6/28/2016	1606C16-18A	Lead	12	15	ppb
033-19A	Boys SF 1	6/20/16 20:28	6/28/2016	1606C16-19A	Copper	0.1	1.3	ppm
033-19A	Boys SF 1	6/20/16 20:28	6/28/2016	1606C16-19A	Lead	6	15	ppb
033-20A	Boys SF 2	6/20/16 20:31	6/28/2016	1606C16-20A	Copper	0.1	1.3	ppm
033-20A	Boys SF 2	6/20/16 20:31	6/28/2016	1606C16-20A	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
East Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	ContainerID	Analyte	Results	EPA Action Level	Units
033-21A Room 1 SF	6/20/16 20:35	6/28/2016	1606C16-21A	Copper	0.0	1.3	ppm
033-21A Room 1 SF	6/20/16 20:35	6/28/2016	1606C16-21A	Lead	6	15	ppb
033-22A 8 Bath SF	6/20/16 20:50	6/29/2016	1606C16-22A	Copper	1.31	1.3	ppm
033-22A 8 Bath SF	6/20/16 20:50	6/28/2016	1606C16-22A	Lead	37	15	ppb
033-23A Room 12 Jan. SF	6/20/16 20:54	6/28/2016	1606C16-23A	Copper	0.3	1.3	ppm
033-23A Room 12 Jan. SF	6/20/16 20:54	6/28/2016	1606C16-23A	Lead	21	15	ppb
033-24A Room 7 Office SF	6/20/16 20:58	6/29/2016	1606C16-24A	Copper	4.2	1.3	ppm
033-24A Room 7 Office SF	6/20/16 20:58	6/29/2016	1606C16-24A	Lead	66	15	ppb
033-25A Hall DF	6/20/16 21:02	6/28/2016	1606C16-25A	Copper	0.7	1.3	ppm
033-25A Hall DF	6/20/16 21:02	6/28/2016	1606C16-25A	Lead	5	15	ppb
033-26A Outside WS 1	6/20/16 21:08	6/29/2016	1606C16-26A	Copper	0.9	1.3	ppm
033-26A Outside WS 1	6/20/16 21:08	6/29/2016	1606C16-26A	Lead	72	15	ppb
033-27A Outside WS 2	6/20/16 21:15	6/28/2016	1606C16-27A	Copper	0.0	1.3	ppm
033-27A Outside WS 2	6/20/16 21:15	6/28/2016	1606C16-27A	Lead	3	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.