

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Level	Units
046-01A	Library SF (Purge)	6/21/16 13:12	6/29/2016	1606C21-01A	Copper	0.9	1.3	ppm
046-01A	Library SF (Purge)	6/21/16 13:12	6/29/2016	1606C21-01A	Lead	13	15	ppb
046-02A	Boiler Rm SF Closest-Main	6/21/16 13:05	6/29/2016	1606C21-02A	Copper	ND	1.3	ppm
046-02A	Boiler Rm SF Closest-Main	6/21/16 13:05	6/29/2016	1606C21-02A	Lead	11	15	ppb
046-03A	Rm 207-SF	6/21/16 12:51	6/29/2016	1606C21-03A	Copper	0.9	1.3	ppm
046-03A	Rm 207-SF	6/21/16 12:51	6/29/2016	1606C21-03A	Lead	31	15	ppb
046-04A	Rm 208 Boys Bath L. Faucet	6/21/16 12:57	6/29/2016	1606C21-04A	Copper	ND	1.3	ppm
046-04A	Rm 208 Boys Bath L. Faucet	6/21/16 12:57	6/29/2016	1606C21-04A	Lead	4	15	ppb
046-05A	Rm 208 Boys Bath R. Faucet	6/21/16 12:57	6/29/2016	1606C21-05A	Copper	0.1	1.3	ppm
046-05A	Rm 208 Boys Bath R. Faucet	6/21/16 12:57	6/29/2016	1606C21-05A	Lead	6	15	ppb
046-06A	N. Corridor DF Right Side	6/21/16 12:51	6/29/2016	1606C21-06A	Copper	0.6	1.3	ppm
046-06A	N. Corridor DF Right Side	6/21/16 12:51	6/29/2016	1606C21-06A	Lead	11	15	ppb
046-07A	Rm 209 Girls Bath Faucet	6/21/16 13:01	6/29/2016	1606C21-07A	Copper	ND	1.3	ppm
046-07A	Rm 209 Girls Bath Faucet	6/21/16 13:01	6/29/2016	1606C21-07A	Lead	16	15	ppb
046-08A	Rm 209 Girls Bath R. Faucet	6/21/16 13:01	6/29/2016	1606C21-08A	Copper	0.1	1.3	ppm
046-08A	Rm 209 Girls Bath R. Faucet	6/21/16 13:01	6/29/2016	1606C21-08A	Lead	4	15	ppb
046-09A	Custodial Slop Sink	6/21/16 13:05	6/29/2016	1606C21-09A	Copper	0.2	1.3	ppm
046-09A	Custodial Slop Sink	6/21/16 13:05	6/29/2016	1606C21-09A	Lead	22	15	ppb
046-10A	DF Metallic Left	6/21/16 13:09	6/29/2016	1606C21-10A	Copper	0.3	1.3	ppm
046-10A	DF Metallic Left	6/21/16 13:09	6/29/2016	1606C21-10A	Lead	2	15	ppb
046-11A	DF Metallic Right	6/21/16 13:09	6/29/2016	1606C21-11A	Copper	0.5	1.3	ppm
046-11A	DF Metallic Right	6/21/16 13:09	6/29/2016	1606C21-11A	Lead	1	15	ppb
046-12A	Custodial Slop Sink-224	6/21/16 13:24	6/29/2016	1606C21-12A	Copper	0.2	1.3	ppm
046-12A	Custodial Slop Sink-224	6/21/16 13:24	6/29/2016	1606C21-12A	Lead	27	15	ppb
046-13A	223 Girls Bath Sink Left	6/21/16 13:27	6/29/2016	1606C21-13A	Copper	0.3	1.3	ppm
046-13A	223 Girls Bath Sink Left	6/21/16 13:27	6/29/2016	1606C21-13A	Lead	5	15	ppb
046-14A	223 Girls Bath Sink Right	6/21/16 13:27	6/29/2016	1606C21-14A	Copper	0.2	1.3	ppm
046-14A	223 Girls Bath Sink Right	6/21/16 13:27	6/29/2016	1606C21-14A	Lead	10	15	ppb
046-15A	223 Girls Bath Sink Spigot	6/21/16 13:31	6/29/2016	1606C21-15A	Copper	9.6	1.3	ppm
046-15A	223 Girls Bath Sink Spigot	6/21/16 13:31	6/29/2016	1606C21-15A	Lead	600	15	ppb
046-16A	Boys Bath Sink Left	6/21/16 13:25	6/29/2016	1606C21-16A	Copper	0.3	1.3	ppm
046-16A	Boys Bath Sink Left	6/21/16 13:25	6/29/2016	1606C21-16A	Lead	29	15	ppb
046-18A	Boys Bath Sink Spigot	6/21/16 13:28	6/29/2016	1606C21-17A	Copper	3.1	1.3	ppm
046-18A	Boys Bath Sink Spigot	6/21/16 13:28	6/29/2016	1606C21-17A	Lead	160	15	ppb
046-19A	Rm 222 SF	6/21/16 13:32	6/29/2016	1606C21-18A	Copper	0.3	1.3	ppm
046-19A	Rm 222 SF	6/21/16 13:32	6/29/2016	1606C21-18A	Lead	16	15	ppb
046-20A	Girls Bath Spigot 209	6/21/16 13:17	6/29/2016	1606C21-19A	Copper	1.5	1.3	ppm
046-20A	Girls Bath Spigot 209	6/21/16 13:17	6/29/2016	1606C21-19A	Lead	530	15	ppb
046-21A	Boys Bath Spigot 208	6/21/16 13:15	6/29/2016	1606C21-20A	Copper	12.3	1.3	ppm
046-21A	Boys Bath Spigot 208	6/21/16 13:15	6/29/2016	1606C21-20A	Lead	490	15	ppb
046-22A	SF Class 100	6/21/16 13:41	6/29/2016	1606C21-21A	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Level	Units
046-22A	SF Class 100	6/21/16 13:41	6/29/2016	1606C21-21A	Lead	5	15	ppb
046-23A	DF Rm 100	6/21/16 13:41	6/29/2016	1606C21-22A	Copper	0.6	1.3	ppm
046-23A	DF Rm 100	6/21/16 13:41	6/29/2016	1606C21-22A	Lead	1	15	ppb
046-24A	SF in Rm 106A	6/21/16 13:40	6/29/2016	1606C21-23A	Copper	0.4	1.3	ppm
046-24A	SF in Rm 106A	6/21/16 13:40	6/29/2016	1606C21-23A	Lead	17	15	ppb
046-25A	DF by Rm 106	6/21/16 13:40	6/29/2016	1606C21-24A	Copper	0.5	1.3	ppm
046-25A	DF by Rm 106	6/21/16 13:40	6/29/2016	1606C21-24A	Lead	4	15	ppb
046-26A	DF by Rm 106 Right	6/21/16 13:45	6/29/2016	1606C21-25A	Copper	0.2	1.3	ppm
046-26A	DF by Rm 106 Right	6/21/16 13:45	6/29/2016	1606C21-25A	Lead	3	15	ppb
046-27A	SF in Rm 103	6/21/16 13:46	6/29/2016	1606C21-26A	Copper	0.4	1.3	ppm
046-27A	SF in Rm 103	6/21/16 13:46	6/29/2016	1606C21-26A	Lead	ND	15	ppb
046-28A	Mens Bath Faucet	6/21/16 13:48	6/29/2016	1606C21-27A	Copper	0.2	1.3	ppm
046-28A	Mens Bath Faucet	6/21/16 13:48	6/29/2016	1606C21-27A	Lead	3	15	ppb
046-29A	Womens Bath Faucet 108	6/21/16 13:50	6/29/2016	1606C21-28A	Copper	ND	1.3	ppm
046-29A	Womens Bath Faucet 108	6/21/16 13:50	6/29/2016	1606C21-28A	Lead	9	15	ppb
046-30A	Boys Bath Faucet 1	6/21/16 13:53	6/29/2016	1606C21-29A	Copper	0.3	1.3	ppm
046-30A	Boys Bath Faucet 1	6/21/16 13:53	6/29/2016	1606C21-29A	Lead	5	15	ppb
046-31A	Boys Bath Faucet 2	6/21/16 13:53	6/29/2016	1606C21-30A	Copper	0.3	1.3	ppm
046-31A	Boys Bath Faucet 2	6/21/16 13:53	6/29/2016	1606C21-30A	Lead	3	15	ppb
046-32A	Boys Bath Faucet 3	6/21/16 13:55	6/29/2016	1606C21-31A	Copper	0.3	1.3	ppm
046-32A	Boys Bath Faucet 3	6/21/16 13:55	6/29/2016	1606C21-31A	Lead	4	15	ppb
046-33A	Boys Bath Faucet 4	6/21/16 13:55	6/29/2016	1606C21-32A	Copper	0.3	1.3	ppm
046-33A	Boys Bath Faucet 4	6/21/16 13:55	6/29/2016	1606C21-32A	Lead	8	15	ppb
046-34A	Boys Bath Spigot	6/21/16 13:58	6/29/2016	1606C21-33A	Copper	27.7	1.3	ppm
046-34A	Boys Bath Spigot	6/21/16 13:58	6/29/2016	1606C21-33A	Lead	580	15	ppb
046-35A	Custodial Office Slop Sink	6/21/16 14:03	6/29/2016	1606C21-34A	Copper	0.3	1.3	ppm
046-35A	Custodial Office Slop Sink	6/21/16 14:03	6/29/2016	1606C21-34A	Lead	13	15	ppb
046-36A	Library SF	6/21/16 14:04	6/29/2016	1606C21-35A	Copper	0.5	1.3	ppm
046-36A	Library SF	6/21/16 14:04	6/29/2016	1606C21-35A	Lead	8	15	ppb
046-37A	Library DF	6/21/16 14:04	6/30/2016	1606C21-36A	Copper	2.7	1.3	ppm
046-37A	Library DF	6/21/16 14:04	6/30/2016	1606C21-36A	Lead	580	15	ppb
046-38A	DF Left	6/21/16 14:08	6/29/2016	1606C21-37A	Copper	0.7	1.3	ppm
046-38A	DF Left	6/21/16 14:08	6/29/2016	1606C21-37A	Lead	8	15	ppb
046-39A	DF Right	6/21/16 14:08	6/29/2016	1606C21-38A	Copper	0.7	1.3	ppm
046-39A	DF Right	6/21/16 14:08	6/29/2016	1606C21-38A	Lead	3	15	ppb
046-40A	Bath Sink in Office Rm 125A	6/21/16 14:13	6/29/2016	1606C21-39A	Copper	0.3	1.3	ppm
046-40A	Bath Sink in Office Rm 125A	6/21/16 14:13	6/29/2016	1606C21-39A	Lead	1	15	ppb
046-41A	FS in Office 125	6/21/16 14:15	6/29/2016	1606C21-40A	Copper	0.3	1.3	ppm
046-41A	FS in Office 125	6/21/16 14:15	6/29/2016	1606C21-40A	Lead	9	15	ppb
046-42A	119 Mens Bath Sink	6/21/16 14:11	6/30/2016	1606C21-41A	Copper	0.2	1.3	ppm
046-42A	119 Mens Bath Sink	6/21/16 14:11	6/30/2016	1606C21-41A	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Level	Units
046-43A	Mixed Bath Handicap B. Fauc.	6/21/16 14:09	6/30/2016	1606C21-42A	Copper	0.2	1.3	ppm
046-43A	Mixed Bath Handicap B. Fauc.	6/21/16 14:09	6/30/2016	1606C21-42A	Lead	5	15	ppb
046-44A	SF 118 Health Rm	6/21/16 14:14	6/30/2016	1606C21-43A	Copper	0.2	1.3	ppm
046-44A	SF 118 Health Rm	6/21/16 14:14	6/30/2016	1606C21-43A	Lead	4	15	ppb
046-45A	Girls Bath Faucet 1	6/21/16 14:24	6/30/2016	1606C21-44A	Copper	0.3	1.3	ppm
046-45A	Girls Bath Faucet 1	6/21/16 14:24	6/30/2016	1606C21-44A	Lead	4	15	ppb
046-46A	Girls Bath Faucet 2	6/21/16 14:24	6/30/2016	1606C21-45A	Copper	0.3	1.3	ppm
046-46A	Girls Bath Faucet 2	6/21/16 14:24	6/30/2016	1606C21-45A	Lead	3	15	ppb
046-47A	Girls Bath Faucet 3	6/21/16 14:28	6/30/2016	1606C21-46A	Copper	0.2	1.3	ppm
046-47A	Girls Bath Faucet 3	6/21/16 14:28	6/30/2016	1606C21-46A	Lead	3	15	ppb
046-48A	Girls Bath Faucet 4	6/21/16 14:28	6/30/2016	1606C21-47A	Copper	0.2	1.3	ppm
046-48A	Girls Bath Faucet 4	6/21/16 14:28	6/30/2016	1606C21-47A	Lead	3	15	ppb
046-49A	Girls Bath Spigot	6/21/16 14:31	6/30/2016	1606C21-48A	Copper	11.5	1.3	ppm
046-49A	Girls Bath Spigot	6/21/16 14:31	6/30/2016	1606C21-48A	Lead	200	15	ppb
046-50A	Gym DF	6/21/16 14:26	6/30/2016	1606C21-49A	Copper	0.6	1.3	ppm
046-50A	Gym DF	6/21/16 14:26	6/30/2016	1606C21-49A	Lead	2	15	ppb
046-51A	DF in Multi-Purpose	6/21/16 14:43	6/30/2016	1606C21-50A	Copper	0.5	1.3	ppm
046-51A	DF in Multi-Purpose	6/21/16 14:43	6/30/2016	1606C21-50A	Lead	6	15	ppb
046-52A	Boys Locker Rm SF 1	6/21/16 14:35	6/30/2016	1606C21-51A	Copper	0.6	1.3	ppm
046-52A	Boys Locker Rm SF 1	6/21/16 14:35	6/30/2016	1606C21-51A	Lead	1	15	ppb
046-53A	Boys Locker Rm Right SF 2	6/21/16 14:35	6/30/2016	1606C21-52A	Copper	1.5	1.3	ppm
046-53A	Boys Locker Rm Right SF 2	6/21/16 14:35	6/30/2016	1606C21-52A	Lead	25	15	ppb
046-54A	Boys Locker Rm Spigot	6/21/16 14:37	6/30/2016	1606C21-53A	Copper	1.4	1.3	ppm
046-54A	Boys Locker Rm Spigot	6/21/16 14:37	6/30/2016	1606C21-53A	Lead	51	15	ppb
046-55A	Boys Locker Rm Shower 1	6/21/16 14:40	6/30/2016	1606C21-54A	Copper	0.7	1.3	ppm
046-55A	Boys Locker Rm Shower 1	6/21/16 14:40	6/30/2016	1606C21-54A	Lead	49	15	ppb
046-56A	Boys Locker Rm Shower 2	6/21/16 14:40	6/30/2016	1606C21-55A	Copper	0.7	1.3	ppm
046-56A	Boys Locker Rm Shower 2	6/21/16 14:40	6/30/2016	1606C21-55A	Lead	270	15	ppb
046-57A	Boys Locker Rm Shower 3	6/21/16 14:42	6/30/2016	1606C21-56A	Copper	0.5	1.3	ppm
046-57A	Boys Locker Rm Shower 3	6/21/16 14:42	6/30/2016	1606C21-56A	Lead	170	15	ppb
046-58A	Boys Locker Rm Shower 4	6/21/16 14:42	6/30/2016	1606C21-57A	Copper	0.6	1.3	ppm
046-58A	Boys Locker Rm Shower 4	6/21/16 14:42	6/30/2016	1606C21-57A	Lead	53	15	ppb
046-59A	Boys Locker Rm Shower 5	6/21/16 14:48	6/30/2016	1606C21-58A	Copper	0.6	1.3	ppm
046-59A	Boys Locker Rm Shower 5	6/21/16 14:48	6/30/2016	1606C21-58A	Lead	72	15	ppb
046-60A	Boys Locker Rm Shower 6	6/21/16 14:49	6/30/2016	1606C21-59A	Copper	0.5	1.3	ppm
046-60A	Boys Locker Rm Shower 6	6/21/16 14:49	6/30/2016	1606C21-59A	Lead	20	15	ppb
046-61A	Girls Locker Rm SF 1 Left	6/21/16 14:46	6/30/2016	1606C21-60A	Copper	0.5	1.3	ppm
046-61A	Girls Locker Rm SF 1 Left	6/21/16 14:46	6/30/2016	1606C21-60A	Lead	3	15	ppb
046-62A	Girls Locker Rm SF 2 Right	6/21/16 14:46	6/30/2016	1606C21-61A	Copper	0.4	1.3	ppm
046-62A	Girls Locker Rm SF 2 Right	6/21/16 14:46	6/30/2016	1606C21-61A	Lead	4	15	ppb
046-63A	Girls Locker Rm Spigot	6/21/16 14:50	6/30/2016	1606C21-62A	Copper	3.8	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
046-63A	Girls Locker Rm Spigot	6/21/16 14:50	6/30/2016	1606C21-62A	Lead	480	15	ppb
046-64A	Girls Locker Rm Shower 1	6/21/16 14:57	6/30/2016	1606C21-63A	Copper	1.0	1.3	ppm
046-64A	Girls Locker Rm Shower 1	6/21/16 14:57	6/30/2016	1606C21-63A	Lead	39	15	ppb
046-65A	Girls Locker Rm Shower 2	6/21/16 14:55	6/30/2016	1606C21-64A	Copper	1.6	1.3	ppm
046-65A	Girls Locker Rm Shower 2	6/21/16 14:55	6/30/2016	1606C21-64A	Lead	95	15	ppb
046-66A	200 Custodian Slop Sink	6/21/16 15:05	6/30/2016	1606C21-65A	Copper	0.7	1.3	ppm
046-66A	200 Custodian Slop Sink	6/21/16 15:05	6/30/2016	1606C21-65A	Lead	10	15	ppb
046-68A	Rm 20 DF	6/21/16 15:03	6/30/2016	1606C21-66A	Copper	0.6	1.3	ppm
046-68A	Rm 20 DF	6/21/16 15:03	6/30/2016	1606C21-66A	Lead	3	15	ppb
046-70A	Science Lab SF 1 (Right)	6/21/16 15:09	6/30/2016	1606C21-67A	Copper	0.4	1.3	ppm
046-70A	Science Lab SF 1 (Right)	6/21/16 15:09	6/30/2016	1606C21-67A	Lead	ND	15	ppb
046-71A	Science Lab SF 2	6/21/16 15:09	6/30/2016	1606C21-68A	Copper	0.3	1.3	ppm
046-71A	Science Lab SF 2	6/21/16 15:09	6/30/2016	1606C21-68A	Lead	7	15	ppb
046-72A	Science Lab SF 3	6/21/16 15:11	6/30/2016	1606C21-69A	Copper	0.3	1.3	ppm
046-72A	Science Lab SF 3	6/21/16 15:11	6/30/2016	1606C21-69A	Lead	4	15	ppb
046-73A	Science Lab SF 4	6/21/16 15:11	6/30/2016	1606C21-70A	Copper	0.3	1.3	ppm
046-73A	Science Lab SF 4	6/21/16 15:11	6/30/2016	1606C21-70A	Lead	5	15	ppb
046-74A	Science Lab SF 5 (Left)	6/21/16 15:06	6/30/2016	1606C21-71A	Copper	0.5	1.3	ppm
046-74A	Science Lab SF 5 (Left)	6/21/16 15:06	6/30/2016	1606C21-71A	Lead	3	15	ppb
046-75A	DF 2 Gym	6/21/16 15:19	6/30/2016	1606C21-72A	Copper	0.4	1.3	ppm
046-75A	DF 2 Gym	6/21/16 15:19	6/30/2016	1606C21-72A	Lead	2	15	ppb
046-76A	Spigot in Boiler Rm	6/21/16 15:20	6/30/2016	1606C21-73A	Copper	0.4	1.3	ppm
046-76A	Spigot in Boiler Rm	6/21/16 15:20	6/30/2016	1606C21-73A	Lead	1	15	ppb
046-77A	Café-Ktchn White Hnd Wsh	6/21/16 15:34	6/30/2016	1606C21-74A	Copper	0.6	1.3	ppm
046-77A	Café-Ktchn White Hnd Wsh	6/21/16 15:34	6/30/2016	1606C21-74A	Lead	1	15	ppb
046-78A	Café Kitchen (Spray) Sink	6/21/16 15:28	6/30/2016	1606C22-01A	Copper	0.3	1.3	ppm
046-78A	Café Kitchen (Spray) Sink	6/21/16 15:28	6/30/2016	1606C22-01A	Lead	1	15	ppb
046-79A	Café Kitchen Faucet	6/21/16 15:29	6/30/2016	1606C22-02A	Copper	0.3	1.3	ppm
046-79A	Café Kitchen Faucet	6/21/16 15:29	6/30/2016	1606C22-02A	Lead	11	15	ppb
046-80A	Café Kitchen Slop Sink	6/21/16 15:30	6/30/2016	1606C22-03A	Copper	0.1	1.3	ppm
046-80A	Café Kitchen Slop Sink	6/21/16 15:30	6/30/2016	1606C22-03A	Lead	3	15	ppb
046-81A	Café Kitchen Sink Food Prep (Sp	6/21/16 15:39	6/30/2016	1606C22-04A	Copper	0.2	1.3	ppm
046-81A	Café Kitchen Sink Food Prep (Sp	6/21/16 15:39	6/30/2016	1606C22-04A	Lead	7	15	ppb
046-82A	Café Kitchen Bathroom HW	6/21/16 15:36	6/30/2016	1606C22-05A	Copper	0.7	1.3	ppm
046-82A	Café Kitchen Bathroom HW	6/21/16 15:36	6/30/2016	1606C22-05A	Lead	2	15	ppb
046-83A	Cafeteria DF	6/21/16 15:25	6/30/2016	1606C22-06A	Copper	0.7	1.3	ppm
046-83A	Cafeteria DF	6/21/16 15:25	6/30/2016	1606C22-06A	Lead	ND	15	ppb
046-84A	Cafeteria DF 2	6/21/16 15:25	6/30/2016	1606C22-07A	Copper	0.8	1.3	ppm
046-84A	Cafeteria DF 2	6/21/16 15:25	6/30/2016	1606C22-07A	Lead	ND	15	ppb
046-85A	Cafeteria Water Bottle Disp	6/21/16 15:31	6/30/2016	1606C22-08A	Copper	0.6	1.3	ppm
046-85A	Cafeteria Water Bottle Disp	6/21/16 15:31	6/30/2016	1606C22-08A	Lead	ND	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Level	Units
046-86A	Room #1 Bathroom Sink	6/21/16 15:49	6/30/2016	1606C22-09A	Copper	ND	1.3	ppm
046-86A	Room #1 Bathroom Sink	6/21/16 15:49	6/30/2016	1606C22-09A	Lead	8	15	ppb
046-87A	Room #2 FS	6/21/16 15:50	6/30/2016	1606C22-10A	Copper	0.5	1.3	ppm
046-87A	Room #2 FS	6/21/16 15:50	6/30/2016	1606C22-10A	Lead	4	15	ppb
046-88A	Custodian Slop Sink	6/21/16 15:54	6/30/2016	1606C22-11A	Copper	0.4	1.3	ppm
046-88A	Custodian Slop Sink	6/21/16 15:54	6/30/2016	1606C22-11A	Lead	26	15	ppb
046-89A	Womens Restroom Sink	6/21/16 15:51	6/30/2016	1606C22-12A	Copper	0.2	1.3	ppm
046-89A	Womens Restroom Sink	6/21/16 15:51	6/30/2016	1606C22-12A	Lead	3	15	ppb
046-90A	Mens Restroom Sink	6/21/16 15:50	6/30/2016	1606C22-13A	Copper	ND	1.3	ppm
046-90A	Mens Restroom Sink	6/21/16 15:50	6/30/2016	1606C22-13A	Lead	10	15	ppb
046-91A	Room 11 Faucet	6/21/16 15:55	6/30/2016	1606C22-14A	Copper	0.1	1.3	ppm
046-91A	Room 11 Faucet	6/21/16 15:55	6/30/2016	1606C22-14A	Lead	14	15	ppb
046-92A	Room #3 Faucet	6/21/16 15:57	6/30/2016	1606C22-15A	Copper	0.5	1.3	ppm
046-92A	Room #3 Faucet	6/21/16 15:57	6/30/2016	1606C22-15A	Lead	18	15	ppb
046-93A	Room #3 DF	6/21/16 15:57	6/30/2016	1606C22-16A	Copper	0.9	1.3	ppm
046-93A	Room #3 DF	6/21/16 15:57	6/30/2016	1606C22-16A	Lead	ND	15	ppb
046-94A	Room #4 SF	6/21/16 16:00	6/30/2016	1606C22-17A	Copper	0.2	1.3	ppm
046-94A	Room #4 SF	6/21/16 16:00	6/30/2016	1606C22-17A	Lead	12	15	ppb
046-95A	Room #5 SF	6/21/16 15:59	6/30/2016	1606C22-18A	Copper	0.6	1.3	ppm
046-95A	Room #5 SF	6/21/16 15:59	6/30/2016	1606C22-18A	Lead	26	15	ppb
046-96A	Room #5 Bathroom Sink	6/21/16 16:01	6/30/2016	1606C22-19A	Copper	0.4	1.3	ppm
046-96A	Room #5 Bathroom Sink	6/21/16 16:01	6/30/2016	1606C22-19A	Lead	5	15	ppb
046-97A	Room #6 Bathroom Sink	6/21/16 16:07	6/30/2016	1606C22-20A	Copper	0.4	1.3	ppm
046-97A	Room #6 Bathroom Sink	6/21/16 16:07	6/30/2016	1606C22-20A	Lead	2	15	ppb
046-98A	Room #6 SF	6/21/16 16:10	6/30/2016	1606C22-21A	Copper	0.3	1.3	ppm
046-98A	Room #6 SF	6/21/16 16:10	6/30/2016	1606C22-21A	Lead	3	15	ppb
046-99A	Room #7 KIN	6/21/16 16:04	6/30/2016	1606C22-22A	Copper	0.7	1.3	ppm
046-99A	Room #7 KIN	6/21/16 16:04	6/30/2016	1606C22-22A	Lead	2	15	ppb
046-100A	Boys Bathroom Sink 1	6/21/16 16:05	6/30/2016	1606C22-23A	Copper	0.3	1.3	ppm
046-100A	Boys Bathroom Sink 1	6/21/16 16:05	6/30/2016	1606C22-23A	Lead	7	15	ppb
046-101A	Boys Bathroom Spigot 1	6/21/16 16:08	6/30/2016	1606C22-24A	Copper	26.9	1.3	ppm
046-101A	Boys Bathroom Spigot 1	6/21/16 16:08	6/30/2016	1606C22-24A	Lead	2500	15	ppb
046-102A	Boys Bathroom Spigot 2	6/21/16 16:13	6/30/2016	1606C22-25A	Copper	3.1	1.3	ppm
046-102A	Boys Bathroom Spigot 2	6/21/16 16:13	6/30/2016	1606C22-25A	Lead	180	15	ppb
046-103A	Girls Bathroom Sink 1	6/21/16 16:16	6/30/2016	1606C22-26A	Copper	0.2	1.3	ppm
046-103A	Girls Bathroom Sink 1	6/21/16 16:16	6/30/2016	1606C22-26A	Lead	8	15	ppb
046-104A	Girls Bathroom Sink 2	6/21/16 16:16	6/30/2016	1606C22-27A	Copper	0.2	1.3	ppm
046-104A	Girls Bathroom Sink 2	6/21/16 16:16	6/30/2016	1606C22-27A	Lead	3	15	ppb
046-105A	Girls Bathroom Spigot 1	6/21/16 16:16	6/30/2016	1606C22-28A	Copper	27.8	1.3	ppm
046-105A	Girls Bathroom Spigot 1	6/21/16 16:16	6/30/2016	1606C22-28A	Lead	480	15	ppb
046-106A	Girls Bathroom Spigot 2	6/21/16 16:19	6/30/2016	1606C22-29A	Copper	0.8	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hosford Middle School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
046-106A	Girls Bathroom Spigot 2	6/21/16 16:19	6/30/2016	1606C22-29A	Lead	300	15	ppb
046-107A	Classroom 8 DF 1	6/21/16 16:22	6/30/2016	1606C22-30A	Copper	0.7	1.3	ppm
046-107A	Classroom 8 DF 1	6/21/16 16:22	6/30/2016	1606C22-30A	Lead	3	15	ppb
046-108A	Classroom 8 SF 1	6/21/16 16:22	6/30/2016	1606C22-31A	Copper	0.6	1.3	ppm
046-108A	Classroom 8 SF 1	6/21/16 16:22	6/30/2016	1606C22-31A	Lead	6	15	ppb
046-109A	Classroom 8 SF 2	6/21/16 16:16	6/30/2016	1606C22-32A	Copper	0.5	1.3	ppm
046-109A	Classroom 8 SF 2	6/21/16 16:16	6/30/2016	1606C22-32A	Lead	14	15	ppb
046-110A	Classroom 8 SF 3	6/21/16 16:26	6/30/2016	1606C22-33A	Copper	0.7	1.3	ppm
046-110A	Classroom 8 SF 3	6/21/16 16:26	6/30/2016	1606C22-33A	Lead	6	15	ppb
046-111A	Classroom 8 SF 4	6/21/16 16:26	6/30/2016	1606C22-34A	Copper	0.7	1.3	ppm
046-111A	Classroom 8 SF 4	6/21/16 16:26	6/30/2016	1606C22-34A	Lead	5	15	ppb
046-112A	Classroom 8 SF 5	6/21/16 16:28	6/30/2016	1606C22-35A	Copper	0.4	1.3	ppm
046-112A	Classroom 8 SF 5	6/21/16 16:28	6/30/2016	1606C22-35A	Lead	7	15	ppb
046-113A	Classroom 8 SF 6	6/21/16 16:28	6/30/2016	1606C22-36A	Copper	0.3	1.3	ppm
046-113A	Classroom 8 SF 6	6/21/16 16:28	6/30/2016	1606C22-36A	Lead	13	15	ppb
046-114A	Classroom 8 SF 7	6/21/16 16:30	6/30/2016	1606C22-37A	Copper	0.4	1.3	ppm
046-114A	Classroom 8 SF 7	6/21/16 16:30	6/30/2016	1606C22-37A	Lead	4	15	ppb
046-115A	Classroom 9 SF 1	6/21/16 16:29	6/30/2016	1606C22-38A	Copper	0.3	1.3	ppm
046-115A	Classroom 9 SF 1	6/21/16 16:29	6/30/2016	1606C22-38A	Lead	ND	15	ppb
046-116A	Classroom 9 SF 2	6/21/16 16:29	6/30/2016	1606C22-39A	Copper	0.5	1.3	ppm
046-116A	Classroom 9 SF 2	6/21/16 16:29	6/30/2016	1606C22-39A	Lead	19	15	ppb
046-117A	Classroom 9 SF 3	6/21/16 16:29	6/30/2016	1606C22-40A	Copper	0.4	1.3	ppm
046-117A	Classroom 9 SF 3	6/21/16 16:29	6/30/2016	1606C22-40A	Lead	12	15	ppb
046-118A	Classroom 9 SF 4	6/21/16 16:23	6/30/2016	1606C22-41A	Copper	0.5	1.3	ppm
046-118A	Classroom 9 SF 4	6/21/16 16:23	6/30/2016	1606C22-41A	Lead	11	15	ppb
046-119A	Classroom 9 SF 5	6/21/16 16:23	6/30/2016	1606C22-42A	Copper	0.6	1.3	ppm
046-119A	Classroom 9 SF 5	6/21/16 16:23	6/30/2016	1606C22-42A	Lead	7	15	ppb
046-120A	Classroom 9 SF 6	6/21/16 16:23	6/30/2016	1606C22-43A	Copper	0.7	1.3	ppm
046-120A	Classroom 9 SF 6	6/21/16 16:23	6/30/2016	1606C22-43A	Lead	14	15	ppb
046-121A	Classroom 9 DF	6/21/16 16:33	6/30/2016	1606C22-44A	Copper	1.0	1.3	ppm
046-121A	Classroom 9 DF	6/21/16 16:33	6/30/2016	1606C22-44A	Lead	3	15	ppb
046-122A	Corridor WF 1	6/21/16 16:36	6/30/2016	1606C22-45A	Copper	0.7	1.3	ppm
046-122A	Corridor WF 1	6/21/16 16:36	6/30/2016	1606C22-45A	Lead	ND	15	ppb
046-123A	Corridor WF Right #2	6/21/16 16:36	7/1/2016	1606C22-46A	Copper	0.5	1.3	ppm
046-123A	Corridor WF Right #2	6/21/16 16:36	7/1/2016	1606C22-46A	Lead	ND	15	ppb
046-124A	Exterior Spigot WS1	6/21/16 17:03	7/1/2016	1606C22-47A	Copper	ND	1.3	ppm
046-124A	Exterior Spigot WS1	6/21/16 17:03	7/1/2016	1606C22-47A	Lead	5	15	ppb
046-125A	Exterior Spigot WS2	6/21/16 17:05	7/1/2016	1606C22-48A	Copper	ND	1.3	ppm
046-125A	Exterior Spigot WS2	6/21/16 17:05	7/1/2016	1606C22-48A	Lead	130	15	ppb
046-126A	Exterior Spigot WS3	6/21/16 16:51	7/1/2016	1606C22-49A	Copper	ND	1.3	ppm
046-126A	Exterior Spigot WS3	6/21/16 16:51	7/1/2016	1606C22-49A	Lead	ND	15	ppb

Portland Public Schools
 Lead and Copper Water Sampling Results
 A (First Draw) Sample Data
 Hosford Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
046-127A Exterior Spigot WS4	6/21/16 16:57	7/1/2016	1606C22-50A	Copper	ND	1.3	ppm
046-127A Exterior Spigot WS4	6/21/16 16:57	7/1/2016	1606C22-50A	Lead	16	15	ppb
046-128A Exterior Spigot WS5	6/21/16 17:00	7/1/2016	1606C22-51A	Copper	ND	1.3	ppm
046-128A Exterior Spigot WS5	6/21/16 17:00	7/1/2016	1606C22-51A	Lead	8	15	ppb

EPA Action Level for Lead of 15 ppb
 EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.