

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Rieke Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
							Action	
072-01A	Boiler Room SF	6/21/16 13:02	6/28/2016	1606C27-01A	Copper	ND	1.3	ppm
072-01A	Boiler Room SF	6/21/16 13:02	6/28/2016	1606C27-01A	Lead	6	15	ppb
072-02A	Custodian SF	6/21/16 13:04	6/28/2016	1606C27-02A	Copper	ND	1.3	ppm
072-02A	Custodian SF	6/21/16 13:04	6/28/2016	1606C27-02A	Lead	5	15	ppb
072-03A	Nurse SF Bathroom	6/21/16 13:06	6/28/2016	1606C27-03A	Copper	ND	1.3	ppm
072-03A	Nurse SF Bathroom	6/21/16 13:06	6/28/2016	1606C27-03A	Lead	7	15	ppb
072-04A	Nurse SF Kitchen	6/21/16 13:05	6/28/2016	1606C27-04A	Copper	ND	1.3	ppm
072-04A	Nurse SF Kitchen	6/21/16 13:05	6/28/2016	1606C27-04A	Lead	4	15	ppb
072-05A	Faculty Restroom SF	6/21/16 13:08	6/28/2016	1606C27-05A	Copper	ND	1.3	ppm
072-05A	Faculty Restroom SF	6/21/16 13:08	6/28/2016	1606C27-05A	Lead	3	15	ppb
072-06A	Hallway DF	6/21/16 13:10	6/28/2016	1606C27-06A	Copper	ND	1.3	ppm
072-06A	Hallway DF	6/21/16 13:10	6/28/2016	1606C27-06A	Lead	ND	15	ppb
072-07A	Room 1 SF	6/21/16 13:16	6/28/2016	1606C27-07A	Copper	ND	1.3	ppm
072-07A	Room 1 SF	6/21/16 13:16	6/28/2016	1606C27-07A	Lead	9	15	ppb
072-08A	Room 1 DF	6/21/16 13:18	6/28/2016	1606C27-08A	Copper	ND	1.3	ppm
072-08A	Room 1 DF	6/21/16 13:18	6/28/2016	1606C27-08A	Lead	6	15	ppb
072-09A	12 SF	6/21/16 13:12	6/28/2016	1606C27-09A	Copper	0.2	1.3	ppm
072-09A	12 SF	6/21/16 13:12	6/28/2016	1606C27-09A	Lead	47	15	ppb
072-10A	12 DF	6/21/16 13:14	6/29/2016	1606C27-10A	Copper	ND	1.3	ppm
072-10A	12 DF	6/21/16 13:14	6/29/2016	1606C27-10A	Lead	65	15	ppb
072-11A	11 SF	6/21/16 13:18	6/28/2016	1606C27-11A	Copper	ND	1.3	ppm
072-11A	11 SF	6/21/16 13:18	6/28/2016	1606C27-11A	Lead	17	15	ppb
072-12A	11 DF	6/21/16 13:20	6/28/2016	1606C27-12A	Copper	ND	1.3	ppm
072-12A	11 DF	6/21/16 13:20	6/28/2016	1606C27-12A	Lead	2	15	ppb
072-13A	2 SF	6/21/16 13:23	6/28/2016	1606C27-13A	Copper	0.1	1.3	ppm
072-13A	2 SF	6/21/16 13:23	6/28/2016	1606C27-13A	Lead	6	15	ppb
072-14A	2 DF	6/21/16 13:25	6/28/2016	1606C27-14A	Copper	ND	1.3	ppm
072-14A	2 DF	6/21/16 13:25	6/28/2016	1606C27-14A	Lead	3	15	ppb
072-15A	10 SF	6/21/16 13:27	6/28/2016	1606C27-15A	Copper	ND	1.3	ppm
072-15A	10 SF	6/21/16 13:27	6/28/2016	1606C27-15A	Lead	3	15	ppb
072-16A	10 DF	6/21/16 13:29	6/28/2016	1606C27-16A	Copper	ND	1.3	ppm
072-16A	10 DF	6/21/16 13:29	6/28/2016	1606C27-16A	Lead	3	15	ppb
072-17A	3 SF	6/21/16 13:31	6/28/2016	1606C27-17A	Copper	0.1	1.3	ppm
072-17A	3 SF	6/21/16 13:31	6/28/2016	1606C27-17A	Lead	8	15	ppb
072-18A	3 DF	6/21/16 13:34	6/28/2016	1606C27-18A	Copper	ND	1.3	ppm
072-18A	3 DF	6/21/16 13:34	6/28/2016	1606C27-18A	Lead	2	15	ppb
072-19A	Faculty Bathroom SF	6/21/16 13:42	6/28/2016	1606C27-19A	Copper	ND	1.3	ppm
072-19A	Faculty Bathroom SF	6/21/16 13:42	6/28/2016	1606C27-19A	Lead	6	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Rieke Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
072-20A	Boys SF	6/21/16 13:34	6/28/2016	1606C27-20A	Copper	ND	1.3	ppm
<b>072-20A</b>	<b>Boys SF</b>	<b>6/21/16 13:34</b>	<b>6/28/2016</b>	<b>1606C27-20A</b>	<b>Lead</b>	<b>15</b>	<b>15</b>	<b>ppb</b>
072-21A	Boys SF	6/21/16 13:36	6/28/2016	1606C27-21A	Copper	ND	1.3	ppm
072-21A	Boys SF	6/21/16 13:36	6/28/2016	1606C27-21A	Lead	6	15	ppb
072-22A	Boys SF	6/21/16 13:38	6/28/2016	1606C27-22A	Copper	ND	1.3	ppm
072-22A	Boys SF	6/21/16 13:38	6/28/2016	1606C27-22A	Lead	7	15	ppb
072-23A	Boys SF	6/21/16 13:40	6/28/2016	1606C27-23A	Copper	ND	1.3	ppm
072-23A	Boys SF	6/21/16 13:40	6/28/2016	1606C27-23A	Lead	6	15	ppb
072-24A	Boys SF	6/21/16 13:42	6/28/2016	1606C27-24A	Copper	ND	1.3	ppm
072-24A	Boys SF	6/21/16 13:42	6/28/2016	1606C27-24A	Lead	5	15	ppb
072-25A	Girls SF	6/21/16 13:44	6/28/2016	1606C27-25A	Copper	ND	1.3	ppm
072-25A	Girls SF	6/21/16 13:44	6/28/2016	1606C27-25A	Lead	9	15	ppb
072-26A	Girls SF	6/21/16 13:46	6/28/2016	1606C27-26A	Copper	ND	1.3	ppm
072-26A	Girls SF	6/21/16 13:46	6/28/2016	1606C27-26A	Lead	8	15	ppb
072-27A	Girls SF	6/21/16 13:48	6/30/2016	1606C27-27A	Copper	ND	1.3	ppm
072-27A	Girls SF	6/21/16 13:48	6/28/2016	1606C27-27A	Lead	7	15	ppb
072-28A	Girls SF	6/21/16 13:50	6/30/2016	1606C27-28A	Copper	ND	1.3	ppm
072-28A	Girls SF	6/21/16 13:50	6/28/2016	1606C27-28A	Lead	7	15	ppb
072-29A	4 SF	6/21/16 14:18	6/30/2016	1606C27-29A	Copper	0.1	1.3	ppm
072-29A	4 SF	6/21/16 14:18	6/28/2016	1606C27-29A	Lead	14	15	ppb
072-30A	4 DF	6/21/16 14:22	6/30/2016	1606C27-30A	Copper	ND	1.3	ppm
072-30A	4 DF	6/21/16 14:22	6/28/2016	1606C27-30A	Lead	ND	15	ppb
072-31A	Library Media Ctr SF	6/21/16 13:56	6/30/2016	1606C27-31A	Copper	ND	1.3	ppm
072-31A	Library Media Ctr SF	6/21/16 13:56	6/28/2016	1606C27-31A	Lead	4	15	ppb
072-32A	Library Media Ctr DF	6/21/16 13:58	6/30/2016	1606C27-32A	Copper	ND	1.3	ppm
072-32A	Library Media Ctr DF	6/21/16 13:58	6/28/2016	1606C27-32A	Lead	2	15	ppb
072-33A	5 SF	6/21/16 13:51	6/30/2016	1606C27-33A	Copper	0.2	1.3	ppm
072-33A	5 SF	6/21/16 13:51	6/28/2016	1606C27-33A	Lead	7	15	ppb
072-34A	5 DF	6/21/16 13:53	6/30/2016	1606C27-34A	Copper	0.1	1.3	ppm
072-34A	5 DF	6/21/16 13:53	6/28/2016	1606C27-34A	Lead	3	15	ppb
072-35A	Hallway DF	6/21/16 14:01	6/30/2016	1606C27-35A	Copper	ND	1.3	ppm
072-35A	Hallway DF	6/21/16 14:01	6/28/2016	1606C27-35A	Lead	2	15	ppb
072-36A	6 SF	6/21/16 14:03	6/30/2016	1606C27-36A	Copper	0.2	1.3	ppm
072-36A	6 SF	6/21/16 14:03	6/28/2016	1606C27-36A	Lead	10	15	ppb
072-37A	6 DF	6/21/16 14:05	6/29/2016	1606C27-37A	Copper	ND	1.3	ppm
<b>072-37A</b>	<b>6 DF</b>	<b>6/21/16 14:05</b>	<b>6/28/2016</b>	<b>1606C27-37A</b>	<b>Lead</b>	<b>17</b>	<b>15</b>	<b>ppb</b>
072-38A	7 SF	6/21/16 14:15	6/29/2016	1606C27-38A	Copper	0.2	1.3	ppm
072-38A	7 SF	6/21/16 14:15	6/28/2016	1606C27-38A	Lead	7	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Rieke Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
072-39A	7 DF	6/21/16 14:17	6/29/2016	1606C27-39A	Copper	0.1	1.3	ppm
072-39A	7 DF	6/21/16 14:17	6/28/2016	1606C27-39A	Lead	6	15	ppb
072-40A	8 DF	6/21/16 14:07	6/29/2016	1606C27-40A	Copper	ND	1.3	ppm
072-40A	8 DF	6/21/16 14:07	6/28/2016	1606C27-40A	Lead	3	15	ppb
072-41A	8 SF	6/21/16 14:10	6/29/2016	1606C27-41A	Copper	ND	1.3	ppm
072-41A	8 SF	6/21/16 14:10	6/28/2016	1606C27-41A	Lead	2	15	ppb
072-42A	Storage Restroom SF	6/21/16 14:50	6/29/2016	1606C27-42A	Copper	0.5	1.3	ppm
072-42A	Storage Restroom SF	6/21/16 14:50	6/28/2016	1606C27-42A	Lead	3	15	ppb
072-43A	Kitchen Bathroom SF	6/21/16 14:48	6/29/2016	1606C27-43A	Copper	ND	1.3	ppm
072-43A	Kitchen Bathroom SF	6/21/16 14:48	6/28/2016	1606C27-43A	Lead	3	15	ppb
072-44A	Kitchen Hand SF	6/21/16 14:31	6/29/2016	1606C27-44A	Copper	0.1	1.3	ppm
072-44A	Kitchen Hand SF	6/21/16 14:31	6/28/2016	1606C27-44A	Lead	8	15	ppb
072-45A	Kitchen Slop SF	6/21/16 14:43	6/29/2016	1606C27-45A	Copper	0.1	1.3	ppm
072-45A	Kitchen Slop SF	6/21/16 14:43	6/29/2016	1606C27-45A	Lead	15	15	ppb
072-46A	Food Prep SF	6/21/16 14:46	6/29/2016	1606C27-46A	Copper	ND	1.3	ppm
072-46A	Food Prep SF	6/21/16 14:46	6/28/2016	1606C27-46A	Lead	10	15	ppb
072-47A	DF in Gym	6/21/16 14:29	6/29/2016	1606C27-47A	Copper	ND	1.3	ppm
072-47A	DF in Gym	6/21/16 14:29	6/28/2016	1606C27-47A	Lead	16	15	ppb
072-48A	14 SF	6/21/16 14:23	6/29/2016	1606C27-48A	Copper	ND	1.3	ppm
072-48A	14 SF	6/21/16 14:23	6/28/2016	1606C27-48A	Lead	8	15	ppb
072-49A	15 SF	6/21/16 14:26	6/29/2016	1606C27-49A	Copper	ND	1.3	ppm
072-49A	15 SF	6/21/16 14:26	6/28/2016	1606C27-49A	Lead	10	15	ppb
072-50A	Hallway DF	6/21/16 14:25	6/29/2016	1606C27-50A	Copper	ND	1.3	ppm
072-50A	Hallway DF	6/21/16 14:25	6/28/2016	1606C27-50A	Lead	12	15	ppb
072-51A	Out Storage Closet WS	6/21/16 15:17	6/29/2016	1606C27-51A	Copper	7.5	1.3	ppm
072-51A	Out Storage Closet WS	6/21/16 15:17	6/29/2016	1606C27-51A	Lead	240	15	ppb
072-52A	Outside WS	6/21/16 15:19	6/29/2016	1606C27-52A	Copper	ND	1.3	ppm
072-52A	Outside WS	6/21/16 15:19	6/29/2016	1606C27-52A	Lead	12	15	ppb
072-53A	Outside WS	6/21/16 15:19	6/29/2016	1606C27-53A	Copper	ND	1.3	ppm
072-53A	Outside WS	6/21/16 15:19	6/29/2016	1606C27-53A	Lead	1	15	ppb
072-54A	Outside WS	6/21/16 14:52	6/29/2016	1606C27-54A	Copper	ND	1.3	ppm
072-54A	Outside WS	6/21/16 14:52	6/29/2016	1606C27-54A	Lead	29	15	ppb
072-55A	Outside WS	6/21/16 14:55	6/29/2016	1606C27-55A	Copper	ND	1.3	ppm
072-55A	Outside WS	6/21/16 14:55	6/28/2016	1606C27-55A	Lead	37	15	ppb
072-56A	Outside WS	6/21/16 14:59	6/29/2016	1606C27-56A	Copper	ND	1.3	ppm
072-56A	Outside WS	6/21/16 14:59	6/28/2016	1606C27-56A	Lead	29	15	ppb
072-57A	Outside WS	6/21/16 15:15	6/29/2016	1606C27-57A	Copper	0.6	1.3	ppm
072-57A	Outside WS	6/21/16 15:15	6/28/2016	1606C27-57A	Lead	130	15	ppb

Portland Public Schools  
 Lead and Copper Water Sampling Results  
 A (First Draw) Sample Data  
 Rieke Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
							Action Level	
072-58A	Outside WS	6/21/16 15:06	6/29/2016	1606C27-58A	Copper	ND	1.3	ppm
072-58A	Outside WS	6/21/16 15:06	6/28/2016	1606C27-58A	Lead	9	15	ppb
072-59A	Outside WS	6/21/16 15:03	6/29/2016	1606C27-59A	Copper	ND	1.3	ppm
072-59A	Outside WS	6/21/16 15:03	6/29/2016	1606C27-59A	Lead	15	15	ppb

EPA Action Level for Lead of 15 ppb  
 EPA Action Level for Copper of 1.3 ppm

ND = Non detect

**Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.**