

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sacajawea Head Start

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	ContainerID	Analyte	Results	EPA	
						Action Level	Units
079-01A Boiler Room Shower Head	6/19/2016 3:06	6/24/2016 13:52	606210001	Copper	0.0	1.3	ppm
079-01A Boiler Room Shower Head	6/19/2016 3:06	6/24/2016 13:52	606210001	Lead	44	15	ppb
079-02A Boiler Room SF	6/19/2016 3:08	6/24/2016 13:52	606210002	Copper	0.0	1.3	ppm
079-02A Boiler Room SF	6/19/2016 3:08	6/24/2016 13:52	606210002	Lead	4	15	ppb
079-03A Custodial Closet SF	6/19/2016 3:12	6/24/2016 13:52	606210003	Copper	0.0	1.3	ppm
079-03A Custodial Closet SF	6/19/2016 3:12	6/24/2016 13:52	606210003	Lead	5	15	ppb
079-04A Kitchen SF	6/19/2016 3:16	6/24/2016 13:52	606210004	Copper	0.0	1.3	ppm
079-04A Kitchen SF	6/19/2016 3:16	6/24/2016 13:52	606210004	Lead	6	15	ppb
079-05A Kitchen Food Prep SF	6/19/2016 3:17	6/24/2016 13:52	606210005	Copper	0.1	1.3	ppm
079-05A Kitchen Food Prep SF	6/19/2016 3:17	6/24/2016 13:52	606210005	Lead	1	15	ppb
079-06A Kitchen SF	6/19/2016 3:19	6/24/2016 13:52	606210006	Copper	0.1	1.3	ppm
079-06A Kitchen SF	6/19/2016 3:19	6/24/2016 13:52	606210006	Lead	3	15	ppb
079-07A Drinking Fountain near Kitchen	6/19/2016 3:21	6/24/2016 13:52	606210007	Copper	0.1	1.3	ppm
079-07A Drinking Fountain near Kitchen	6/19/2016 3:21	6/24/2016 13:52	606210007	Lead	5	15	ppb
079-08A Classroom 106 SF	6/19/2016 3:24	6/24/2016 13:52	606210008	Copper	0.1	1.3	ppm
079-08A Classroom 106 SF	6/19/2016 3:24	6/24/2016 13:52	606210008	Lead	5	15	ppb
079-09A Classroom 106 DF	6/19/2016 3:26	6/24/2016 13:53	606210009	Copper	0.1	1.3	ppm
079-09A Classroom 106 DF	6/19/2016 3:26	6/24/2016 13:53	606210009	Lead	11	15	ppb
079-10A Classroom 107 SF	6/19/2016 3:29	6/24/2016 13:53	606210010	Copper	0.1	1.3	ppm
079-10A Classroom 107 SF	6/19/2016 3:29	6/24/2016 13:53	606210010	Lead	7	15	ppb
079-11A Girls Bathroom SF	6/19/2016 3:32	6/24/2016 13:53	606210011	Copper	0.1	1.3	ppm
079-11A Girls Bathroom SF	6/19/2016 3:32	6/24/2016 13:53	606210011	Lead	5	15	ppb
079-12A Girls Bathroom SF	6/19/2016 3:34	6/24/2016 13:53	606210012	Copper	0.1	1.3	ppm
079-12A Girls Bathroom SF	6/19/2016 3:34	6/24/2016 13:53	606210012	Lead	2	15	ppb
079-13A Boys Bathroom SF	6/19/2016 3:38	6/24/2016 13:53	606210013	Copper	0.1	1.3	ppm
079-13A Boys Bathroom SF	6/19/2016 3:38	6/24/2016 13:53	606210013	Lead	5	15	ppb
079-14A Boys Bathroom SF	6/19/2016 3:39	6/24/2016 13:53	606210014	Copper	0.1	1.3	ppm
079-14A Boys Bathroom SF	6/19/2016 3:39	6/24/2016 13:53	606210014	Lead	9	15	ppb
079-15A Classroom 105 SF	6/19/2016 3:43	6/24/2016 13:53	606210015	Copper	0.1	1.3	ppm
079-15A Classroom 105 SF	6/19/2016 3:43	6/24/2016 13:53	606210015	Lead	2	15	ppb
079-16A Classroom 105 SF	6/19/2016 3:44	6/24/2016 13:53	606210016	Copper	0.1	1.3	ppm
079-16A Classroom 105 SF	6/19/2016 3:44	6/24/2016 13:53	606210016	Lead	8	15	ppb
079-17A Classroom 108 SF	6/19/2016 3:49	6/24/2016 13:53	606210017	Copper	0.1	1.3	ppm
079-17A Classroom 108 SF	6/19/2016 3:49	6/24/2016 13:53	606210017	Lead	3	15	ppb
079-18A Classroom 108 DF	6/19/2016 3:51	6/24/2016 13:53	606210018	Copper	0.2	1.3	ppm
079-18A Classroom 108 DF	6/19/2016 3:51	6/24/2016 13:53	606210018	Lead	3	15	ppb
079-19A Classroom 104 SF	6/19/2016 3:55	6/24/2016 13:55	606210019	Copper	0.2	1.3	ppm
079-19A Classroom 104 SF	6/19/2016 3:55	6/24/2016 13:55	606210019	Lead	2	15	ppb
079-20A Classroom 104 DF	6/19/2016 3:56	6/24/2016 13:55	606210020	Copper	0.2	1.3	ppm
079-20A Classroom 104 DF	6/19/2016 3:56	6/24/2016 13:55	606210020	Lead	4	15	ppb
079-21A Staff Lounge 109 SF	6/19/2016 3:59	6/24/2016 13:55	606210021	Copper	0.3	1.3	ppm
079-21A Staff Lounge 109 SF	6/19/2016 3:59	6/24/2016 13:55	606210021	Lead	5	15	ppb
079-22A Boys Bathroom SF	6/19/2016 4:02	6/24/2016 13:55	606210022	Copper	0.5	1.3	ppm
079-22A Boys Bathroom SF	6/19/2016 4:02	6/24/2016 13:55	606210022	Lead	3	15	ppb
079-23A Boys Bathroom SF	6/19/2016 4:05	6/24/2016 13:56	606210023	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sacajawea Head Start

079-23A Boys Bathroom SF	6/19/2016 4:05	6/24/2016 13:56	606210023	Lead	7	15	ppb
079-24A Girls Bathroom SF	6/19/2016 4:06	6/24/2016 13:56	606210024	Copper	0.0	1.3	ppm
079-24A Girls Bathroom SF	6/19/2016 4:06	6/24/2016 13:56	606210024	Lead	6	15	ppb
079-25A Girls Bathroom SF	6/19/2016 4:10	6/24/2016 13:56	606210025	Copper	0.0	1.3	ppm
079-25A Girls Bathroom SF	6/19/2016 4:10	6/24/2016 13:56	606210025	Lead	2	15	ppb
079-26A Wellness Center SF	6/19/2016 4:13	6/24/2016 13:56	606210026	Copper	0.0	1.3	ppm
079-26A Wellness Center SF	6/19/2016 4:13	6/24/2016 13:56	606210026	Lead	7	15	ppb
079-27A Faculty Bathroom SF	6/19/2016 4:16	6/24/2016 13:56	606210027	Copper	0.0	1.3	ppm
079-27A Faculty Bathroom SF	6/19/2016 4:16	6/24/2016 13:56	606210027	Lead	17	15	ppb
079-28A Custodial SF	6/19/2016 4:18	6/24/2016 13:56	606210028	Copper	0.0	1.3	ppm
079-28A Custodial SF	6/19/2016 4:18	6/24/2016 13:56	606210028	Lead	2	15	ppb
079-29A Classroom 103 SF	6/19/2016 4:22	6/24/2016 14:00	606210029	Copper	0.0	1.3	ppm
079-29A Classroom 103 SF	6/19/2016 4:22	6/24/2016 14:00	606210029	Lead	3	15	ppb
079-30A Classroom 103 DF	6/19/2016 4:23	6/24/2016 14:00	606210030	Copper	0.0	1.3	ppm
079-30A Classroom 103 DF	6/19/2016 4:23	6/24/2016 14:00	606210030	Lead	3	15	ppb
079-31A Copier Room SF	6/19/2016 4:26	6/24/2016 14:00	606210031	Copper	0.0	1.3	ppm
079-31A Copier Room SF	6/19/2016 4:26	6/24/2016 14:00	606210031	Lead	13	15	ppb
079-32A Supply Room SF	6/19/2016 4:28	6/24/2016 14:00	606210032	Copper	0.0	1.3	ppm
079-32A Supply Room SF	6/19/2016 4:28	6/24/2016 14:00	606210032	Lead	13	15	ppb
079-33A Room 102 SF	6/19/2016 4:31	6/24/2016 14:00	606210033	Copper	0.0	1.3	ppm
079-33A Room 102 SF	6/19/2016 4:31	6/24/2016 14:00	606210033	Lead	76	15	ppb
079-34A Classroom 101 SF	6/19/2016 4:24	6/24/2016 14:00	606210034	Copper	0.0	1.3	ppm
079-34A Classroom 101 SF	6/19/2016 4:24	6/24/2016 14:00	606210034	Lead	9	15	ppb
079-35A Classroom 100 SF	6/19/2016 4:40	6/24/2016 14:00	606210035	Copper	0.0	1.3	ppm
079-35A Classroom 100 SF	6/19/2016 4:40	6/24/2016 14:00	606210035	Lead	6	15	ppb
079-36A Drinking Fountain	6/19/2016 4:43	6/24/2016 14:00	606210036	Copper	0.0	1.3	ppm
079-36A Drinking Fountain	6/19/2016 4:43	6/24/2016 14:00	606210036	Lead	3	15	ppb
079-37A Room 100/101 Bathroom SF	6/19/2016 4:38	6/24/2016 14:00	606210037	Copper	0.0	1.3	ppm
079-37A Room 100/101 Bathroom SF	6/19/2016 4:38	6/24/2016 14:00	606210037	Lead	7	15	ppb
079-38A Outside Water Spigot 1	6/19/2016 4:46	6/24/2016 14:00	606210038	Copper	0.0	1.3	ppm
079-38A Outside Water Spigot 1	6/19/2016 4:46	6/24/2016 14:00	606210038	Lead	19	15	ppb
079-39A Outside Water Spigot 2	6/19/2016 5:03	6/27/2016 19:32	606210039	Copper	0.0	1.3	ppm
079-39A Outside Water Spigot 2	6/19/2016 5:03	6/27/2016 19:32	606210039	Lead	88	15	ppb
079-40A Outside Water Spigot 3	6/19/2016 5:05	6/24/2016 14:29	606210040	Copper	0.0	1.3	ppm
079-40A Outside Water Spigot 3	6/19/2016 5:05	6/24/2016 14:29	606210040	Lead	16	15	ppb
079-41A Outside Water Spigot 4	6/19/2016 5:08	6/24/2016 14:29	606210041	Copper	0.0	1.3	ppm
079-41A Outside Water Spigot 4	6/19/2016 5:08	6/24/2016 14:29	606210041	Lead	82	15	ppb
079-42A Outside Water Spigot 7	6/19/2016 4:58	6/24/2016 14:29	606210042	Copper	0.0	1.3	ppm
079-42A Outside Water Spigot 7	6/19/2016 4:58	6/24/2016 14:29	606210042	Lead	81	15	ppb
079-43A Outside Water Spigot 8	6/19/2016 4:50	6/24/2016 14:29	606210043	Copper	0.0	1.3	ppm
079-43A Outside Water Spigot 8	6/19/2016 4:50	6/24/2016 14:29	606210043	Lead	5	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance action levels.