

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Sitton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
082-OUT-01A Water Spigot 1 Outside Boilerroom	6/16/2016 9:10	6/23/2016 14:47	606171601	Copper	0.0	1.3	ppm
082-OUT-01A Water Spigot 1 Outside Boilerroom	6/16/2016 9:10	6/23/2016 14:47	606171601	Lead	10	15	ppb
082-MB-02A Maintenance Bathroom Sink Faucet	6/16/2016 9:36	6/23/2016 14:47	606171602	Copper	0.0	1.3	ppm
082-MB-02A Maintenance Bathroom Sink Faucet	6/16/2016 9:36	6/23/2016 14:47	606171602	Lead	1	15	ppb
082-OUT-03A Outside Cafeteria W Water Spigot 2	6/16/2016 9:12	6/23/2016 14:48	606171603	Copper	0.0	1.3	ppm
082-OUT-03A Outside Cafeteria W Water Spigot 2	6/16/2016 9:12	6/23/2016 14:48	606171603	Lead	8	15	ppb
082-BS-04A Boys Shower Sink Faucet	6/16/2016 9:47	6/23/2016 14:48	606171604	Copper	0.0	1.3	ppm
082-BS-04A Boys Shower Sink Faucet	6/16/2016 9:47	6/23/2016 14:48	606171604	Lead	13	15	ppb
082-DF-05A Cafeteria Drinking Fountain	6/16/2016 9:41	6/23/2016 14:48	606171605	Copper	0.0	1.3	ppm
082-DF-05A Cafeteria Drinking Fountain	6/16/2016 9:41	6/23/2016 14:48	606171605	Lead	1	15	ppb
082-KS-06A Kitchen Sink not Food Prep	6/16/2016 9:49	6/23/2016 14:49	606171606	Copper	0.0	1.3	ppm
082-KS-06A Kitchen Sink not Food Prep	6/16/2016 9:49	6/23/2016 14:49	606171606	Lead	2	15	ppb
082-KS-07A Kitchen Sink Food Prep	6/16/2016 9:51	6/23/2016 14:49	606171607	Copper	0.0	1.3	ppm
082-KS-07A Kitchen Sink Food Prep	6/16/2016 9:51	6/23/2016 14:49	606171607	Lead	3	15	ppb
082-KS-08A Kitchen Sink Food Prep Sprayer	6/16/2016 9:52	6/23/2016 14:49	606171608	Copper	0.0	1.3	ppm
082-KS-08A Kitchen Sink Food Prep Sprayer	6/16/2016 9:52	6/23/2016 14:49	606171608	Lead	3	15	ppb
082-KS-09A Kitchen Sink Food Prep Faucet	6/16/2016 9:53	6/23/2016 14:49	606171609	Copper	0.0	1.3	ppm
082-KS-09A Kitchen Sink Food Prep Faucet	6/16/2016 9:53	6/23/2016 14:49	606171609	Lead	1	15	ppb
082-JC-10A Janitors Closet in Kitchen Sink	6/16/2016 10:02	6/23/2016 14:49	606171610	Copper	0.0	1.3	ppm
082-JC-10A Janitors Closet in Kitchen Sink	6/16/2016 10:02	6/23/2016 14:49	606171610	Lead	8	15	ppb
082-BF-11A Bathroom Faucet inside Cafeteria Bathroom	6/16/2016 9:52	6/23/2016 14:49	606171611	Copper	0.0	1.3	ppm
082-BF-11A Bathroom Faucet inside Cafeteria Bathroom	6/16/2016 9:52	6/23/2016 14:49	606171611	Lead	2	15	ppb
082-BS-12A Boys Shower Water Spigot under Sink	6/16/2016 9:49	6/23/2016 14:49	606171612	Copper	0.0	1.3	ppm
082-BS-12A Boys Shower Water Spigot under Sink	6/16/2016 9:49	6/23/2016 14:49	606171612	Lead	16	15	ppb
082-GS-13A Girls Shower Water Spigot	6/16/2016 10:12	6/23/2016 10:57	606171613	Copper	0.0	1.3	ppm
082-GS-13A Girls Shower Water Spigot	6/16/2016 10:12	6/23/2016 10:57	606171613	Lead	106	15	ppb
082-OUT-14A Outside Water Spigot	6/16/2016 11:10	6/23/2016 14:54	606171614	Copper	0.0	1.3	ppm
082-OUT-14A Outside Water Spigot	6/16/2016 11:10	6/23/2016 14:54	606171614	Lead	2	15	ppb
082-CB-15A Bathroom outside Cafeteria Sink Faucet	6/16/2016 9:18	6/23/2016 14:54	606171615	Copper	0.0	1.3	ppm
082-CB-15A Bathroom outside Cafeteria Sink Faucet	6/16/2016 9:18	6/23/2016 14:54	606171615	Lead	3	15	ppb
082-CB-16A Bathroom outside Cafeteria Spigot under Sink	6/16/2016 9:20	6/23/2016 14:54	606171616	Lead	101	15	ppb
082-CB-17A Cafeteria Bathroom Sink Faucet	6/16/2016 9:26	6/23/2016 14:55	606171617	Copper	0.0	1.3	ppm
082-CB-17A Cafeteria Bathroom Sink Faucet	6/16/2016 9:26	6/23/2016 14:55	606171617	Lead	3	15	ppb
082-CB-18A Cafeteria Bathroom Spigot under Sink	6/16/2016 9:28	6/23/2016 14:55	606171618	Copper	0.0	1.3	ppm
082-CB-18A Cafeteria Bathroom Spigot under Sink	6/16/2016 9:28	6/23/2016 14:55	606171618	Lead	8	15	ppb
082-C03-19A Custodial NO3 Sink Faucet	6/16/2016 9:27	6/23/2016 14:55	606171619	Copper	0.0	1.3	ppm
082-C03-19A Custodial NO3 Sink Faucet	6/16/2016 9:27	6/23/2016 14:55	606171619	Lead	4	15	ppb
082-Library-20A Library Office Sink Faucet 29D	6/16/2016 10:01	6/23/2016 14:55	606171620	Copper	0.0	1.3	ppm
082-Library-20A Library Office Sink Faucet 29D	6/16/2016 10:01	6/23/2016 14:55	606171620	Lead	17	15	ppb
082-7A-21A Mechanical Room Bathroom Sink	6/16/2016 9:40	6/23/2016 14:55	606171621	Copper	0.0	1.3	ppm
082-7A-21A Mechanical Room Bathroom Sink	6/16/2016 9:40	6/23/2016 14:55	606171621	Lead	6	15	ppb
082-7A-22A Mechanical Room Shower	6/16/2016 9:41	6/23/2016 14:55	606171622	Copper	0.0	1.3	ppm
082-7A-22A Mechanical Room Shower	6/16/2016 9:41	6/23/2016 14:55	606171622	Lead	9	15	ppb
082-HALL-23A Drinking Fountain Outside Library	6/16/2016 10:10	6/23/2016 14:55	606171623	Copper	0.0	1.3	ppm
082-HALL-23A Drinking Fountain Outside Library	6/16/2016 10:10	6/23/2016 14:55	606171623	Lead	1	15	ppb
082-1-24A Classroom 1 Sink Faucet	6/16/2016 10:20	6/23/2016 14:57	606171624	Copper	0.1	1.3	ppm
082-1-24A Classroom 1 Sink Faucet	6/16/2016 10:20	6/23/2016 14:57	606171624	Lead	8	15	ppb
082-OUT-26A Water Spigot outside Classroom 9	6/16/2016 10:27	6/23/2016 14:57	606171625	Copper	0.1	1.3	ppm
082-OUT-26A Water Spigot outside Classroom 9	6/16/2016 10:27	6/23/2016 14:57	606171625	Lead	16	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Sitton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
082-9-27A Classroom 9 Drinking Fountain	6/16/2016 10:26	6/23/2016 14:57	606171626	Copper	0.1	1.3	ppm
082-9-27A Classroom 9 Drinking Fountain	6/16/2016 10:26	6/23/2016 14:57	606171626	Lead	3	15	ppb
082-9-28A Classroom 9 Sink Faucet	6/16/2016 10:28	6/23/2016 14:57	606171627	Copper	0.1	1.3	ppm
082-9-28A Classroom 9 Sink Faucet	6/16/2016 10:28	6/23/2016 14:57	606171627	Lead	3	15	ppb
082-8-29A Classroom 8 Drinking Fountain	6/16/2016 10:35	6/23/2016 14:57	606171628	Copper	0.1	1.3	ppm
<b>082-8-29A Classroom 8 Drinking Fountain</b>	<b>6/16/2016 10:35</b>	<b>6/23/2016 14:57</b>	<b>606171628</b>	<b>Lead</b>	<b>29</b>	<b>15</b>	<b>ppb</b>
082-8-30A Classroom 8 Sink Faucet	6/16/2016 10:37	6/23/2016 14:57	606171629	Copper	0.1	1.3	ppm
082-8-30A Classroom 8 Sink Faucet	6/16/2016 10:37	6/23/2016 14:57	606171629	Lead	4	15	ppb
082-OUT-31A Water Spigot outside Classroom 8	6/16/2016 11:20	6/23/2016 14:57	606171630	Copper	0.1	1.3	ppm
082-OUT-31A Water Spigot outside Classroom 8	6/16/2016 11:20	6/23/2016 14:57	606171630	Lead	9	15	ppb
082-2-32A Classroom 2 Sink Faucet	6/16/2016 10:25	6/23/2016 14:57	606171631	Copper	0.1	1.3	ppm
082-2-32A Classroom 2 Sink Faucet	6/16/2016 10:25	6/23/2016 14:57	606171631	Lead	10	15	ppb
082-2-33A Classroom 2 Drinking Fountain	6/16/2016 10:27	6/23/2016 14:57	606171632	Copper	0.1	1.3	ppm
082-2-33A Classroom 2 Drinking Fountain	6/16/2016 10:27	6/23/2016 14:57	606171632	Lead	5	15	ppb
082-2A-34A Bathroom 2A Sink Faucet	6/16/2016 10:33	6/23/2016 14:58	606171633	Copper	0.1	1.3	ppm
082-2A-35A Bathroom 2A Spgit under Sink	6/16/2016 10:35	6/23/2016 15:02	606171634	Copper	0.1	1.3	ppm
<b>082-2A-35A Bathroom 2A Spigot under Sink</b>	<b>6/16/2016 10:35</b>	<b>6/23/2016 15:02</b>	<b>606171634</b>	<b>Lead</b>	<b>77</b>	<b>15</b>	<b>ppb</b>
082-2A-36A Bathroom 2A Sink Faucet	6/16/2016 10:37	6/23/2016 15:02	606171635	Copper	0.1	1.3	ppm
<b>082-2A-36A Bathroom 2A Sink Faucet</b>	<b>6/16/2016 10:37</b>	<b>6/23/2016 15:02</b>	<b>606171635</b>	<b>Lead</b>	<b>21</b>	<b>15</b>	<b>ppb</b>
082-8A-37A Bathroom 8A Sink Faucet	6/16/2016 10:40	6/23/2016 15:02	606171636	Copper	0.1	1.3	ppm
082-8A-37A Bathroom 8A Sink Faucet	6/16/2016 10:40	6/23/2016 15:02	606171636	Lead	4	15	ppb
082-8A-38A Bathroom 8A Spigot under Sink	6/16/2016 10:42	6/23/2016 10:57	606171637	Copper	0.1	1.3	ppm
082-8A-39A Bathroom 8A Sink Faucet	6/16/2016 10:44	6/23/2016 15:02	606171638	Copper	0.1	1.3	ppm
082-8A-39A Bathroom 8A Sink Faucet	6/16/2016 10:44	6/23/2016 15:02	606171638	Lead	6	15	ppb
082-2B-40A Resource Center 2B Sink Faucet	6/16/2016 10:46	6/23/2016 15:02	606171639	Copper	0.1	1.3	ppm
082-2B-40A Resource Center 2B Sink Faucet	6/16/2016 10:46	6/23/2016 15:02	606171639	Lead	7	15	ppb
082-8B-41A 8B Sink Faucet	6/16/2016 10:48	6/23/2016 15:02	606171640	Copper	0.1	1.3	ppm
082-8B-41A 8B Sink Faucet	6/16/2016 10:48	6/23/2016 15:02	606171640	Lead	6	15	ppb
082-2C-42A 2C Faculty Women Sink Faucet	6/16/2016 10:50	6/23/2016 15:02	606171641	Copper	0.1	1.3	ppm
082-2C-42A 2C Faculty Women Sink Faucet	6/16/2016 10:50	6/23/2016 15:02	606171641	Lead	7	15	ppb
082-C01-43A Custodial Room N01 Sink Faucet	6/16/2016 10:53	6/23/2016 15:02	606171642	Copper	0.1	1.3	ppm
082-C01-43A Custodial Room N01 Sink Faucet	6/16/2016 10:53	6/23/2016 15:02	606171642	Lead	3	15	ppb
082-7-44A Classroom 7 Sink Faucet	6/16/2016 10:55	6/23/2016 15:02	606171643	Copper	0.1	1.3	ppm
<b>082-7-44A Classroom 7 Sink Faucet</b>	<b>6/16/2016 10:55</b>	<b>6/23/2016 15:02</b>	<b>606171643</b>	<b>Lead</b>	<b>20</b>	<b>15</b>	<b>ppb</b>
082-7-45A Classroom 7 Drinking Fountain	6/16/2016 10:57	6/23/2016 15:02	606171644	Copper	0.1	1.3	ppm
082-7-45A Classroom 7 Drinking Fountain	6/16/2016 10:57	6/23/2016 15:02	606171644	Lead	9	15	ppb
082-GYM-46A Gym Drinking Fountain	6/16/2016 9:56	6/23/2016 15:07	606171645	Copper	0.1	1.3	ppm
082-GYM-46A Gym Drinking Fountain	6/16/2016 9:56	6/23/2016 15:07	606171645	Lead	1	15	ppb
082-19-47A Classroom 19 Sink Faucet	6/16/2016 9:31	6/23/2016 15:07	606171646	Copper	0.1	1.3	ppm
082-19-47A Classroom 19 Sink Faucet	6/16/2016 9:31	6/23/2016 15:07	606171646	Lead	9	15	ppb
082-19-48A Classroom 19 Drinking Fountain	6/16/2016 9:33	6/23/2016 15:07	606171647	Copper	0.1	1.3	ppm
082-19-48A Classroom 19 Drinking Fountain	6/16/2016 9:33	6/23/2016 15:07	606171647	Lead	11	15	ppb
082-PLAY-49A Covered Play Area Water Spigot	6/16/2016 11:01	6/23/2016 15:07	606171648	Copper	0.1	1.3	ppm
<b>082-PLAY-49A Covered Play Area Water Spigot</b>	<b>6/16/2016 11:01</b>	<b>6/23/2016 15:07</b>	<b>606171648</b>	<b>Lead</b>	<b>34</b>	<b>15</b>	<b>ppb</b>
082-18-50A Classroom 18 Sink Faucet	6/16/2016 11:10	6/23/2016 15:07	606171649	Copper	0.1	1.3	ppm
082-18-50A Classroom 18 Sink Faucet	6/16/2016 11:10	6/23/2016 15:07	606171649	Lead	9	15	ppb
082-18-51A Classroom 18 Drinking Fountain	6/16/2016 11:12	6/23/2016 15:07	606171650	Copper	0.1	1.3	ppm
082-18-51A Classroom 18 Drinking Fountain	6/16/2016 11:12	6/23/2016 15:07	606171650	Lead	2	15	ppb
082-17B-52A Boys Bathroom 17B Sink Faucet	6/16/2016 11:14	6/23/2016 15:07	606171651	Copper	0.1	1.3	ppm

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Sitton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
082-17B-52A Boys Bathroom 17B Sink Faucet	6/16/2016 11:14	6/23/2016 15:07	606171651	Lead	26	15	ppb
082-17B-53A Boys Bathroom 17B Water Spigot	6/16/2016 11:16	6/23/2016 15:07	606171652	Copper	0.2	1.3	ppm
082-17B-53A Boys Bathroom 17B Water Spigot	6/16/2016 11:16	6/23/2016 15:07	606171652	Lead	237	15	ppb
082-17-54A Classroom 17 Sink Faucet	6/16/2016 11:20	6/23/2016 15:07	606171653	Copper	0.2	1.3	ppm
082-17-54A Classroom 17 Sink Faucet	6/16/2016 11:20	6/23/2016 15:07	606171653	Lead	9	15	ppb
082-17-55A Classroom 17 Drinking Fountain	6/16/2016 11:22	6/23/2016 15:07	606171654	Copper	0.2	1.3	ppm
082-17-55A Classroom 17 Drinking Fountain	6/16/2016 11:22	6/23/2016 15:07	606171654	Lead	3	15	ppb
082-HALL-56A Fountain outside 17A Left Side	6/16/2016 11:47	6/23/2016 15:09	606171655	Copper	0.3	1.3	ppm
082-HALL-56A Fountain outside 17A Left Side	6/16/2016 11:47	6/23/2016 15:09	606171655	Lead	2	15	ppb
082-HALL-57A Fountain outside 17A Right Side	6/16/2016 11:49	6/23/2016 15:09	606171656	Copper	0.4	1.3	ppm
082-HALL-57A Fountain outside 17A Right Side	6/16/2016 11:49	6/23/2016 15:09	606171656	Lead	1	15	ppb
082-17A-58A Girls Bathroom 17A Sink Faucet	6/16/2016 11:51	6/23/2016 15:09	606171657	Copper	0.0	1.3	ppm
082-17A-58A Girls Bathroom 17A Sink Faucet	6/16/2016 11:51	6/23/2016 15:09	606171657	Lead	6	15	ppb
082-17A-59A Girls Bathroom 17A Sink Faucet	6/16/2016 11:53	6/23/2016 15:09	606171658	Copper	0.0	1.3	ppm
082-17A-59A Girls Bathroom 17A Sink Faucet	6/16/2016 11:53	6/23/2016 15:09	606171658	Lead	11	15	ppb
082-17A-60A Girls Bathroom 17A Water Spigot	6/16/2016 11:55	6/23/2016 15:09	606171659	Copper	0.0	1.3	ppm
082-17A-60A Girls Bathroom 17A Water Spigot	6/16/2016 11:55	6/23/2016 15:09	606171659	Lead	86	15	ppb
082-22-61A Music Room 22 Sink Faucet	6/16/2016 11:58	6/23/2016 15:09	606171660	Copper	0.0	1.3	ppm
082-22-61A Music Room 22 Sink Faucet	6/16/2016 11:58	6/23/2016 15:09	606171660	Lead	28	15	ppb
082-21-62A Classroom 21 Sink Faucet 1	6/16/2016 12:00	6/23/2016 15:09	606171661	Copper	0.0	1.3	ppm
082-21-62A Classroom 21 Sink Faucet 1	6/16/2016 12:00	6/23/2016 15:09	606171661	Lead	26	15	ppb
082-21-63A Classroom 21 Sink Faucet 2	6/16/2016 12:02	6/23/2016 15:09	606171662	Copper	0.0	1.3	ppm
082-21-63A Classroom 21 Sink Faucet 2	6/16/2016 12:02	6/23/2016 15:09	606171662	Lead	26	15	ppb
082-21-64A Classroom 21 Sink Faucet 3	6/16/2016 12:04	6/23/2016 15:09	606171663	Copper	0.0	1.3	ppm
082-21-64A Classroom 21 Sink Faucet 3	6/16/2016 12:04	6/23/2016 15:09	606171663	Lead	18	15	ppb
082-16-65A Classroom 16 Sink Faucet	6/16/2016 11:58	6/23/2016 15:09	606171664	Copper	0.0	1.3	ppm
082-16-65A Classroom 16 Sink Faucet	6/16/2016 11:58	6/23/2016 15:09	606171664	Lead	16	15	ppb
082-16-66A Classroom 16 Drinking Fountain	6/16/2016 11:56	6/23/2016 15:10	606171665	Copper	0.0	1.3	ppm
082-16-66A Classroom 16 Drinking Fountain	6/16/2016 11:56	6/23/2016 15:10	606171665	Lead	7	15	ppb
082-OUT-67A Water Spigot outside Classroom 16	6/16/2016 12:01	6/23/2016 15:10	606171666	Copper	0.0	1.3	ppm
082-OUT-67A Water Spigot outside Classroom 16	6/16/2016 12:01	6/23/2016 15:10	606171666	Lead	8	15	ppb
082-OUT-68A Water Spigot outside Classroom 14	6/16/2016 12:03	6/23/2016 15:10	606171667	Copper	0.0	1.3	ppm
082-OUT-68A Water Spigot outside Classroom 14	6/16/2016 12:03	6/23/2016 15:10	606171667	Lead	48	15	ppb
082-15-69A Classroom 15 Sink Faucet	6/16/2016 11:59	6/23/2016 15:10	606171668	Copper	0.0	1.3	ppm
082-15-69A Classroom 15 Sink Faucet	6/16/2016 11:59	6/23/2016 15:10	606171668	Lead	7	15	ppb
082-15-70A Classroom 15 Drinking Fountain	6/16/2016 12:05	6/23/2016 15:10	606171669	Copper	0.0	1.3	ppm
082-15-70A Classroom 15 Drinking Fountain	6/16/2016 12:05	6/23/2016 15:10	606171669	Lead	13	15	ppb
082-14-71A Classroom 14 Sink Faucet	6/16/2016 12:07	6/23/2016 15:10	606171670	Copper	0.0	1.3	ppm
082-14-71A Classroom 14 Sink Faucet	6/16/2016 12:07	6/23/2016 15:10	606171670	Lead	10	15	ppb
082-14-72A Classroom 14 Drinking Fountain	6/16/2016 12:09	6/23/2016 15:10	606171671	Copper	0.0	1.3	ppm
082-14-72A Classroom 14 Drinking Fountain	6/16/2016 12:09	6/23/2016 15:10	606171671	Lead	3	15	ppb
082-13-73A Classroom 13 Sink Faucet	6/16/2016 13:10	6/23/2016 15:10	606171672	Copper	0.0	1.3	ppm
082-13-73A Classroom 13 Sink Faucet	6/16/2016 13:10	6/23/2016 15:10	606171672	Lead	8	15	ppb
082-13-74A Classroom 13 Drinking Fountain	6/16/2016 13:12	6/23/2016 15:10	606171673	Copper	0.0	1.3	ppm
082-13-74A Classroom 13 Drinking Fountain	6/16/2016 13:12	6/23/2016 15:10	606171673	Lead	15.3	15	ppb
082-13A-75A Bathroom 13A Sink Faucet	6/16/2016 13:14	6/23/2016 15:10	606171674	Copper	0.0	1.3	ppm
082-13A-75A Bathroom 13A Sink Faucet	6/16/2016 13:14	6/23/2016 15:10	606171674	Lead	7	15	ppb
082-12B-76A Bathroom 12B Sink Faucet	6/16/2016 12:24	6/23/2016 15:11	606171675	Copper	0.0	1.3	ppm
082-12B-76A Bathroom 12B Sink Faucet	6/16/2016 12:24	6/23/2016 15:11	606171675	Lead	5	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Sitton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
082-12-77A Classroom 12 Sink Faucet	6/16/2016 12:26	6/23/2016 15:12	606171676	Copper	0.0	1.3	ppm
<b>082-12-77A Classroom 12 Sink Faucet</b>	<b>6/16/2016 12:26</b>	<b>6/23/2016 15:12</b>	<b>606171676</b>	<b>Lead</b>	<b>16</b>	<b>15</b>	<b>ppb</b>
082-12-78A Classroom 12 Drinking Fountain	6/16/2016 12:28	6/23/2016 15:12	606171677	Copper	0.0	1.3	ppm
082-12-78A Classroom 12 Drinking Fountain	6/16/2016 12:28	6/23/2016 15:12	606171677	Lead	8	15	ppb
082-11-79A Classroom 11 Sink Faucet	6/16/2016 12:30	6/23/2016 15:12	606171678	Copper	0.0	1.3	ppm
<b>082-11-79A Classroom 11 Sink Faucet</b>	<b>6/16/2016 12:30</b>	<b>6/23/2016 15:12</b>	<b>606171678</b>	<b>Lead</b>	<b>18</b>	<b>15</b>	<b>ppb</b>
082-11-80A Classroom 11 Drinking Fountain	6/16/2016 12:32	6/23/2016 15:12	606171679	Copper	0.0	1.3	ppm
082-11-80A Classroom 11 Drinking Fountain	6/16/2016 12:32	6/23/2016 15:12	606171679	Lead	1	15	ppb
082-6-81A Classroom 6 Drinking Fountain	6/16/2016 11:39	6/23/2016 15:12	606171680	Copper	0.0	1.3	ppm
082-6-81A Classroom 6 Drinking Fountain	6/16/2016 11:39	6/23/2016 15:12	606171680	Lead	11	15	ppb
082-6-82A Classroom 6 Sink Faucet	6/16/2016 11:41	6/23/2016 15:12	606171681	Copper	0.0	1.3	ppm
082-6-82A Classroom 6 Sink Faucet	6/16/2016 11:41	6/23/2016 15:12	606171681	Lead	6	15	ppb
082-OUT-83A Water Spigot outside Classroom 6	6/16/2016 12:34	6/23/2016 15:12	606171682	Copper	0.0	1.3	ppm
<b>082-OUT-83A Water Spigot outside Classroom 6</b>	<b>6/16/2016 12:34</b>	<b>6/23/2016 15:12</b>	<b>606171682</b>	<b>Lead</b>	<b>27</b>	<b>15</b>	<b>ppb</b>
082-3-84A Classroom 3 Sink Faucet	6/16/2016 11:14	6/23/2016 15:12	606171683	Copper	0.0	1.3	ppm
082-3-84A Classroom 3 Sink Faucet	6/16/2016 11:14	6/23/2016 15:12	606171683	Lead	4	15	ppb
082-3-85A Classroom 3 Drinking Fountain	6/16/2016 11:16	6/23/2016 15:12	606171684	Copper	ND	1.3	ppm
082-3-85A Classroom 3 Drinking Fountain	6/16/2016 11:16	6/23/2016 15:12	606171684	Lead	7	15	ppb
082-3A-86A Boys Bathroom 3A Sink Faucet	6/16/2016 11:18	6/23/2016 15:13	606171685	Copper	0.0	1.3	ppm
082-3A-86A Boys Bathroom 3A Sink Faucet	6/16/2016 11:18	6/23/2016 15:13	606171685	Lead	3	15	ppb
082-3A-87A Boys Bathroom 3A Sink Faucet	6/16/2016 11:20	6/23/2016 15:13	606171686	Copper	0.0	1.3	ppm
082-3A-87A Boys Bathroom 3A Sink Faucet	6/16/2016 11:20	6/23/2016 15:13	606171686	Lead	2	15	ppb
082-3A-88A Boys Bathroom 3A Water Spigot	6/16/2016 11:22	6/23/2016 15:13	606171687	Copper	0.0	1.3	ppm
082-3A-88A Boys Bathroom 3A Water Spigot	6/16/2016 11:22	6/23/2016 15:13	606171687	Lead	1	15	ppb
082-6A-89A Girls Bathroom 6A Sink Faucet	6/16/2016 11:27	6/23/2016 15:13	606171688	Copper	0.0	1.3	ppm
082-6A-89A Girls Bathroom 6A Sink Faucet	6/16/2016 11:27	6/23/2016 15:13	606171688	Lead	3	15	ppb
082-6A-90A Girls Bathroom 6A Spigot	6/16/2016 11:29	6/23/2016 10:58	606171689	Copper	0.0	1.3	ppm
<b>082-6A-90A Girls Bathroom 6A Spigot</b>	<b>6/16/2016 11:29</b>	<b>6/23/2016 10:58</b>	<b>606171689</b>	<b>Lead</b>	<b>230</b>	<b>15</b>	<b>ppb</b>
082-6A-91A Girls Bathroom 6A Sink Faucet	6/16/2016 11:31	6/23/2016 15:13	606171690	Copper	0.0	1.3	ppm
082-6A-91A Girls Bathroom 6A Sink Faucet	6/16/2016 11:31	6/23/2016 15:13	606171690	Lead	4	15	ppb
082-5-92A Classroom 5 Sink Faucet	6/16/2016 11:33	6/23/2016 15:13	606171691	Copper	0.0	1.3	ppm
082-5-92A Classroom 5 Sink Faucet	6/16/2016 11:33	6/23/2016 15:13	606171691	Lead	7	15	ppb
082-5-93A Classroom 5 Drinking Fountain	6/16/2016 11:35	6/23/2016 15:13	606171692	Copper	0.0	1.3	ppm
082-5-93A Classroom 5 Drinking Fountain	6/16/2016 11:35	6/23/2016 15:13	606171692	Lead	2	15	ppb
082-4-94A Classroom 4 Drinking Fountain	6/16/2016 11:21	6/23/2016 15:13	606171693	Copper	0.0	1.3	ppm
082-4-94A Classroom 4 Drinking Fountain	6/16/2016 11:21	6/23/2016 15:13	606171693	Lead	14	15	ppb
082-4-95A Classroom 4 Sink Faucet	6/16/2016 11:23	6/23/2016 15:13	606171694	Copper	0.0	1.3	ppm
082-4-95A Classroom 4 Sink Faucet	6/16/2016 11:23	6/23/2016 15:13	606171694	Lead	6	15	ppb
082-COURT-96A Courtyard Water Spigot	6/16/2016 13:11	6/23/2016 15:14	606171695	Copper	0.0	1.3	ppm
082-COURT-96A Courtyard Water Spigot	6/16/2016 13:11	6/23/2016 15:14	606171695	Lead	0	15	ppb
082-Office-97A Office Bathroom Sink Faucet	6/16/2016 13:13	6/23/2016 15:16	606171696	Copper	0.0	1.3	ppm
082-Office-97A Office Bathroom Sink Faucet	6/16/2016 13:13	6/23/2016 15:16	606171696	Lead	7	15	ppb
082-11B-98A Boys Bathroom 11B Sink Faucet	6/16/2016 12:44	6/23/2016 15:16	606171697	Copper	0.0	1.3	ppm
082-11B-98A Boys Bathroom 11B Sink Faucet	6/16/2016 12:44	6/23/2016 15:16	606171697	Lead	9	15	ppb
082-11B-99A Boys Bathroom 11B Sink Faucet	6/16/2016 12:46	6/23/2016 15:16	606171698	Copper	0.0	1.3	ppm
082-11B-99A Boys Bathroom 11B Sink Faucet	6/16/2016 12:46	6/23/2016 15:16	606171698	Lead	11	15	ppb
082-11B-100A Boys Bathroom 11B Water Spigot	6/16/2016 12:48	6/23/2016 15:16	606171699	Copper	0.0	1.3	ppm
082-11B-100A Boys Bathroom 11B Water Spigot	6/16/2016 12:48	6/23/2016 15:16	606171699	Lead	8	15	ppb
082-4C-101A Room 4C Sink Faucet	6/16/2016 12:50	6/23/2016 15:16	6061716100	Copper	0.0	1.3	ppm

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Sitton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
082-4C-101A Room 4C Sink Faucet	6/16/2016 12:50	6/23/2016 15:16	6061716100	Lead	1	15	ppb
082-HALL-102A Drinking Fountain outside 11B	6/16/2016 12:52	6/23/2016 15:16	6061716101	Copper	0.0	1.3	ppm
082-HALL-102A Drinking Fountain outside 11B	6/16/2016 12:52	6/23/2016 15:16	6061716101	Lead	ND	15	ppb
082-C02-103A Custodial N02 Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716102	Copper	0.0	1.3	ppm
082-C02-103A Custodial N02 Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716102	Lead	6	15	ppb
082-11E-105A Girls Bathroom 11E Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716103	Copper	0.0	1.3	ppm
082-11E-105A Girls Bathroom 11E Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716103	Lead	1	15	ppb
082-11E-106A Girls Bathroom 11E Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716104	Copper	0.0	1.3	ppm
082-11E-106A Girls Bathroom 11E Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716104	Lead	1	15	ppb
082-10-107A Classroom 10 Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716105	Copper	0.0	1.3	ppm
082-10-107A Classroom 10 Sink Faucet	6/16/2016 0:01	6/23/2016 15:17	6061716105	Lead	3	15	ppb
082-10-108A Classroom 10 Drinking Fountain	6/16/2016 0:01	6/23/2016 15:18	6061716106	Copper	0.0	1.3	ppm
082-10-108A Classroom 10 Drinking Fountain	6/16/2016 0:01	6/23/2016 15:18	6061716106	Lead	4	15	ppb
082-LC1-109A Annex Classroom LC1 Bath Sink	6/16/2016 13:05	6/23/2016 15:18	6061716107	Copper	0.0	1.3	ppm
082-LC1-109A Annex Classroom LC1 Bath Sink	6/16/2016 13:05	6/23/2016 15:18	6061716107	Lead	1	15	ppb
082-LC2-110A Annex Classroom LC2 Bath Sink	6/16/2016 13:07	6/23/2016 15:18	6061716108	Copper	0.0	1.3	ppm
082-LC2-110A Annex Classroom LC2 Bath Sink	6/16/2016 13:07	6/23/2016 15:18	6061716108	Lead	0	15	ppb
082-OUT-111A outside Entrance Water Spigot	6/16/2016 13:09	6/23/2016 15:18	6061716109	Copper	0.0	1.3	ppm
<b>082-OUT-111A outside Entrance Water Spigot</b>	<b>6/16/2016 13:09</b>	<b>6/23/2016 15:18</b>	<b>6061716109</b>	<b>Lead</b>	<b>213</b>	<b>15</b>	<b>ppb</b>
082-DF-112A Hall by Custodial 1 Drinking Fountain	6/16/2016 13:15	6/23/2016 15:18	6061716110	Copper	0.0	1.3	ppm
082-DF-112A Hall by Custodial 1 Drinking Fountain	6/16/2016 13:15	6/23/2016 15:18	6061716110	Lead	11	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect