

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-01A Water Spigot Boiler Room - Incinerator	7/3/16 17:21	08-Jul-16	38083	Copper	ND	1.3	ppm
037-01A Water Spigot Boiler Room - Incinerator	7/3/16 17:21	08-Jul-16	38083	Lead	4	15	ppb
037-02A Water Spigot Boiler Room - Incinerator	7/3/16 17:22	14-Jul-16	38084	Copper	0.2	1.3	ppm
037-02A Water Spigot Boiler Room - Incinerator	7/3/16 17:22	14-Jul-16	38084	Lead	2017	15	ppb
037-03A A14 Custodial Lockers - Shower	7/3/16 17:24	08-Jul-16	38085	Copper	ND	1.3	ppm
037-03A A14 Custodial Lockers - Shower	7/3/16 17:24	08-Jul-16	38085	Lead	23	15	ppb
037-04A A14 Custodial Lockers - Handwash	7/3/16 17:27	08-Jul-16	38086	Copper	ND	1.3	ppm
037-04A A14 Custodial Lockers - Handwash	7/3/16 17:27	08-Jul-16	38086	Lead	11	15	ppb
037-05A A12 Custodial Room Sink Faucet	7/3/16 17:29	08-Jul-16	38087	Copper	ND	1.3	ppm
037-05A A12 Custodial Room Sink Faucet	7/3/16 17:29	08-Jul-16	38087	Lead	12	15	ppb
037-06A A13 Room Sink Faucet	7/3/16 17:31	14-Jul-16	38088	Copper	10.7	1.3	ppm
037-06A A13 Room Sink Faucet	7/3/16 17:31	14-Jul-16	38088	Lead	4022	15	ppb
037-07A A10 Room Sink Faucet #1	7/3/16 17:38	08-Jul-16	38089	Copper	ND	1.3	ppm
037-07A A10 Room Sink Faucet #1	7/3/16 17:38	08-Jul-16	38089	Lead	1	15	ppb
037-08A A10 Room Sink Faucet #2	7/3/16 17:38	08-Jul-16	38090	Copper	ND	1.3	ppm
037-08A A10 Room Sink Faucet #2	7/3/16 17:38	08-Jul-16	38090	Lead	3	15	ppb
037-09A A10 Room Sink Faucet #3	7/3/16 17:39	08-Jul-16	38091	Copper	ND	1.3	ppm
037-09A A10 Room Sink Faucet #3	7/3/16 17:39	08-Jul-16	38091	Lead	6	15	ppb
037-10A A10 Room Sink Faucet #4	7/3/16 17:41	08-Jul-16	38092	Copper	ND	1.3	ppm
037-10A A10 Room Sink Faucet #4	7/3/16 17:41	08-Jul-16	38092	Lead	ND	15	ppb
037-11A A10 Room Sink Faucet #5	7/3/16 17:42	08-Jul-16	38093	Copper	0.1	1.3	ppm
037-11A A10 Room Sink Faucet #5	7/3/16 17:42	08-Jul-16	38093	Lead	1	15	ppb
037-12A A9 Room Sink Faucet	7/3/16 17:44	08-Jul-16	38094	Copper	ND	1.3	ppm
037-12A A9 Room Sink Faucet	7/3/16 17:44	08-Jul-16	38094	Lead	14	15	ppb
037-13A A5B Room Sink Faucet	7/3/16 17:46	08-Jul-16	38095	Copper	ND	1.3	ppm
037-13A A5B Room Sink Faucet	7/3/16 17:46	08-Jul-16	38095	Lead	46	15	ppb
037-14A A5 Room Sink Faucet	7/3/16 17:47	08-Jul-16	38096	Copper	ND	1.3	ppm
037-14A A5 Room Sink Faucet	7/3/16 17:47	08-Jul-16	38096	Lead	13	15	ppb
037-15A A4A Room Sink Faucet	7/3/16 17:49	08-Jul-16	38097	Copper	ND	1.3	ppm
037-15A A4A Room Sink Faucet	7/3/16 17:49	08-Jul-16	38097	Lead	43	15	ppb
037-16A A4 Room Sink Faucet	7/3/16 17:49	08-Jul-16	38098	Copper	ND	1.3	ppm
037-16A A4 Room Sink Faucet	7/3/16 17:49	08-Jul-16	38098	Lead	50	15	ppb
037-17A A3 Slop Sink Faucet	7/3/16 17:56	08-Jul-16	38099	Copper	ND	1.3	ppm
037-17A A3 Slop Sink Faucet	7/3/16 17:56	08-Jul-16	38099	Lead	58	15	ppb
037-18A A3 Water Spigot	7/3/16 17:57	14-Jul-16	38100	Copper	0.1	1.3	ppm
037-18A A3 Water Spigot	7/3/16 17:57	14-Jul-16	38100	Lead	254	15	ppb
037-19A A1 Room Sink Faucet	7/3/16 17:52	08-Jul-16	38101	Copper	0.1	1.3	ppm
037-19A A1 Room Sink Faucet	7/3/16 17:52	08-Jul-16	38101	Lead	74	15	ppb
037-20A A1A Small Room Sink Faucet	7/3/16 17:54	08-Jul-16	38102	Copper	ND	1.3	ppm
037-20A A1A Small Room Sink Faucet	7/3/16 17:54	08-Jul-16	38102	Lead	22	15	ppb
037-21A A15 Room Sink Faucet	7/3/16 18:11	08-Jul-16	38103	Copper	ND	1.3	ppm
037-21A A15 Room Sink Faucet	7/3/16 18:11	08-Jul-16	38103	Lead	13	15	ppb
037-22A A15 Room Shower	7/3/16 18:11	08-Jul-16	38104	Copper	ND	1.3	ppm
037-22A A15 Room Shower	7/3/16 18:11	08-Jul-16	38104	Lead	278	15	ppb
037-23A A16 Boys Bathroom Sink Faucet #1	7/3/16 18:13	08-Jul-16	38105	Copper	ND	1.3	ppm
037-23A A16 Boys Bathroom Sink Faucet #1	7/3/16 18:13	08-Jul-16	38105	Lead	14	15	ppb
037-24A A16 Boys Bathroom Sink Faucet #2	7/3/16 18:14	08-Jul-16	38106	Copper	ND	1.3	ppm
037-24A A16 Boys Bathroom Sink Faucet #2	7/3/16 18:14	08-Jul-16	38106	Lead	25	15	ppb
037-25A A16 Boys Bathroom Sink Faucet #3	7/3/16 18:15	08-Jul-16	38107	Copper	ND	1.3	ppm
037-25A A16 Boys Bathroom Sink Faucet #3	7/3/16 18:15	08-Jul-16	38107	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-26A A16 Boys Bathroom Water Spigot	7/3/16 18:16	14-Jul-16	38108	Copper	0.2	1.3	ppm
037-26A A16 Boys Bathroom Water Spigot	7/3/16 18:16	14-Jul-16	38108	Lead	26	15	ppb
037-27A A16 Boys Bathroom Water Spigot	7/3/16 18:17	08-Jul-16	38109	Copper	0.1	1.3	ppm
037-27A A16 Boys Bathroom Water Spigot	7/3/16 18:17	08-Jul-16	38109	Lead	30	15	ppb
037-28A A17 Men's Faculty Bathroom Sink Faucet	7/3/16 18:14	08-Jul-16	38110	Copper	ND	1.3	ppm
037-28A A17 Men's Faculty Bathroom Sink Faucet	7/3/16 18:14	08-Jul-16	38110	Lead	13	15	ppb
037-29A A19 Women's Faculty Bathroom Sink Faucet	7/3/16 18:16	08-Jul-16	38111	Copper	ND	1.3	ppm
037-29A A19 Women's Faculty Bathroom Sink Faucet	7/3/16 18:16	08-Jul-16	38111	Lead	25	15	ppb
037-30A A20 Custodial Slop Sink Faucet	7/3/16 18:18	08-Jul-16	38112	Copper	ND	1.3	ppm
037-30A A20 Custodial Slop Sink Faucet	7/3/16 18:18	08-Jul-16	38112	Lead	8	15	ppb
037-31A A20 Custodial Water Spigot	7/3/16 18:18	08-Jul-16	38113	Copper	0.2	1.3	ppm
037-31A A20 Custodial Water Spigot	7/3/16 18:18	08-Jul-16	38113	Lead	74	15	ppb
037-32A A21 Room Hand Wash	7/3/16 18:12	08-Jul-16	38114	Copper	0.1	1.3	ppm
037-32A A21 Room Hand Wash	7/3/16 18:12	08-Jul-16	38114	Lead	10	15	ppb
037-33A A21 Room Eye Wash	7/3/16 18:12	08-Jul-16	38115	Copper	ND	1.3	ppm
037-33A A21 Room Eye Wash	7/3/16 18:12	08-Jul-16	38115	Lead	5	15	ppb
037-34A Drinking Fountain On Corridor Left	7/3/16 18:12	08-Jul-16	38116	Copper	ND	1.3	ppm
037-34A Drinking Fountain On Corridor Left	7/3/16 18:12	08-Jul-16	38116	Lead	8	15	ppb
037-35A Drinking Fountain On Corridor Right	7/3/16 18:13	08-Jul-16	38117	Copper	ND	1.3	ppm
037-35A Drinking Fountain On Corridor Right	7/3/16 18:13	08-Jul-16	38117	Lead	10	15	ppb
037-36A A22 Room Hand Wash Station	7/3/16 18:16	08-Jul-16	38118	Copper	0.1	1.3	ppm
037-36A A22 Room Hand Wash Station	7/3/16 18:16	08-Jul-16	38118	Lead	13	15	ppb
037-37A A22 Room Eye Wash Hose	7/3/16 18:17	08-Jul-16	38119	Copper	ND	1.3	ppm
037-37A A22 Room Eye Wash Hose	7/3/16 18:17	08-Jul-16	38119	Lead	14	15	ppb
037-38A A22 Room Drinking Fountain	7/3/16 18:18	08-Jul-16	38120	Copper	ND	1.3	ppm
037-38A A22 Room Drinking Fountain	7/3/16 18:18	08-Jul-16	38120	Lead	17	15	ppb
037-39A A23 Girls Bathroom Sink Faucet #1	7/3/16 18:19	08-Jul-16	38121	Copper	ND	1.3	ppm
037-39A A23 Girls Bathroom Sink Faucet #1	7/3/16 18:19	08-Jul-16	38121	Lead	15.0	15	ppb
037-40A A23 Girls Bathroom Sink Faucet #2	7/3/16 18:24	08-Jul-16	38122	Copper	ND	1.3	ppm
037-40A A23 Girls Bathroom Sink Faucet #2	7/3/16 18:24	08-Jul-16	38122	Lead	11	15	ppb
037-41A A23 Girls Bathroom Sink Faucet #3	7/3/16 18:22	08-Jul-16	38123	Copper	ND	1.3	ppm
037-41A A23 Girls Bathroom Sink Faucet #3	7/3/16 18:22	08-Jul-16	38123	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-42A A23 Girls Bathroom Water Spigot #1	7/3/16 18:23	14-Jul-16	38124	Copper	1	1.3	ppm
037-42A A23 Girls Bathroom Water Spigot #1	7/3/16 18:23	14-Jul-16	38124	Lead	78	15	ppb
037-43A A23 Girls Bathroom Water Spigot #2	7/3/16 18:23	14-Jul-16	38125	Copper	ND	1.3	ppm
037-43A A23 Girls Bathroom Water Spigot #2	7/3/16 18:23	14-Jul-16	38125	Lead	168	15	ppb
037-44A A25 Room Sink Faucet	7/3/16 18:24	08-Jul-16	38126	Copper	ND	1.3	ppm
037-44A A25 Room Sink Faucet	7/3/16 18:24	08-Jul-16	38126	Lead	32	15	ppb
037-45A A26 Room Hand Wash Station	7/3/16 18:26	08-Jul-16	38127	Copper	0.1	1.3	ppm
037-45A A26 Room Hand Wash Station	7/3/16 18:26	08-Jul-16	38127	Lead	5	15	ppb
037-46A A26 Drinking Fountain	7/3/16 18:26	08-Jul-16	38128	Copper	ND	1.3	ppm
037-46A A26 Drinking Fountain	7/3/16 18:26	08-Jul-16	38128	Lead	14	15	ppb
037-47A A27 Room Sink Faucet	7/3/16 18:28	08-Jul-16	38129	Copper	0.2	1.3	ppm
037-47A A27 Room Sink Faucet	7/3/16 18:28	08-Jul-16	38129	Lead	3	15	ppb
037-48A A30 Health Room Lounge	7/3/16 18:31	08-Jul-16	38130	Copper	0.3	1.3	ppm
037-48A A30 Health Room Lounge	7/3/16 18:31	08-Jul-16	38130	Lead	6	15	ppb
037-49A A30 Health Room Exam -1	7/3/16 18:31	08-Jul-16	38131	Copper	0.4	1.3	ppm
037-49A A30 Health Room Exam -1	7/3/16 18:31	08-Jul-16	38131	Lead	3	15	ppb
037-50A A30 Health Room Exam -2	7/3/16 18:33	08-Jul-16	38132	Copper	0.6	1.3	ppm
037-50A A30 Health Room Exam -2	7/3/16 18:33	08-Jul-16	38132	Lead	8	15	ppb
037-51A A30 Health Room Exam -3	7/3/16 18:33	08-Jul-16	38133	Copper	0.2	1.3	ppm
037-51A A30 Health Room Exam -3	7/3/16 18:33	08-Jul-16	38133	Lead	14	15	ppb
037-52A A30 Health Room Lab - Sink Faucet Right	7/3/16 18:35	08-Jul-16	38134	Copper	0.7	1.3	ppm
037-52A A30 Health Room Lab - Sink Faucet Right	7/3/16 18:35	08-Jul-16	38134	Lead	7	15	ppb
037-53A A30 Health Room Lab - Sink Faucet Left	7/3/16 18:35	08-Jul-16	38135	Copper	0.5	1.3	ppm
037-53A A30 Health Room Lab - Sink Faucet Left	7/3/16 18:35	08-Jul-16	38135	Lead	24	15	ppb
037-54A A30 Health Room Lab Eye Wash	7/3/16 18:37	08-Jul-16	38136	Copper	0.3	1.3	ppm
037-54A A30 Health Room Lab Eye Wash	7/3/16 18:37	08-Jul-16	38136	Lead	42	15	ppb
037-55A A30 Health Room Bathroom Faucet	7/3/16 18:37	08-Jul-16	38137	Copper	0.6	1.3	ppm
037-55A A30 Health Room Bathroom Faucet	7/3/16 18:37	08-Jul-16	38137	Lead	2	15	ppb
037-56A Drinking Fountain On Corridor By 130 Left	7/3/16 18:38	08-Jul-16	38138	Copper	0.1	1.3	ppm
037-56A Drinking Fountain On Corridor By 130 Left	7/3/16 18:38	08-Jul-16	38138	Lead	ND	15	ppb
037-57A Drinking Fountain On Corridor By 130 Right	7/3/16 18:39	08-Jul-16	38139	Copper	ND	1.3	ppm
037-57A Drinking Fountain On Corridor By 130 Right	7/3/16 18:39	08-Jul-16	38139	Lead	10	15	ppb
037-58A Girls Bathroom Sink Faucet #1	7/3/16 18:41	08-Jul-16	38140	Copper	ND	1.3	ppm
037-58A Girls Bathroom Sink Faucet #1	7/3/16 18:41	08-Jul-16	38140	Lead	15.0	15	ppb
037-59A Girls Bathroom Sink Faucet #2	7/3/16 18:42	08-Jul-16	38141	Copper	ND	1.3	ppm
037-59A Girls Bathroom Sink Faucet #2	7/3/16 18:42	08-Jul-16	38141	Lead	27	15	ppb
037-60A Girls Bathroom Sink Faucet #3	7/3/16 18:43	08-Jul-16	38142	Copper	ND	1.3	ppm
037-60A Girls Bathroom Sink Faucet #3	7/3/16 18:43	08-Jul-16	38142	Lead	12	15	ppb
037-61A Girls Bathroom Water Spigot #1	7/3/16 18:44	14-Jul-16	38143	Copper	2.1	1.3	ppm
037-61A Girls Bathroom Water Spigot #1	7/3/16 18:44	14-Jul-16	38143	Lead	589	15	ppb
037-62A Girls Bathroom Water Spigot #2	7/3/16 18:45	08-Jul-16	38144	Copper	0.2	1.3	ppm
037-62A Girls Bathroom Water Spigot #2	7/3/16 18:45	08-Jul-16	38144	Lead	108	15	ppb
037-63A Boys Bathroom Sink Faucet #1	7/3/16 18:46	08-Jul-16	38145	Copper	ND	1.3	ppm
037-63A Boys Bathroom Sink Faucet #1	7/3/16 18:46	08-Jul-16	38145	Lead	31	15	ppb
037-64A Boys Bathroom Sink Faucet #2	7/3/16 18:49	08-Jul-16	38146	Copper	ND	1.3	ppm
037-64A Boys Bathroom Sink Faucet #2	7/3/16 18:49	08-Jul-16	38146	Lead	32	15	ppb
037-65A Boys Bathroom Sink Faucet #3	7/3/16 18:53	08-Jul-16	38147	Copper	ND	1.3	ppm
037-65A Boys Bathroom Sink Faucet #3	7/3/16 18:53	08-Jul-16	38147	Lead	9	15	ppb
037-66A Boys Bathroom Water Spigot #1	7/3/16 18:54	14-Jul-16	38148	Copper	0.9	1.3	ppm
037-66A Boys Bathroom Water Spigot #1	7/3/16 18:54	14-Jul-16	38148	Lead	397	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-67A Boys Bathroom Water Spigot #2	7/3/16 18:55	08-Jul-16	38149	Copper	ND	1.3	ppm
037-67A Boys Bathroom Water Spigot #2	7/3/16 18:55	08-Jul-16	38149	Lead	94	15	ppb
037-68A A38 Custodial Slop Sink Faucet	7/3/16 18:56	08-Jul-16	38150	Copper	ND	1.3	ppm
037-68A A38 Custodial Slop Sink Faucet	7/3/16 18:56	08-Jul-16	38150	Lead	34	15	ppb
037-69A Gymnasium Drinking Fountain by Boys Lockers	7/3/16 18:59	08-Jul-16	38151	Copper	0.3	1.3	ppm
037-69A Gymnasium Drinking Fountain By Boys Lockers	7/3/16 18:59	08-Jul-16	38151	Lead	12	15	ppb
037-70A Gymnasium Drinking Fountain By Girls Lockers	7/3/16 19:11	08-Jul-16	38152	Copper	0.1	1.3	ppm
037-70A Gymnasium Drinking Fountain By Girls Lockers	7/3/16 19:11	08-Jul-16	38152	Lead	4	15	ppb
037-71A Girls Locker Room Training Clinic Ice Tub #1	7/3/16 19:15	08-Jul-16	38153	Copper	ND	1.3	ppm
037-71A Girls Locker Room Training Clinic Ice Tub #1	7/3/16 19:15	08-Jul-16	38153	Lead	4	15	ppb
037-72A Girls Locker Room Training Clinic Ice Tub #2	7/3/16 19:16	08-Jul-16	38154	Copper	ND	1.3	ppm
037-72A Girls Locker Room Training Clinic Ice Tub #2	7/3/16 19:16	08-Jul-16	38154	Lead	16	15	ppb
037-73A Girls Locker Room Training Clinic Ice Machine	7/3/16 19:15	08-Jul-16	38155	Copper	ND	1.3	ppm
037-73A Girls Locker Room Training Clinic Ice Machine	7/3/16 19:15	08-Jul-16	38155	Lead	ND	15	ppb
037-74A Girls Locker Room Gym 3 Hand Wash	7/3/16 19:17	08-Jul-16	38156	Copper	ND	1.3	ppm
037-74A Girls Locker Room Gym 3 Hand Wash	7/3/16 19:17	08-Jul-16	38156	Lead	68	15	ppb
037-75A Girls Locker Room 3A Sink Faucet	7/3/16 19:18	08-Jul-16	38157	Copper	ND	1.3	ppm
037-75A Girls Locker Room 3A Sink Faucet	7/3/16 19:18	12-Jul-16	38157	Lead	54	15	ppb
037-76A Girls Locker Room 3A Shower	7/3/16 19:11	08-Jul-16	38158	Copper	0.3	1.3	ppm
037-76A Girls Locker Room 3A Shower	7/3/16 19:11	08-Jul-16	38158	Lead	49	15	ppb
037-77A Girls Locker Room 3A Water Spigot	7/3/16 19:19	14-Jul-16	38159	Copper	0.2	1.3	ppm
037-77A Girls Locker Room 3A Water Spigot	7/3/16 19:19	14-Jul-16	38159	Lead	287	15	ppb
037-78A Girls Locker Room Sink Faucet #1	7/3/16 19:11	08-Jul-16	38160	Copper	ND	1.3	ppm
037-78A Girls Locker Room Sink Faucet #1	7/3/16 19:11	08-Jul-16	38160	Lead	37	15	ppb
037-79A Girls Locker Room Sink Faucet #2	7/3/16 19:13	08-Jul-16	38161	Copper	ND	1.3	ppm
037-79A Girls Locker Room Sink Faucet #2	7/3/16 19:13	08-Jul-16	38161	Lead	22	15	ppb
037-80A Girls Locker Room Water Spigot #1	7/3/16 19:14	08-Jul-16	38162	Copper	0.2	1.3	ppm
037-80A Girls Locker Room Water Spigot #1	7/3/16 19:14	08-Jul-16	38162	Lead	29	15	ppb
037-81A Girls Locker Room Water Spigot #2	7/3/16 19:14	08-Jul-16	38163	Copper	ND	1.3	ppm
037-81A Girls Locker Room Water Spigot #2	7/3/16 19:14	08-Jul-16	38163	Lead	49	15	ppb
037-82A Girls Locker Room Isolated Shower	7/3/16 19:16	08-Jul-16	38164	Copper	ND	1.3	ppm
037-82A Girls Locker Room Isolated Shower	7/3/16 19:16	08-Jul-16	38164	Lead	10	15	ppb
037-83A Girls Locker Room Showers #1	7/3/16 19:18	08-Jul-16	38165	Copper	0.3	1.3	ppm
037-83A Girls Locker Room Showers #1	7/3/16 19:18	12-Jul-16	38165	Lead	438	15	ppb
037-84A Girls Locker Room Showers #2	7/3/16 19:21	14-Jul-16	38166	Copper	0.4	1.3	ppm
037-84A Girls Locker Room Showers #2	7/3/16 19:21	14-Jul-16	38166	Lead	571	15	ppb
037-85A Girls Locker Room Showers #3	7/3/16 19:21	14-Jul-16	38167	Copper	0.9	1.3	ppm
037-85A Girls Locker Room Showers #3	7/3/16 19:21	14-Jul-16	38167	Lead	996	15	ppb
037-86A Girls Locker Room Showers #4	7/3/16 19:22	14-Jul-16	38168	Copper	2.4	1.3	ppm
037-86A Girls Locker Room Showers #4	7/3/16 19:22	14-Jul-16	38168	Lead	1115	15	ppb
037-87A Girls Locker Room Showers #5	7/3/16 19:24	14-Jul-16	38169	Copper	0.7	1.3	ppm
037-87A Girls Locker Room Showers #5	7/3/16 19:24	14-Jul-16	38169	Lead	489	15	ppb
037-88A Girls Locker Room Showers #6	7/3/16 19:25	08-Jul-16	38170	Copper	0.5	1.3	ppm
037-88A Girls Locker Room Showers #6	7/3/16 19:25	12-Jul-16	38170	Lead	467	15	ppb
037-89A Girls Locker Room Showers #7	7/3/16 19:26	14-Jul-16	38171	Copper	0.9	1.3	ppm
037-89A Girls Locker Room Showers #7	7/3/16 19:26	12-Jul-16	38171	Lead	1247	15	ppb
037-90A Girls Locker Room Showers #8	7/3/16 19:28	14-Jul-16	38172	Copper	1.1	1.3	ppm
037-90A Girls Locker Room Showers #8	7/3/16 19:28	14-Jul-16	38172	Lead	863	15	ppb
037-91A Girls Locker Room Showers #9	7/3/16 19:29	08-Jul-16	38173	Copper	0.5	1.3	ppm
037-91A Girls Locker Room Showers #9	7/3/16 19:29	12-Jul-16	38173	Lead	279	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-92A Girls Locker Room Showers #10	7/3/16 19:31	14-Jul-16	38174	Copper	0.9	1.3	ppm
037-92A Girls Locker Room Showers #10	7/3/16 19:31	14-Jul-16	38174	Lead	646	15	ppb
037-93A Girls Locker Room Showers #11	7/3/16 19:32	08-Jul-16	38175	Copper	0.4	1.3	ppm
037-93A Girls Locker Room Showers #11	7/3/16 19:32	12-Jul-16	38175	Lead	202	15	ppb
037-94A Girls Locker Room Showers #12	7/3/16 19:34	08-Jul-16	38176	Copper	0.3	1.3	ppm
037-94A Girls Locker Room Showers #12	7/3/16 19:34	12-Jul-16	38176	Lead	199	15	ppb
037-95A Girls Locker Room Showers #13	7/3/16 19:36	08-Jul-16	38177	Copper	0.2	1.3	ppm
037-95A Girls Locker Room Showers #13	7/3/16 19:36	12-Jul-16	38177	Lead	193	15	ppb
037-96A Girls Locker Room Showers #14	7/3/16 19:38	08-Jul-16	38178	Copper	0.2	1.3	ppm
037-96A Girls Locker Room Showers #14	7/3/16 19:38	12-Jul-16	38178	Lead	107	15	ppb
037-97A Girls Locker Room Showers #15	7/3/16 19:41	08-Jul-16	38179	Copper	0.3	1.3	ppm
037-97A Girls Locker Room Showers #15	7/3/16 19:41	12-Jul-16	38179	Lead	166	15	ppb
037-98A Girls Locker Room Showers #16	7/3/16 19:42	08-Jul-16	38180	Copper	0.2	1.3	ppm
037-98A Girls Locker Room Showers #16	7/3/16 19:42	12-Jul-16	38180	Lead	151	15	ppb
037-99A Girls Locker Room Showers #17	7/3/16 19:43	08-Jul-16	38181	Copper	0.3	1.3	ppm
037-99A Girls Locker Room Showers #17	7/3/16 19:43	12-Jul-16	38181	Lead	221	15	ppb
037-100A Girls Locker Room Shower 18	7/3/16 19:45	08-Jul-16	38182	Copper	0.6	1.3	ppm
037-100A Girls Locker Room Shower 18	7/3/16 19:45	12-Jul-16	38182	Lead	580	15	ppb
037-101A Girls Locker Room Shower 19	7/3/16 19:46	14-Jul-16	38183	Copper	6.4	1.3	ppm
037-101A Girls Locker Room Shower 19	7/3/16 19:46	12-Jul-16	38183	Lead	292	15	ppb
037-102A Girls Locker Room Shower 20	7/3/16 19:47	14-Jul-16	38184	Copper	0.9	1.3	ppm
037-102A Girls Locker Room Shower 20	7/3/16 19:47	14-Jul-16	38184	Lead	16	15	ppb
037-103A Girls Locker Room Shower 21	7/3/16 19:48	08-Jul-16	38185	Copper	0.4	1.3	ppm
037-103A Girls Locker Room Shower 21	7/3/16 19:48	12-Jul-16	38185	Lead	77	15	ppb
037-104A Girls Locker Room Shower 22	7/3/16 19:51	14-Jul-16	38186	Copper	0.6	1.3	ppm
037-104A Girls Locker Room Shower 22	7/3/16 19:51	14-Jul-16	38186	Lead	514	15	ppb
037-105A Girls Locker Room Shower 23	7/3/16 19:52	08-Jul-16	38187	Copper	0.3	1.3	ppm
037-105A Girls Locker Room Shower 23	7/3/16 19:52	12-Jul-16	38187	Lead	404	15	ppb
037-106A Girls Locker Room Shower 24	7/3/16 19:53	08-Jul-16	38188	Copper	0.3	1.3	ppm
037-106A Girls Locker Room Shower 24	7/3/16 19:53	12-Jul-16	38188	Lead	282	15	ppb
037-107A Girls Locker Room Shower 25	7/3/16 19:54	08-Jul-16	38189	Copper	0.1	1.3	ppm
037-107A Girls Locker Room Shower 25	7/3/16 19:54	12-Jul-16	38189	Lead	252	15	ppb
037-108A Girls Locker Room Shower 26	7/3/16 19:55	08-Jul-16	38190	Copper	0.1	1.3	ppm
037-108A Girls Locker Room Shower 26	7/3/16 19:55	12-Jul-16	38190	Lead	239	15	ppb
037-109A Girls Locker Room Drinking Fountain	7/3/16 19:58	08-Jul-16	38191	Copper	ND	1.3	ppm
037-109A Girls locker Room drinking fountain	7/3/16 19:58	08-Jul-16	38191	Lead	10	15	ppb
037-110A Girls locker Room Water Spigot	7/3/16 20:09	08-Jul-16	38192	Copper	ND	1.3	ppm
037-110A Girls locker Room Water Spigot	7/3/16 20:09	12-Jul-16	38192	Lead	108	15	ppb
037-111A A/3-Gym - Slop Sink Faucet	7/3/16 20:03	08-Jul-16	38193	Copper	0.4	1.3	ppm
037-111A A/3-Gym - Slop Sink Faucet	7/3/16 20:03	12-Jul-16	38193	Lead	57	15	ppb
037-112A A/3-Gym - Slop Water Spigot	7/3/16 21:14	08-Jul-16	38194	Copper	ND	1.3	ppm
037-112A A/3-Gym - Slop Water Spigot	7/3/16 21:14	12-Jul-16	38194	Lead	51	15	ppb
037-113A Gym 4 - Drinking fountain	7/3/16 20:06	08-Jul-16	38195	Copper	ND	1.3	ppm
037-113A Gym 4 - Drinking fountain	7/3/16 20:06	08-Jul-16	38195	Lead	11	15	ppb
037-114A Gym 4- Weight Room-Drinking Fountain	7/3/16 20:07	08-Jul-16	38196	Copper	ND	1.3	ppm
037-114A Gym 4- Weight Room-Drinking Fountain	7/3/16 20:07	08-Jul-16	38196	Lead	39	15	ppb
037-115A Gym 26- Slop Sink Faucet	7/3/16 20:09	08-Jul-16	38197	Copper	ND	1.3	ppm
037-115A Gym 26- Slop Sink Faucet	7/3/16 20:09	12-Jul-16	38197	Lead	69	15	ppb
037-116A Gym 26- Water Spigot	7/3/16 20:10	14-Jul-16	38198	Copper	0.4	1.3	ppm
037-116A Gym 26- Water Spigot	7/3/16 20:10	14-Jul-16	38198	Lead	379	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-117A Boys locker Room - Water Spigot	7/3/16 20:17	08-Jul-16	38199	Copper	ND	1.3	ppm
037-117A Boys locker Room - Water Spigot	7/3/16 20:17	08-Jul-16	38199	Lead	34	15	ppb
037-118A Boys Locker Room Isolated Shower	7/3/16 20:18	08-Jul-16	38200	Copper	ND	1.3	ppm
037-118A Boys Locker Room Isolated Shower	7/3/16 20:18	08-Jul-16	38200	Lead	7	15	ppb
037-119A Boys Locker Roomhand Sink Faucet	7/3/16 20:19	08-Jul-16	38201	Copper	ND	1.3	ppm
037-119A Boys Locker RoomHand Sink Faucet	7/3/16 20:19	08-Jul-16	38201	Lead	14	15	ppb
037-120A Boys Locker RoomWater Spigot	7/3/16 20:21	14-Jul-16	38202	Copper	0.2	1.3	ppm
037-120A Boys Locker RoomWater Spigot	7/3/16 20:21	14-Jul-16	38202	Lead	256	15	ppb
037-121A Hand Sink Faucet by Showers left	7/3/16 20:22	08-Jul-16	38203	Copper	ND	1.3	ppm
037-121A Hand Sink Faucet by Showers left	7/3/16 20:22	08-Jul-16	38203	Lead	18	15	ppb
037-122A Hand Sink Faucet by Showers (right)	7/3/16 20:23	08-Jul-16	38204	Copper	ND	1.3	ppm
037-122A Hand Sink Faucet by Showers (right)	7/3/16 20:23	08-Jul-16	38204	Lead	5	15	ppb
037-123A Water Spigot #1 Showers (right)	7/3/16 20:23	08-Jul-16	38205	Copper	0.2	1.3	ppm
037-123A Water Spigot #1 Showers (right)	7/3/16 20:23	08-Jul-16	38205	Lead	16	15	ppb
037-124A Water Spigot #2 shower (right)	7/3/16 20:24	08-Jul-16	38206	Copper	ND	1.3	ppm
037-124A Water Spigot #2 shower (right)	7/3/16 20:24	08-Jul-16	38206	Lead	8	15	ppb
037-125A Boys Locker Room Showers #1	7/3/16 20:27	08-Jul-16	38207	Copper	0.6	1.3	ppm
037-125A Boys Locker Room Showers #1	7/3/16 20:27	08-Jul-16	38207	Lead	17	15	ppb
037-126A Boys Locker Room Showers #2	7/3/16 20:29	08-Jul-16	38208	Copper	0.4	1.3	ppm
037-126A Boys Locker Room Showers #2	7/3/16 20:29	12-Jul-16	38208	Lead	71	15	ppb
037-127A Boys Locker Room Showers #3	7/3/16 20:31	08-Jul-16	38209	Copper	0.5	1.3	ppm
037-127A Boys Locker Room Showers #3	7/3/16 20:31	12-Jul-16	38209	Lead	110	15	ppb
037-128A Boys Locker Room Showers #4	7/3/16 20:33	08-Jul-16	38210	Copper	0.6	1.3	ppm
037-128A Boys Locker Room Showers #4	7/3/16 20:33	12-Jul-16	38210	Lead	204	15	ppb
037-129A Boys Locker Room Showers #5	7/3/16 20:35	08-Jul-16	38211	Copper	0.6	1.3	ppm
037-129A Boys Locker Room Showers #5	7/3/16 20:35	12-Jul-16	38211	Lead	97	15	ppb
037-130A Boys Locker Room Showers #6	7/3/16 20:37	08-Jul-16	38212	Copper	0.6	1.3	ppm
037-130A Boys Locker Room Showers #6	7/3/16 20:37	12-Jul-16	38212	Lead	126	15	ppb
037-131A Boys Locker Room Showers #7	7/3/16 20:39	08-Jul-16	38213	Copper	0.5	1.3	ppm
037-131A Boys Locker Room Showers #7	7/3/16 20:39	12-Jul-16	38213	Lead	115	15	ppb
037-132A Boys Locker Room Showers #8	7/3/16 20:41	08-Jul-16	38214	Copper	0.4	1.3	ppm
037-132A Boys Locker Room Showers #8	7/3/16 20:41	12-Jul-16	38214	Lead	98	15	ppb
037-133A Boys Locker Room Shower #9	7/3/16 20:45	08-Jul-16	38215	Copper	0.6	1.3	ppm
037-133A Boys Locker Room Shower #9	7/3/16 20:45	12-Jul-16	38215	Lead	87	15	ppb
037-134A Boys Locker Room Showers #10	7/3/16 20:47	08-Jul-16	38216	Copper	0.5	1.3	ppm
037-134A Boys Locker Room Showers #10	7/3/16 20:47	12-Jul-16	38216	Lead	111	15	ppb
037-135A Boys Locker Room Shower #11	7/3/16 20:49	14-Jul-16	38217	Copper	1.4	1.3	ppm
037-135A Boys Locker Room Shower #11	7/3/16 20:49	12-Jul-16	38217	Lead	76	15	ppb
037-136A Boys Locker Room Shower #12	7/3/16 20:50	08-Jul-16	38218	Copper	0.7	1.3	ppm
037-136A Boys Locker Room Shower #12	7/3/16 20:50	12-Jul-16	38218	Lead	190	15	ppb
037-137A Boys Locker Room Shower #13	7/3/16 20:51	08-Jul-16	38219	Copper	0.7	1.3	ppm
037-137A Boys Locker Room Shower #13	7/3/16 20:51	12-Jul-16	38219	Lead	158	15	ppb
037-138A Boys Locker Room Shower #14	7/3/16 20:53	08-Jul-16	38220	Copper	0.6	1.3	ppm
037-138A Boys Locker Room Shower #14	7/3/16 20:53	12-Jul-16	38220	Lead	79	15	ppb
037-139A Boys Locker Room Shower #15	7/3/16 20:54	08-Jul-16	38221	Copper	0.4	1.3	ppm
037-139A Boys Locker Room Shower #15	7/3/16 20:54	12-Jul-16	38221	Lead	72	15	ppb
037-140A Boys Locker Room Shower #16	7/3/16 20:56	14-Jul-16	38222	Copper	0.4	1.3	ppm
037-140A Boys Locker Room Shower #16	7/3/16 20:56	14-Jul-16	38222	Lead	87	15	ppb
037-141A Boys Locker Room Shower #17	7/3/16 20:58	08-Jul-16	38223	Copper	0.4	1.3	ppm
037-141A Boys Locker Room Shower #17	7/3/16 20:58	12-Jul-16	38223	Lead	84	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-142A Boys Locker Room Shower #18	7/3/16 20:59	08-Jul-16	38224	Copper	0.5	1.3	ppm
037-142A Boys Locker Room Shower #18	7/3/16 20:59	12-Jul-16	38224	Lead	164	15	ppb
037-143A Boys Locker Room Shower #19	7/3/16 21:01	08-Jul-16	38225	Copper	0.4	1.3	ppm
037-143A Boys Locker Room Shower #19	7/3/16 21:01	12-Jul-16	38225	Lead	123	15	ppb
037-144A Boys Locker Room Shower #20	7/3/16 21:01	08-Jul-16	38226	Copper	0.4	1.3	ppm
037-144A Boys Locker Room Shower #20	7/3/16 21:01	12-Jul-16	38226	Lead	119	15	ppb
037-145A Boys Locker Room Showers #21	7/3/16 21:02	08-Jul-16	38227	Copper	0.4	1.3	ppm
037-145A Boys Locker Room Showers #21	7/3/16 21:02	12-Jul-16	38227	Lead	142	15	ppb
037-146A Boys Locker Room Showers #22	7/3/16 21:03	14-Jul-16	38228	Copper	0.9	1.3	ppm
037-146A Boys Locker Room Showers #22	7/3/16 21:03	12-Jul-16	38228	Lead	251	15	ppb
037-147A Boys Locker Room Showers #23	7/3/16 21:05	14-Jul-16	38229	Copper	0.5	1.3	ppm
037-147A Boys Locker Room Showers #23	7/3/16 21:05	14-Jul-16	38229	Lead	147	15	ppb
037-148A Boys Locker Room Showers #24	7/3/16 21:06	08-Jul-16	38230	Copper	0.4	1.3	ppm
037-148A Boys Locker Room Showers #24	7/3/16 21:06	12-Jul-16	38230	Lead	150	15	ppb
037-149A Boys Locker Room Showers #25	7/3/16 21:08	08-Jul-16	38231	Copper	0.2	1.3	ppm
037-149A Boys Locker Room Showers #25	7/3/16 21:08	12-Jul-16	38231	Lead	94	15	ppb
037-150A Boys Locker Room Showers #26	7/3/16 21:10	08-Jul-16	38232	Copper	0.2	1.3	ppm
037-150A Boys Locker Room Showers #26	7/3/16 21:10	12-Jul-16	38232	Lead	90	15	ppb
037-151A Boys Locker Room Shower #27	7/3/16 21:11	08-Jul-16	38233	Copper	0.1	1.3	ppm
037-151A Boys Locker Room Shower #27	7/3/16 21:11	12-Jul-16	38233	Lead	50	15	ppb
037-152A Cafeteria Drinking Fountain by A-41	7/3/16 21:16	08-Jul-16	38234	Copper	0.2	1.3	ppm
037-152A Cafeteria Drinking Fountain by A-41	7/3/16 21:16	08-Jul-16	38234	Lead	9	15	ppb
037-153A Cafeteria Drinking Fountain by Dish Washing Room	7/3/16 21:18	08-Jul-16	38235	Copper	ND	1.3	ppm
037-153A Cafeteria Drinking Fountain by Dish Washing Room	7/3/16 21:18	08-Jul-16	38235	Lead	17	15	ppb
037-154A Dish Washing Room - hanging hose	7/3/16 21:20	08-Jul-16	38236	Copper	0.3	1.3	ppm
037-154A Dish Washing Room - hanging hose	7/3/16 21:20	08-Jul-16	38236	Lead	3	15	ppb
037-155A Dish Washing Room - Sink Faucet	7/3/16 21:24	08-Jul-16	38237	Copper	0.3	1.3	ppm
037-155A Dish Washing Room - Sink Faucet	7/3/16 21:24	08-Jul-16	38237	Lead	9	15	ppb
037-156A Dish Washing Room Bathroom Sink Faucet	7/3/16 21:26	08-Jul-16	38238	Copper	ND	1.3	ppm
037-156A Dish Washing Room Bathroom Sink Faucet	7/3/16 21:26	08-Jul-16	38238	Lead	20	15	ppb
037-157A Womens Dressing Room Bathroom Sink Faucet	7/3/16 21:28	08-Jul-16	38239	Copper	ND	1.3	ppm
037-157A Womens Dressing Room Bathroom Sink Faucet	7/3/16 21:28	08-Jul-16	38239	Lead	7	15	ppb
037-158A Kitchen Sink Faucet #1	7/3/16 21:30	08-Jul-16	38240	Copper	ND	1.3	ppm
037-158A Kitchen Sink Faucet #1	7/3/16 21:30	08-Jul-16	38240	Lead	10	15	ppb
037-159A Kitchen White Hand Wash Sink Faucet (#2)	7/3/16 21:31	08-Jul-16	38241	Copper	0.2	1.3	ppm
037-159A Kitchen White Hand Wash Sink Faucet (#2)	7/3/16 21:31	08-Jul-16	38241	Lead	28	15	ppb
037-160A Kitchen Sink Faucet #3	7/3/16 21:32	08-Jul-16	38242	Copper	0.2	1.3	ppm
037-160A Kitchen Sink Faucet #3	7/3/16 21:32	08-Jul-16	38242	Lead	15.0	15	ppb
037-161A Kitchen Sink Faucet #4	7/3/16 21:33	08-Jul-16	38243	Copper	0.1	1.3	ppm
037-161A Kitchen Sink Faucet #4	7/3/16 21:33	08-Jul-16	38243	Lead	14	15	ppb
037-162A Kitchen Sink Faucet by window (#5)	7/3/16 21:33	08-Jul-16	38244	Copper	ND	1.3	ppm
037-162A Kitchen Sink Faucet by window (#5)	7/3/16 21:33	08-Jul-16	38244	Lead	3	15	ppb
037-163A Kitchen emergency eye wash	7/3/16 21:35	08-Jul-16	38245	Copper	ND	1.3	ppm
037-163A Kitchen emergency eye wash	7/3/16 21:35	08-Jul-16	38245	Lead	ND	15	ppb
037-164A Kitchen Sink Faucet by window (#6)	7/3/16 21:36	08-Jul-16	38246	Copper	ND	1.3	ppm
037-164A Kitchen Sink Faucet by window (#6)	7/3/16 21:36	08-Jul-16	38246	Lead	2	15	ppb
037-165A Kitchen Sink Faucet by wall (#7)	7/3/16 21:37	08-Jul-16	38247	Copper	ND	1.3	ppm
037-165A Kitchen Sink Faucet by wall (#7)	7/3/16 21:37	08-Jul-16	38247	Lead	2	15	ppb
037-166A Child Care Kitchen Sink Faucet #1	7/3/16 21:38	08-Jul-16	38248	Copper	0.2	1.3	ppm
037-166A Child Care Kitchen Sink Faucet #1	7/3/16 21:38	08-Jul-16	38248	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-167A Child Care Sink Faucet #2	7/3/16 21:38	08-Jul-16	38249	Copper	0.5	1.3	ppm
037-167A Child Care Sink Faucet #2	7/3/16 21:38	08-Jul-16	38249	Lead	4	15	ppb
037-168A Child Care - Child Sink Faucet	7/3/16 21:39	08-Jul-16	38250	Copper	0.4	1.3	ppm
037-168A Child Care - Child Sink Faucet	7/3/16 21:39	08-Jul-16	38250	Lead	7	15	ppb
037-169A Child care Sink Faucet #2	7/3/16 21:39	08-Jul-16	38251	Copper	0.6	1.3	ppm
037-169A Child care Sink Faucet #2	7/3/16 21:39	08-Jul-16	38251	Lead	4	15	ppb
037-170A First Floor Corridor - Drinking Fountain #1 by B23	7/3/16 21:48	08-Jul-16	38252	Copper	ND	1.3	ppm
037-170A First Floor Corridor - Drinking Fountain #1 by B23	7/3/16 21:48	08-Jul-16	38252	Lead	15.0	15	ppb
037-171A First Floor Corridor - Drinking Fountain #2 by B23	7/3/16 21:49	08-Jul-16	38253	Copper	ND	1.3	ppm
037-171A First Floor Corridor - Drinking Fountain #2 by B23	7/3/16 21:49	08-Jul-16	38253	Lead	10	15	ppb
037-172A Girls Bathroom Sink Faucet #1	7/3/16 21:51	08-Jul-16	38254	Copper	ND	1.3	ppm
037-172A Girls Bathroom Sink Faucet #1	7/3/16 21:51	08-Jul-16	38254	Lead	5	15	ppb
037-173A Girls Bathroom Sink Faucet #2	7/3/16 21:53	08-Jul-16	38255	Copper	ND	1.3	ppm
037-173A Girls Bathroom Sink Faucet #2	7/3/16 21:53	08-Jul-16	38255	Lead	8	15	ppb
037-174A Girls Bathroom Sink Faucet #3	7/3/16 21:54	08-Jul-16	38256	Copper	0.1	1.3	ppm
037-174A Girls Bathroom Sink Faucet #3	7/3/16 21:54	08-Jul-16	38256	Lead	23	15	ppb
037-175A Girls Bathroom Water Spigot #1	7/3/16 21:56	08-Jul-16	38257	Copper	ND	1.3	ppm
037-175A Girls Bathroom Water Spigot #1	7/3/16 21:56	08-Jul-16	38257	Lead	40	15	ppb
037-176A Girls Bathroom Water Spigot #2	7/3/16 21:56	08-Jul-16	38258	Copper	0.2	1.3	ppm
037-176A Girls Bathroom Water Spigot #2	7/3/16 21:56	12-Jul-16	38258	Lead	97	15	ppb
037-177A B33 Girls Bathroom Sink Faucet #1	7/3/16 21:58	08-Jul-16	38259	Copper	ND	1.3	ppm
037-177A B33 Girls Bathroom Sink Faucet #1	7/3/16 21:58	08-Jul-16	38259	Lead	19	15	ppb
037-178A B33 Girls Bathroom Sink Faucet #2	7/3/16 22:00	08-Jul-16	38260	Copper	ND	1.3	ppm
037-178A B33 Girls Bathroom Sink Faucet #2	7/3/16 22:00	08-Jul-16	38260	Lead	18	15	ppb
037-179A B33 Girls Bathroom Sink Faucet #3	7/3/16 22:00	08-Jul-16	38261	Copper	ND	1.3	ppm
037-179A B33 Girls Bathroom Sink Faucet #3	7/3/16 22:00	08-Jul-16	38261	Lead	18	15	ppb
037-180A B33 Girls Bathroom Water Spigot #1	7/3/16 21:58	08-Jul-16	38262	Copper	0.5	1.3	ppm
037-180A B33 Girls Bathroom Water Spigot #1	7/3/16 21:58	12-Jul-16	38262	Lead	101	15	ppb
037-181A B33 Girls Bathroom Water Spigot #2	7/3/16 21:58	14-Jul-16	38263	Copper	0.9	1.3	ppm
037-181A B33 Girls Bathroom Water Spigot #2	7/3/16 21:58	14-Jul-16	38263	Lead	5259	15	ppb
037-182A B34 Custodial Slop Sink Faucet	7/3/16 22:01	08-Jul-16	38264	Copper	ND	1.3	ppm
037-182A B34 Custodial Slop Sink Faucet	7/3/16 22:01	08-Jul-16	38264	Lead	27	15	ppb
037-183A B34 Custodial slop Water Spigot	7/3/16 22:02	14-Jul-16	38265	Copper	0.1	1.3	ppm
037-183A B34 Custodial slop Water Spigot	7/3/16 22:02	14-Jul-16	38265	Lead	114	15	ppb
037-184A B35 Restroom Sink Faucet #1	7/3/16 22:02	08-Jul-16	38266	Copper	ND	1.3	ppm
037-184A B35 Restroom Sink Faucet #1	7/3/16 22:02	08-Jul-16	38266	Lead	23	15	ppb
037-185A B35 Restroom Sink Faucet #2	7/3/16 22:03	08-Jul-16	38267	Copper	ND	1.3	ppm
037-185A B35 Restroom Sink Faucet #2	7/3/16 22:03	08-Jul-16	38267	Lead	21	15	ppb
037-186A B35 Restroom Sink Faucet Water Spigot #1	7/3/16 22:04	14-Jul-16	38268	Copper	0.4	1.3	ppm
037-186A B35 Restroom Sink Faucet Water Spigot #1	7/3/16 22:04	14-Jul-16	38268	Lead	62	15	ppb
037-187A B35 Restroom Sink Faucet Water Spigot #2	7/3/16 22:05	14-Jul-16	38269	Copper	0.3	1.3	ppm
037-187A B35 Restroom Sink Faucet Water Spigot #2	7/3/16 22:05	14-Jul-16	38269	Lead	453	15	ppb
037-188A Drinking Fountain by Room B36 - left	7/3/16 22:04	08-Jul-16	38270	Copper	ND	1.3	ppm
037-188A Drinking Fountain by Room B36 - left	7/3/16 22:04	08-Jul-16	38270	Lead	9	15	ppb
037-189A Drinking Fountain by Room B36 - right	7/3/16 22:05	08-Jul-16	38271	Copper	ND	1.3	ppm
037-189A Drinking Fountain by Room B36 - right	7/3/16 22:05	08-Jul-16	38271	Lead	20	15	ppb
037-190A Boys Bathroom B37 Sink Faucet 1	7/3/16 22:07	08-Jul-16	38272	Copper	ND	1.3	ppm
037-190A Boys Bathroom B37 Sink Faucet 1	7/3/16 22:07	08-Jul-16	38272	Lead	43	15	ppb
037-191A Boys Bathroom B37 Sink Faucet 2	7/3/16 22:07	08-Jul-16	38273	Copper	ND	1.3	ppm
037-191A Boys Bathroom B37 Sink Faucet 2	7/3/16 22:07	08-Jul-16	38273	Lead	27	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-192A Boys Bathroom B37 Sink Faucet 3	7/3/16 22:08	08-Jul-16	38274	Copper	ND	1.3	ppm
037-192A Boys Bathroom B37 Sink Faucet 3	7/3/16 22:08	08-Jul-16	38274	Lead	19	15	ppb
037-193A Boys Bathroom Water Spigot #1	7/3/16 22:08	14-Jul-16	38275	Copper	0.6	1.3	ppm
037-193A Boys Bathroom Water Spigot #1	7/3/16 22:08	14-Jul-16	38275	Lead	67	15	ppb
037-194A Boys Bathroom Water Spigot #2	7/3/16 22:09	08-Jul-16	38276	Copper	0.3	1.3	ppm
037-194A Boys Bathroom Water Spigot #2	7/3/16 22:09	12-Jul-16	38276	Lead	150	15	ppb
037-195A B46 Room Sink Faucet	7/3/16 22:13	08-Jul-16	38277	Copper	ND	1.3	ppm
037-195A B46 Room Sink Faucet	7/3/16 22:13	08-Jul-16	38277	Lead	5	15	ppb
037-196A B51 Room Sink Faucet	7/3/16 22:15	08-Jul-16	38278	Copper	ND	1.3	ppm
037-196A B51 Room Sink Faucet	7/3/16 22:15	08-Jul-16	38278	Lead	2	15	ppb
037-197A B52 Girls Bathroom Sink Faucet #1	7/3/16 22:17	08-Jul-16	38279	Copper	ND	1.3	ppm
037-197A B52 Girls Bathroom Sink Faucet #1	7/3/16 22:17	08-Jul-16	38279	Lead	11	15	ppb
037-198A B52 Girls Bathroom Sink Faucet #2	7/3/16 22:17	08-Jul-16	38280	Copper	ND	1.3	ppm
037-198A B52 Girls Bathroom Sink Faucet #2	7/3/16 22:17	08-Jul-16	38280	Lead	15.0	15	ppb
037-199A B52 Girls Bathroom Sink Faucet #3	7/3/16 22:18	08-Jul-16	38281	Copper	ND	1.3	ppm
037-199A B52 Girls Bathroom Sink Faucet #3	7/3/16 22:18	08-Jul-16	38281	Lead	8	15	ppb
037-200A B52 Girls Bathroom Water Spigot #1	7/3/16 22:18	14-Jul-16	38282	Copper	0.5	1.3	ppm
037-200A B52 Girls Bathroom Water Spigot #1	7/3/16 22:18	14-Jul-16	38282	Lead	233	15	ppb
037-201A B52 Girls Bathroom Water Spigot #2	7/3/16 22:19	14-Jul-16	38283	Copper	1	1.3	ppm
037-201A B52 Girls Restroom Water Spigot #2	7/3/16 22:19	12-Jul-16	38283	Lead	79	15	ppb
037-202A Handicap Bathroom Sink Faucet	7/3/16 22:21	08-Jul-16	38284	Copper	ND	1.3	ppm
037-202A Handicap Bathroom Sink Faucet	7/3/16 22:21	08-Jul-16	38284	Lead	13	15	ppb
037-203A B54 Slop Sink Faucet	7/3/16 22:23	08-Jul-16	38285	Copper	ND	1.3	ppm
037-203A B54 Slop Sink Faucet	7/3/16 22:23	08-Jul-16	38285	Lead	12	15	ppb
037-204A B55 Boys Bathroom Sink Faucet #1	7/3/16 22:24	08-Jul-16	38286	Copper	ND	1.3	ppm
037-204A B55 Boys Bathroom Sink Faucet #1	7/3/16 22:24	08-Jul-16	38286	Lead	10	15	ppb
037-205A B55 Boys Bathroom Sink Faucet #2	7/3/16 22:24	08-Jul-16	38287	Copper	ND	1.3	ppm
037-205A B55 Boys Bathroom Sink Faucet #2	7/3/16 22:24	08-Jul-16	38287	Lead	11	15	ppb
037-206A B55 Boys Bathroom Sink Faucet #3	7/3/16 22:25	08-Jul-16	38288	Copper	ND	1.3	ppm
037-206A B55 Boys Bathroom Sink Faucet #3	7/3/16 22:25	08-Jul-16	38288	Lead	22	15	ppb
037-207A B55 Boys Bathroom Water Spigot #1	7/3/16 22:25	14-Jul-16	38289	Copper	0.6	1.3	ppm
037-207A B55 Boys Bathroom Water Spigot #1	7/3/16 22:25	14-Jul-16	38289	Lead	205	15	ppb
037-208A B55 Boys Bathroom Water Spigot #2	7/3/16 22:26	14-Jul-16	38290	Copper	0.3	1.3	ppm
037-208A B55 Boys Bathroom Water Spigot #2	7/3/16 22:26	14-Jul-16	38290	Lead	268	15	ppb
037-209A Drinking Fountain by Restrooms	7/3/16 22:27	08-Jul-16	38291	Copper	ND	1.3	ppm
037-209A Drinking Fountain by Restrooms	7/3/16 22:27	08-Jul-16	38291	Lead	4	15	ppb
037-210A Drinking Fountain by Restrooms	7/3/16 22:28	08-Jul-16	38292	Copper	ND	1.3	ppm
037-210A Drinking Fountain by Restrooms	7/3/16 22:28	08-Jul-16	38292	Lead	3	15	ppb
037-211A B59 Boys Bathroom handwash	7/3/16 22:30	08-Jul-16	38293	Copper	ND	1.3	ppm
037-211A B59 Boys Bathroom handwash	7/3/16 22:30	08-Jul-16	38293	Lead	16	15	ppb
037-212A B59 Boys Bathroom Water Spigot	7/3/16 22:31	08-Jul-16	38294	Copper	ND	1.3	ppm
037-212A B59 Boys Bathroom Water Spigot	7/3/16 22:31	12-Jul-16	38294	Lead	77	15	ppb
037-213A B16 Custodial Slop Sink Faucet	7/3/16 22:33	08-Jul-16	38295	Copper	ND	1.3	ppm
037-213A B16 Custodial Slop Sink Faucet	7/3/16 22:33	12-Jul-16	38295	Lead	283	15	ppb
037-214A B16 Custodial Water Spigot	7/3/16 22:33	08-Jul-16	38296	Copper	0.1	1.3	ppm
037-214A B16 Custodial Water Spigot	7/3/16 22:33	12-Jul-16	38296	Lead	400	15	ppb
037-215A Drinking Fountain by B61	7/3/16 22:34	08-Jul-16	38297	Copper	ND	1.3	ppm
037-215A Drinking Fountain by B61	7/3/16 22:34	08-Jul-16	38297	Lead	2	15	ppb
037-216A B63 Girls Bathroom handwash	7/3/16 22:36	08-Jul-16	38298	Copper	ND	1.3	ppm
037-216A B63 Girls Bathroom handwash	7/3/16 22:36	08-Jul-16	38298	Lead	34	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-217A B63 Girls Bathroom Water Spigot	7/3/16 22:37	14-Jul-16	38299	Copper	ND	1.3	ppm
037-217A B63 Girls Bathroom Water Spigot	7/3/16 22:37	14-Jul-16	38299	Lead	127	15	ppb
037-218A B65 stage Room Sink Faucet	7/3/16 22:38	08-Jul-16	38300	Copper	ND	1.3	ppm
037-218A B65 stage Room Sink Faucet	7/3/16 22:38	08-Jul-16	38300	Lead	48	15	ppb
037-219A Drinking Fountain by Main Office #1	7/3/16 22:42	08-Jul-16	38301	Copper	ND	1.3	ppm
037-219A Drinking Fountain by Main Office #1	7/3/16 22:42	08-Jul-16	38301	Lead	4	15	ppb
037-220A Drinking Fountain by Main Office #2	7/3/16 22:43	08-Jul-16	38302	Copper	ND	1.3	ppm
037-220A Drinking Fountain by Main Office #2	7/3/16 22:43	08-Jul-16	38302	Lead	ND	15	ppb
037-221A Main Office Work Room Sink Faucet	7/3/16 22:45	08-Jul-16	38303	Copper	0.2	1.3	ppm
037-221A Main Office Work Room Sink Faucet	7/3/16 22:45	08-Jul-16	38303	Lead	20	15	ppb
037-222A Nurse Bathroom Sink Faucet Hand Wash	7/3/16 22:46	08-Jul-16	38304	Copper	0.1	1.3	ppm
037-222A Nurse Bathroom Sink Faucet Hand Wash	7/3/16 22:46	12-Jul-16	38304	Lead	59	15	ppb
037-223A Nurse Bathroom Sink Faucet Eye Wash	7/3/16 22:47	08-Jul-16	38305	Copper	0.1	1.3	ppm
037-223A Nurse Bathroom Sink Faucet Eye Wash	7/3/16 22:47	12-Jul-16	38305	Lead	62	15	ppb
037-224A Library Bathroom Sink Faucet - Instructional material	7/3/16 22:58	08-Jul-16	38306	Copper	ND	1.3	ppm
037-224A Library Bathroom Sink Faucet - Instructional material	7/3/16 22:58	08-Jul-16	38306	Lead	20	15	ppb
037-225A B2 Faculty Mens Bathroom Sink Faucet	7/3/16 22:48	12-Jul-16	38307	Copper	0.1	1.3	ppm
037-225A B2 Faculty Mens Bathroom Sink Faucet	7/3/16 22:48	12-Jul-16	38307	Lead	51	15	ppb
037-226A Drinking Fountain on Corridor by B5 #1	7/3/16 22:54	12-Jul-16	38308	Copper	0.1	1.3	ppm
037-226A Drinking Fountain on Corridor by B5 #1	7/3/16 22:54	12-Jul-16	38308	Lead	5	15	ppb
037-227A Drinking Fountain on Corridor by B5 #2	7/3/16 22:55	12-Jul-16	38309	Copper	ND	1.3	ppm
037-227A Drinking Fountain on Corridor by B5 #2	7/3/16 22:55	12-Jul-16	38309	Lead	9	15	ppb
037-228A B3 - Faculty Womens Bathroom Sink Faucet #1	7/3/16 22:57	12-Jul-16	38310	Copper	ND	1.3	ppm
037-228A B3 - Faculty Womens Bathroom Sink Faucet #1	7/3/16 22:57	12-Jul-16	38310	Lead	22	15	ppb
037-229A B3 - Faculty Womens Bathroom Sink Faucet #2	7/3/16 22:58	12-Jul-16	38311	Copper	ND	1.3	ppm
037-229A B3 - Faculty Womens Bathroom Sink Faucet #2	7/3/16 22:58	12-Jul-16	38311	Lead	9	15	ppb
037-230A B4 Custodial Water Spigot	7/3/16 23:00	12-Jul-16	38312	Copper	0.5	1.3	ppm
037-230A B4 Custodial Water Spigot	7/3/16 23:00	12-Jul-16	38312	Lead	68	15	ppb
037-231A B14 Student Store Sink Faucet	7/3/16 23:02	12-Jul-16	38313	Copper	0.1	1.3	ppm
037-231A B14 Student Store Sink Faucet	7/3/16 23:02	12-Jul-16	38313	Lead	69	15	ppb
037-232A B19 - Boys Bathroom Sink Faucet #1	7/3/16 23:05	12-Jul-16	38314	Copper	0.2	1.3	ppm
037-232A B19 - Boys Bathroom Sink Faucet #1	7/3/16 23:05	12-Jul-16	38314	Lead	109	15	ppb
037-233A B19 - Boys Bathroom Sink Faucet #2	7/3/16 23:05	12-Jul-16	38315	Copper	ND	1.3	ppm
037-233A B19 - Boys Bathroom Sink Faucet #2	7/3/16 23:05	12-Jul-16	38315	Lead	21	15	ppb
037-234A B19 - Boys Bathroom Water Spigot #1	7/3/16 23:06	14-Jul-16	38316	Copper	0.4	1.3	ppm
037-234A B19 - Boys Bathroom Water Spigot #1	7/3/16 23:06	14-Jul-16	38316	Lead	96	15	ppb
037-235A B19 - Boys Bathroom Water Spigot #2	7/3/16 23:06	14-Jul-16	38317	Copper	0.3	1.3	ppm
037-235A B19 - Boys Bathroom Water Spigot #2	7/3/16 23:06	14-Jul-16	38317	Lead	111	15	ppb
037-236A B20 Restroom Sink Faucet	7/3/16 23:08	12-Jul-16	38318	Copper	ND	1.3	ppm
037-236A B20 Restroom Sink Faucet	7/3/16 23:08	12-Jul-16	38318	Lead	8	15	ppb
037-237A B21 Restroom Sink Faucet	7/3/16 23:08	12-Jul-16	38319	Copper	ND	1.3	ppm
037-237A B21 Restroom Sink Faucet	7/3/16 23:08	12-Jul-16	38319	Lead	8	15	ppb
037-238A B22 Custodial Slop Sink Faucet	7/3/16 23:10	12-Jul-16	38320	Copper	ND	1.3	ppm
037-238A B22 Custodial Slop Sink Faucet	7/3/16 23:10	12-Jul-16	38320	Lead	6	15	ppb
037-239A B22 Custodial Water Spigot	7/3/16 23:11	14-Jul-16	38321	Copper	2	1.3	ppm
037-239A B22 Custodial Water Spigot	7/3/16 23:11	14-Jul-16	38321	Lead	153	15	ppb
037-240A Drinking Fountain by C26 #1	7/3/16 23:17	12-Jul-16	38322	Copper	0.2	1.3	ppm
037-240A Drinking Fountain by C26 #1	7/3/16 23:17	12-Jul-16	38322	Lead	1	15	ppb
037-241A Drinking Fountain by C26 #2	7/3/16 23:18	12-Jul-16	38323	Copper	ND	1.3	ppm
037-241A Drinking Fountain by C26 #2	7/3/16 23:18	12-Jul-16	38323	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-242A C26 Girls Bathroom Sink Faucet #1	7/3/16 23:23	12-Jul-16	38324	Copper	0.1	1.3	ppm
037-242A C26 Girls Bathroom Sink Faucet #1	7/3/16 23:23	12-Jul-16	38324	Lead	11	15	ppb
037-243A C26 Girls Bathroom Sink Faucet #2	7/3/16 23:24	12-Jul-16	38325	Copper	ND	1.3	ppm
037-243A C26 Girls Bathroom Sink Faucet #2	7/3/16 23:24	12-Jul-16	38325	Lead	7	15	ppb
037-244A C26 Girls Bathroom Sink Faucet #3	7/3/16 23:24	12-Jul-16	38326	Copper	ND	1.3	ppm
037-244A C26 Girls Bathroom Sink Faucet #3	7/3/16 23:24	12-Jul-16	38326	Lead	9	15	ppb
037-245A C26 Girls Bathroom Water Spigot #1	7/3/16 23:25	14-Jul-16	38327	Copper	0.1	1.3	ppm
037-245A C26 Girls Bathroom Water Spigot #1	7/3/16 23:25	14-Jul-16	38327	Lead	17	15	ppb
037-246A C26 Girls Bathroom Water Spigot #2	7/3/16 23:25	14-Jul-16	38328	Copper	0.8	1.3	ppm
037-246A C26 Girls Bathroom Water Spigot #2	7/3/16 23:25	14-Jul-16	38328	Lead	84	15	ppb
037-247A C27 Room Sink Faucet #1	7/3/16 23:28	12-Jul-16	38329	Copper	0.1	1.3	ppm
037-247A C27 Room Sink Faucet #1	7/3/16 23:28	12-Jul-16	38329	Lead	47	15	ppb
037-248A C27 Room Sink Faucet #2	7/3/16 23:29	12-Jul-16	38330	Copper	ND	1.3	ppm
037-248A C27 Room Sink Faucet #2	7/3/16 23:29	12-Jul-16	38330	Lead	18	15	ppb
037-249A C27 Room Sink Faucet #3	7/3/16 23:30	12-Jul-16	38331	Copper	ND	1.3	ppm
037-249A C27 Room Sink Faucet #3	7/3/16 23:30	12-Jul-16	38331	Lead	40	15	ppb
037-250A C28 Room Sink Faucet #1	7/3/16 23:31	12-Jul-16	38332	Copper	0.2	1.3	ppm
037-250A C28 Room Sink Faucet #1	7/3/16 23:31	12-Jul-16	38332	Lead	61	15	ppb
037-251A C28 Room Sink Faucet #2	7/3/16 23:32	14-Jul-16	38333	Copper	ND	1.3	ppm
037-251A C28 Room Sink Faucet #2	7/3/16 23:32	14-Jul-16	38333	Lead	58	15	ppb
037-252A C34 Girls Bathroom Sink Faucet #1	7/3/16 23:34	12-Jul-16	38334	Copper	ND	1.3	ppm
037-252A C34 Girls Bathroom Sink Faucet #1	7/3/16 23:34	12-Jul-16	38334	Lead	40	15	ppb
037-253A C34 Girls Bathroom Sink Faucet #2	7/3/16 23:34	12-Jul-16	38335	Copper	ND	1.3	ppm
037-253A C34 Girls Bathroom Sink Faucet #2	7/3/16 23:34	12-Jul-16	38335	Lead	43	15	ppb
037-254A C34 Girls Bathroom Sink Faucet #3	7/3/16 23:36	12-Jul-16	38336	Copper	ND	1.3	ppm
037-254A C34 Girls Bathroom Sink Faucet #3	7/3/16 23:36	12-Jul-16	38336	Lead	38	15	ppb
037-255A C35 Custodian Slop Sink Faucet	7/3/16 23:36	12-Jul-16	38337	Copper	ND	1.3	ppm
037-255A C35 Custodian Slop Sink Faucet	7/3/16 23:36	12-Jul-16	38337	Lead	20	15	ppb
037-256A C35 Custodian Water Spigot	7/3/16 23:37	14-Jul-16	38338	Copper	0.3	1.3	ppm
037-256A C35 Custodian Water Spigot	7/3/16 23:37	14-Jul-16	38338	Lead	442	15	ppb
037-257A C32 - Mens Bathroom Sink Faucet #1	7/3/16 23:39	12-Jul-16	38339	Copper	ND	1.3	ppm
037-257A C32 - Mens Bathroom Sink Faucet #1	7/3/16 23:39	12-Jul-16	38339	Lead	37	15	ppb
037-258A C32 - Mens Bathroom Sink Faucet #2	7/3/16 23:40	12-Jul-16	38340	Copper	ND	1.3	ppm
037-258A C32 - Mens Bathroom Sink Faucet #2	7/3/16 23:40	12-Jul-16	38340	Lead	37	15	ppb
037-259A C32 - Mens Bathroom Water Spigot #1	7/3/16 23:41	14-Jul-16	38341	Copper	0.1	1.3	ppm
037-259A C32 - Mens Bathroom Water Spigot #1	7/3/16 23:41	14-Jul-16	38341	Lead	414	15	ppb
037-260A C32 - Mens Bathroom Water Spigot #2	7/3/16 23:41	14-Jul-16	38342	Copper	0.3	1.3	ppm
037-260A C32 - Mens Bathroom Water Spigot #2	7/3/16 23:41	14-Jul-16	38342	Lead	94	15	ppb
037-261A Drinking Fountain by C36 #1	7/3/16 23:42	12-Jul-16	38343	Copper	ND	1.3	ppm
037-261A Drinking Fountain by C36 #1	7/3/16 23:42	12-Jul-16	38343	Lead	24	15	ppb
037-262A Drinking Fountain by C36 #2	7/3/16 23:42	12-Jul-16	38344	Copper	0.1	1.3	ppm
037-262A Drinking Fountain by C36 #2	7/3/16 23:42	12-Jul-16	38344	Lead	39	15	ppb
037-263A C37 Boys Bathroom Sink Faucet #1	7/3/16 23:44	12-Jul-16	38345	Copper	ND	1.3	ppm
037-263A C37 Boys Bathroom Sink Faucet #1	7/3/16 23:44	12-Jul-16	38345	Lead	45	15	ppb
037-264A C37 Boys Bathroom Sink Faucet #2	7/3/16 23:44	12-Jul-16	38346	Copper	ND	1.3	ppm
037-264A C37 Boys Bathroom Sink Faucet #2	7/3/16 23:44	12-Jul-16	38346	Lead	38	15	ppb
037-265A C37 Boys Bathroom Sink Faucet #3	7/3/16 23:45	12-Jul-16	38347	Copper	ND	1.3	ppm
037-265A C37 Boys Bathroom Sink Faucet #3	7/3/16 23:45	12-Jul-16	38347	Lead	28	15	ppb
037-266A C37 Boys Bathroom Water Spigot 1	7/3/16 23:45	14-Jul-16	38348	Copper	0.8	1.3	ppm
037-266A C37 Boys Bathroom Water Spigot 1	7/3/16 23:45	14-Jul-16	38348	Lead	140	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-267A C37 Boys Bathroom Water Spigot #2	7/3/16 23:46	12-Jul-16	38349	Copper	0.2	1.3	ppm
037-267A C37 Boys Bathroom Water Spigot #2	7/3/16 23:46	12-Jul-16	38349	Lead	218	15	ppb
037-268A C38 Room Sink Faucet	7/3/16 23:46	12-Jul-16	38350	Copper	ND	1.3	ppm
037-268A C38 Room Sink Faucet	7/3/16 23:46	12-Jul-16	38350	Lead	15.0	15	ppb
037-269A C40 Room Sink Faucet	7/3/16 23:48	12-Jul-16	38351	Copper	ND	1.3	ppm
037-269A C40 Room Sink Faucet	7/3/16 23:48	12-Jul-16	38351	Lead	17	15	ppb
037-270A C44 Room Sink Faucet	7/3/16 23:48	12-Jul-16	38352	Copper	ND	1.3	ppm
037-270A C44 Room Sink Faucet	7/3/16 23:48	12-Jul-16	38352	Lead	9	15	ppb
037-271A C45 - Sink Faucet	7/3/16 23:49	12-Jul-16	38353	Copper	ND	1.3	ppm
037-271A C45 - Sink Faucet	7/3/16 23:49	12-Jul-16	38353	Lead	17	15	ppb
037-272A C46 Sink Faucet	7/3/16 23:51	12-Jul-16	38354	Copper	ND	1.3	ppm
037-272A C46 Sink Faucet	7/3/16 23:51	12-Jul-16	38354	Lead	28	15	ppb
037-273A C49 Girls Bathroom Sink Faucet #1	7/3/16 23:53	12-Jul-16	38355	Copper	ND	1.3	ppm
037-273A C49 Girls Bathroom Sink Faucet #1	7/3/16 23:53	12-Jul-16	38355	Lead	11	15	ppb
037-274A C49 Girls Bathroom Sink Faucet #2	7/3/16 23:54	12-Jul-16	38356	Copper	ND	1.3	ppm
037-274A C49 Girls Bathroom Sink Faucet #2	7/3/16 23:54	12-Jul-16	38356	Lead	5	15	ppb
037-275A C49 Girls Bathroom Sink Faucet #3	7/3/16 23:55	12-Jul-16	38357	Copper	ND	1.3	ppm
037-275A C49 Girls Bathroom Sink Faucet #3	7/3/16 23:55	12-Jul-16	38357	Lead	4	15	ppb
037-276A C49 Girls Bathroom Sink Faucet #1	7/3/16 23:55	14-Jul-16	38358	Copper	1.1	1.3	ppm
037-276A C49 Girls Bathroom Sink Faucet #1	7/3/16 23:55	14-Jul-16	38358	Lead	270	15	ppb
037-277A C49 Girls Bathroom Sink Faucet #2	7/3/16 23:56	12-Jul-16	38359	Copper	0.7	1.3	ppm
037-277A C49 Girls Bathroom Sink Faucet #2	7/3/16 23:56	12-Jul-16	38359	Lead	185	15	ppb
037-278A Restroom next to C49 Sink Faucet	7/3/16 23:56	12-Jul-16	38360	Copper	ND	1.3	ppm
037-278A Restroom next to C49 Sink Faucet	7/3/16 23:56	12-Jul-16	38360	Lead	6	15	ppb
037-279A Restroom next to C49 shower	7/3/16 23:56	12-Jul-16	38361	Copper	ND	1.3	ppm
037-279A Restroom next to C49 shower	7/3/16 23:56	12-Jul-16	38361	Lead	31	15	ppb
037-280A C51 Custodial Slop Sink Faucet	7/4/16 0:01	12-Jul-16	38362	Copper	ND	1.3	ppm
037-280A C51 Custodial Slop Sink Faucet	7/4/16 0:01	12-Jul-16	38362	Lead	3	15	ppb
037-281A C51 Custodial Slop Sink Faucet Water Spigot	7/4/16 0:01	14-Jul-16	38363	Copper	0.1	1.3	ppm
037-281A C51 Custodial Slop Sink Faucet Water Spigot	7/4/16 0:01	14-Jul-16	38363	Lead	81	15	ppb
037-282A C52 Boys Bathroom Sink Faucet #1	7/4/16 0:02	12-Jul-16	38364	Copper	ND	1.3	ppm
037-282A C52 Boys Bathroom Sink Faucet #1	7/4/16 0:02	12-Jul-16	38364	Lead	16	15	ppb
037-283A C52 Boys Bathroom Sink Faucet #2	7/4/16 0:02	12-Jul-16	38365	Copper	ND	1.3	ppm
037-283A C52 Boys Bathroom Sink Faucet #2	7/4/16 0:02	12-Jul-16	38365	Lead	22	15	ppb
037-284A C52 Boys Bathroom Sink Faucet #3	7/4/16 0:02	12-Jul-16	38366	Copper	ND	1.3	ppm
037-284A C52 Boys Bathroom Sink Faucet #3	7/4/16 0:02	12-Jul-16	38366	Lead	17	15	ppb
037-285A C52 Boys Bathroom Water Spigot #1	7/4/16 0:03	12-Jul-16	38367	Copper	0.1	1.3	ppm
037-285A C52 Boys Bathroom Water Spigot #1	7/4/16 0:03	12-Jul-16	38367	Lead	53	15	ppb
037-286A C52 Boys Bathroom Water Spigot #2	7/4/16 0:03	12-Jul-16	38368	Copper	0.2	1.3	ppm
037-286A C52 Boys Bathroom Water Spigot #2	7/4/16 0:03	12-Jul-16	38368	Lead	145	15	ppb
037-287A Drinking Fountain by Room C54 #1	7/4/16 0:05	12-Jul-16	38369	Copper	ND	1.3	ppm
037-287A Drinking Fountain by Room C54 #1	7/4/16 0:05	12-Jul-16	38369	Lead	3	15	ppb
037-288A Drinking Fountain by Room C54 #2	7/4/16 0:06	12-Jul-16	38370	Copper	ND	1.3	ppm
037-288A Drinking Fountain by Room C54 #2	7/4/16 0:06	12-Jul-16	38370	Lead	8	15	ppb
037-289A Drinking Fountain on Corridor by Room C10 #1	7/4/16 0:10	12-Jul-16	38371	Copper	ND	1.3	ppm
037-289A Drinking Fountain on Corridor by Room C10 #1	7/4/16 0:10	12-Jul-16	38371	Lead	4	15	ppb
037-290A Drinking Fountain on Corridor by Room C10 #2	7/4/16 0:10	12-Jul-16	38372	Copper	ND	1.3	ppm
037-290A Drinking Fountain on Corridor by Room C10 #2	7/4/16 0:10	12-Jul-16	38372	Lead	12	15	ppb
037-291A Room C10 Sink Faucet #1	7/4/16 0:12	12-Jul-16	38373	Copper	ND	1.3	ppm
037-291A Room C10 Sink Faucet #1	7/4/16 0:12	12-Jul-16	38373	Lead	37	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-292A Room C10 Sink Faucet #2	7/4/16 0:13	12-Jul-16	38374	Copper	ND	1.3	ppm
037-292A Room C10 Sink Faucet #2	7/4/16 0:13	12-Jul-16	38374	Lead	26	15	ppb
037-293A Room C10 Sink Faucet Upfront #3	7/4/16 0:14	12-Jul-16	38375	Copper	ND	1.3	ppm
037-293A Room C10 Sink Faucet Upfront #3	7/4/16 0:14	12-Jul-16	38375	Lead	126	15	ppb
037-294A C11 - Sink Faucet by window	7/4/16 0:15	12-Jul-16	38376	Copper	ND	1.3	ppm
037-294A C11 - Sink Faucet by window	7/4/16 0:15	12-Jul-16	38376	Lead	23	15	ppb
037-295A C12 - Sink Faucet #1	7/4/16 0:16	14-Jul-16	38377	Copper	0.1	1.3	ppm
037-295A C12 - Sink Faucet #1	7/4/16 0:16	14-Jul-16	38377	Lead	658	15	ppb
037-296A C12 - Sink Faucet #2	7/4/16 0:16	14-Jul-16	38378	Copper	0.2	1.3	ppm
037-296A C12 - Sink Faucet #2	7/4/16 0:16	14-Jul-16	38378	Lead	378	15	ppb
037-297A C12 - Sink Faucet #3	7/4/16 0:17	14-Jul-16	38379	Copper	0.1	1.3	ppm
037-297A C12 - Sink Faucet #3	7/4/16 0:17	14-Jul-16	38379	Lead	100	15	ppb
037-298A C12 - Sink Faucet #4	7/4/16 0:19	14-Jul-16	38380	Copper	0.4	1.3	ppm
037-298A C12 - Sink Faucet #4	7/4/16 0:19	14-Jul-16	38380	Lead	478	15	ppb
037-299A C12 - Sink Faucet #5	7/4/16 0:19	14-Jul-16	38381	Copper	0.2	1.3	ppm
037-299A C12 - Sink Faucet #5	7/4/16 0:19	14-Jul-16	38381	Lead	230	15	ppb
037-300A C12 - Sink Faucet #6	7/4/16 0:20	14-Jul-16	38382	Copper	0.3	1.3	ppm
037-300A C12 - Sink Faucet #6	7/4/16 0:20	14-Jul-16	38382	Lead	447	15	ppb
037-301A C12 - Sink Faucet #7	7/4/16 0:21	14-Jul-16	38383	Copper	0.2	1.3	ppm
037-301A C12 - Sink Faucet #7	7/4/16 0:21	14-Jul-16	38383	Lead	349	15	ppb
037-302A C12 - Sink Faucet #8	7/4/16 0:22	12-Jul-16	38384	Copper	ND	1.3	ppm
037-302A C12 - Sink Faucet #8	7/4/16 0:22	12-Jul-16	38384	Lead	119	15	ppb
037-303A C12 - Sink Faucet #9	7/4/16 0:23	12-Jul-16	38385	Copper	ND	1.3	ppm
037-303A C12 - Sink Faucet #9	7/4/16 0:23	12-Jul-16	38385	Lead	116	15	ppb
037-304A C12 - Sink Faucet #10	7/4/16 0:24	12-Jul-16	38386	Copper	ND	1.3	ppm
037-304A C12 - Sink Faucet #10	7/4/16 0:24	12-Jul-16	38386	Lead	103	15	ppb
037-305A C12 - Sink Faucet #11	7/4/16 0:25	14-Jul-16	38387	Copper	0.2	1.3	ppm
037-305A C12 - Sink Faucet #11	7/4/16 0:25	14-Jul-16	38387	Lead	278	15	ppb
037-306A C12 - Sink Faucet #12	7/4/16 0:26	14-Jul-16	38388	Copper	0.2	1.3	ppm
037-306A C12 - Sink Faucet #12	7/4/16 0:26	14-Jul-16	38388	Lead	280	15	ppb
037-307A C12 - Sink Faucet #13	7/4/16 0:29	14-Jul-16	38389	Copper	0.1	1.3	ppm
037-307A C12 - Sink Faucet #13	7/4/16 0:29	14-Jul-16	38389	Lead	205	15	ppb
037-308A C13 - Sink Faucet #1	7/4/16 0:30	12-Jul-16	38390	Copper	ND	1.3	ppm
037-308A C13 - Sink Faucet #1	7/4/16 0:30	12-Jul-16	38390	Lead	145	15	ppb
037-309A C13 - Sink Faucet #2	7/4/16 0:32	12-Jul-16	38391	Copper	ND	1.3	ppm
037-309A C13 - Sink Faucet #2	7/4/16 0:32	12-Jul-16	38391	Lead	42	15	ppb
037-310A C13 - Sink Faucet #3	7/4/16 0:33	12-Jul-16	38392	Copper	ND	1.3	ppm
037-310A C13 - Sink Faucet #3	7/4/16 0:33	12-Jul-16	38392	Lead	13	15	ppb
037-311A C15 - Sink Faucet #1	7/4/16 0:33	12-Jul-16	38393	Copper	ND	1.3	ppm
037-311A C15 - Sink Faucet #1	7/4/16 0:33	12-Jul-16	38393	Lead	64	15	ppb
037-312A C15 - Sink Faucet #2	7/4/16 0:33	12-Jul-16	38394	Copper	0.1	1.3	ppm
037-312A C15 - Sink Faucet #2	7/4/16 0:33	12-Jul-16	38394	Lead	24	15	ppb
037-313A C15 - Sink Faucet #3	7/4/16 0:34	12-Jul-16	38395	Copper	ND	1.3	ppm
037-313A C15 - Sink Faucet #3	7/4/16 0:34	12-Jul-16	38395	Lead	54	15	ppb
037-314A C15 - Sink Faucet #4	7/4/16 0:34	12-Jul-16	38396	Copper	0.1	1.3	ppm
037-314A C15 - Sink Faucet #4	7/4/16 0:34	12-Jul-16	38396	Lead	94	15	ppb
037-315A C16 - Sink Faucet #1	7/4/16 0:35	14-Jul-16	38397	Copper	ND	1.3	ppm
037-315A C16 - Sink Faucet #1	7/4/16 0:35	14-Jul-16	38397	Lead	286	15	ppb
037-316A C16 - Sink Faucet #2	7/4/16 0:35	14-Jul-16	38398	Copper	0.1	1.3	ppm
037-316A C16 - Sink Faucet #2	7/4/16 0:35	14-Jul-16	38398	Lead	179	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-317A C16 - Sink Faucet #3	7/4/16 0:36	14-Jul-16	38399	Copper	0.1	1.3	ppm
037-317A C16 - Sink Faucet #3	7/4/16 0:36	14-Jul-16	38399	Lead	127	15	ppb
037-318A C16 - Sink Faucet #4	7/4/16 0:36	12-Jul-16	38400	Copper	0.1	1.3	ppm
037-318A C16 - Sink Faucet #4	7/4/16 0:36	12-Jul-16	38400	Lead	139	15	ppb
037-319A C16 - Sink Faucet #5	7/4/16 0:36	14-Jul-16	38401	Copper	0.1	1.3	ppm
037-319A C16 - Sink Faucet #5	7/4/16 0:36	14-Jul-16	38401	Lead	168	15	ppb
037-320A C16 - Sink Faucet #6	7/4/16 0:37	12-Jul-16	38402	Copper	ND	1.3	ppm
037-320A C16 - Sink Faucet #6	7/4/16 0:37	12-Jul-16	38402	Lead	106	15	ppb
037-321A I C16 - Sink Faucet #7	7/4/16 0:38	12-Jul-16	38403	Copper	ND	1.3	ppm
037-321A I C16 - Sink Faucet #7	7/4/16 0:38	12-Jul-16	38403	Lead	310	15	ppb
037-321A II C16 - Sink Faucet #7	7/4/16 0:38	14-Jul-16	38404	Copper	0.2	1.3	ppm
037-321A II C16 - Sink Faucet #7	7/4/16 0:38	14-Jul-16	38404	Lead	362	15	ppb
037-322A C16 - Sink Faucet #8	7/4/16 0:38	12-Jul-16	38405	Copper	ND	1.3	ppm
037-322A C16 - Sink Faucet #8	7/4/16 0:38	12-Jul-16	38405	Lead	34	15	ppb
037-323A C16 - Sink Faucet #9	7/4/16 0:39	14-Jul-16	38406	Copper	0.3	1.3	ppm
037-323A C16 - Sink Faucet #9	7/4/16 0:39	14-Jul-16	38406	Lead	145	15	ppb
037-324A C16 - Sink Faucet #10	7/4/16 0:39	14-Jul-16	38407	Copper	0.3	1.3	ppm
037-324A C16 - Sink Faucet #10	7/4/16 0:39	14-Jul-16	38407	Lead	747	15	ppb
037-325A C16 - Sink Faucet #11	7/4/16 0:40	14-Jul-16	38408	Copper	0.1	1.3	ppm
037-325A C16 - Sink Faucet #11	7/4/16 0:40	14-Jul-16	38408	Lead	186	15	ppb
037-326A C16 - Sink Faucet #12	7/4/16 0:42	12-Jul-16	38409	Copper	ND	1.3	ppm
037-326A C16 - Sink Faucet #12	7/4/16 0:42	12-Jul-16	38409	Lead	31	15	ppb
037-327A C16 - Sink Faucet #13	7/4/16 0:43	14-Jul-16	38410	Copper	ND	1.3	ppm
037-327A C16 - Sink Faucet #13	7/4/16 0:43	14-Jul-16	38410	Lead	167	15	ppb
037-328A C16 - Eye Wash #1	7/4/16 0:44	15-Jul-16	38411	Copper	ND	1.3	ppm
037-328A C16 - Eye Wash #1	7/4/16 0:44	15-Jul-16	38411	Lead	35	15	ppb
037-329A C16 - Eye Wash #2	7/4/16 0:45	12-Jul-16	38412	Copper	ND	1.3	ppm
037-329A C16 - Eye Wash #2	7/4/16 0:45	12-Jul-16	38412	Lead	23	15	ppb
037-330A C16 -Sink Faucet In Hoods #1	7/4/16 0:47	12-Jul-16	38413	Copper	0.4	1.3	ppm
037-330A C16 -Sink Faucet In Hoods #1	7/4/16 0:47	12-Jul-16	38413	Lead	169	15	ppb
037-331A C16 -Sink Faucet In Hoods #2	7/4/16 0:47	12-Jul-16	38414	Copper	0.3	1.3	ppm
037-331A C16 -Sink Faucet In Hoods #2	7/4/16 0:47	12-Jul-16	38414	Lead	70	15	ppb
037-332A C17 Sink Faucet #1	7/4/16 0:48	12-Jul-16	38415	Copper	ND	1.3	ppm
037-332A C17 Sink Faucet #1	7/4/16 0:48	12-Jul-16	38415	Lead	636	15	ppb
037-333A C17 Sink Faucet #2	7/4/16 0:48	12-Jul-16	38416	Copper	ND	1.3	ppm
037-333A C17 Sink Faucet #2	7/4/16 0:48	12-Jul-16	38416	Lead	53	15	ppb
037-334A C17 Sink Faucet #3	7/4/16 0:48	12-Jul-16	38417	Copper	ND	1.3	ppm
037-334A C17 Sink Faucet #3	7/4/16 0:48	12-Jul-16	38417	Lead	11	15	ppb
037-335A C17 Sink Faucet #4	7/4/16 0:48	12-Jul-16	38418	Copper	ND	1.3	ppm
037-335A C17 Sink Faucet #4	7/4/16 0:48	12-Jul-16	38418	Lead	22	15	ppb
037-336A C20 Sink Faucet #1	7/4/16 0:50	12-Jul-16	38419	Copper	ND	1.3	ppm
037-336A C20 Sink Faucet #1	7/4/16 0:50	12-Jul-16	38419	Lead	28	15	ppb
037-337A C20 Sink Faucet #2	7/4/16 0:51	12-Jul-16	38420	Copper	0.1	1.3	ppm
037-337A C20 Sink Faucet #2	7/4/16 0:51	12-Jul-16	38420	Lead	11	15	ppb
037-338A C20 Sink Faucet #3	7/4/16 0:52	12-Jul-16	38421	Copper	ND	1.3	ppm
037-338A C20 Sink Faucet #3	7/4/16 0:52	12-Jul-16	38421	Lead	18	15	ppb
037-339A C20 Sink Faucet #4	7/4/16 0:53	12-Jul-16	38422	Copper	ND	1.3	ppm
037-339A C20 Sink Faucet #4	7/4/16 0:53	12-Jul-16	38422	Lead	32	15	ppb
037-340A C22 Boys Bathroom Sink Faucet #1	7/4/16 0:56	12-Jul-16	38423	Copper	ND	1.3	ppm
037-340A C22 Boys Bathroom Sink Faucet #1	7/4/16 0:56	12-Jul-16	38423	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-341A C22 Boys Bathroom Sink Faucet #2	7/4/16 0:56	12-Jul-16	38424	Copper	ND	1.3	ppm
037-341A C22 Boys Bathroom Sink Faucet #2	7/4/16 0:56	12-Jul-16	38424	Lead	6	15	ppb
037-342A C22 Boys Bathroom Sink Faucet #3	7/4/16 0:58	12-Jul-16	38425	Copper	ND	1.3	ppm
037-342A C22 Boys Bathroom Sink Faucet #3	7/4/16 0:58	12-Jul-16	38425	Lead	13	15	ppb
037-343A C22 Boys Bathroom Water Spigot #1	7/4/16 0:58	12-Jul-16	38426	Copper	ND	1.3	ppm
037-343A C22 Boys Bathroom Water Spigot #1	7/4/16 0:58	12-Jul-16	38426	Lead	10	15	ppb
037-344A C22 Boys Bathroom Water Spigot #2	7/4/16 0:59	12-Jul-16	38427	Copper	0.1	1.3	ppm
037-344A C22 Boys Bathroom Water Spigot #2	7/4/16 0:59	12-Jul-16	38427	Lead	53	15	ppb
037-345A C23 Bathroom Sink Faucet	7/4/16 0:59	12-Jul-16	38428	Copper	0.1	1.3	ppm
037-345A C23 Bathroom Sink Faucet	7/4/16 0:59	12-Jul-16	38428	Lead	6	15	ppb
037-346A C24 Bathroom Sink Faucet	7/4/16 1:01	12-Jul-16	38429	Copper	0.1	1.3	ppm
037-346A C24 Bathroom Sink Faucet	7/4/16 1:01	12-Jul-16	38429	Lead	16	15	ppb
037-347A C25 Custodial Slop Sink Faucet	7/4/16 1:03	12-Jul-16	38430	Copper	ND	1.3	ppm
037-347A C25 Custodial Slop Sink Faucet	7/4/16 1:03	12-Jul-16	38430	Lead	6	15	ppb
037-348A C25 Custodial Water Spigot	7/4/16 1:04	12-Jul-16	38431	Copper	0.2	1.3	ppm
037-348A C25 Custodial Water Spigot	7/4/16 1:04	12-Jul-16	38431	Lead	38	15	ppb
037-349A Exterior Water Spigot WS1	7/4/16 2:36	12-Jul-16	38432	Copper	0.3	1.3	ppm
037-349A Exterior Water Spigot WS1	7/4/16 2:36	12-Jul-16	38432	Lead	58	15	ppb
037-350A Exterior Water Spigot WS2	7/4/16 2:38	12-Jul-16	38433	Copper	0.1	1.3	ppm
037-350A Exterior Water Spigot WS2	7/4/16 2:38	12-Jul-16	38433	Lead	10	15	ppb
037-351A Exterior Water Spigot WS3	7/4/16 2:41	12-Jul-16	38434	Copper	ND	1.3	ppm
037-351A Exterior Water Spigot WS3	7/4/16 2:41	12-Jul-16	38434	Lead	113	15	ppb
037-352A Exterior Water Spigot WS4	7/4/16 2:43	12-Jul-16	38435	Copper	ND	1.3	ppm
037-352A Exterior Water Spigot WS4	7/4/16 2:43	12-Jul-16	38435	Lead	4	15	ppb
037-353A Exterior Water Spigot WS5	7/4/16 1:09	15-Jul-16	38436	Copper	0.3	1.3	ppm
037-353A Exterior Water Spigot WS5	7/4/16 1:09	15-Jul-16	38436	Lead	215	15	ppb
037-354A Exterior Water Spigot WS6	7/4/16 1:11	12-Jul-16	38437	Copper	ND	1.3	ppm
037-354A Exterior Water Spigot WS6	7/4/16 1:11	12-Jul-16	38437	Lead	45	15	ppb
037-355A Exterior Water Spigot WS7	7/4/16 1:14	12-Jul-16	38438	Copper	ND	1.3	ppm
037-355A Exterior Water Spigot WS7	7/4/16 1:14	12-Jul-16	38438	Lead	12	15	ppb
037-356A Exterior Water Spigot WS8	7/4/16 1:16	12-Jul-16	38439	Copper	ND	1.3	ppm
037-356A Exterior Water Spigot WS8	7/4/16 1:16	12-Jul-16	38439	Lead	11	15	ppb
037-357A Exterior Water Spigot WS9	7/4/16 1:18	12-Jul-16	38440	Copper	ND	1.3	ppm
037-357A Exterior Water Spigot WS9	7/4/16 1:18	12-Jul-16	38440	Lead	51	15	ppb
037-358A Exterior Water Spigot WS10	7/4/16 1:21	12-Jul-16	38441	Copper	ND	1.3	ppm
037-358A Exterior Water Spigot WS10	7/4/16 1:21	12-Jul-16	38441	Lead	12	15	ppb
037-359A Exterior Water Spigot WS11	7/4/16 1:23	12-Jul-16	38442	Copper	ND	1.3	ppm
037-359A Exterior Water Spigot WS11	7/4/16 1:23	12-Jul-16	38442	Lead	20	15	ppb
037-360A Exterior Water Spigot WS12	7/4/16 1:25	12-Jul-16	38443	Copper	0.3	1.3	ppm
037-360A Exterior Water Spigot WS12	7/4/16 1:25	12-Jul-16	38443	Lead	88	15	ppb
037-361A Exterior Water Spigot WS13	7/4/16 1:27	12-Jul-16	38444	Copper	0.6	1.3	ppm
037-361A Exterior Water Spigot WS13	7/4/16 1:27	12-Jul-16	38444	Lead	60	15	ppb
037-362A Exterior Water Spigot WS14	7/4/16 1:29	12-Jul-16	38445	Copper	ND	1.3	ppm
037-362A Exterior Water Spigot WS14	7/4/16 1:29	12-Jul-16	38445	Lead	5	15	ppb
037-363A Exterior Water Spigot WS15	7/4/16 1:31	12-Jul-16	38446	Copper	ND	1.3	ppm
037-363A Exterior Water Spigot WS15	7/4/16 1:31	12-Jul-16	38446	Lead	13	15	ppb
037-364A Exterior Water Spigot WS16	7/4/16 1:35	12-Jul-16	38447	Copper	ND	1.3	ppm
037-364A Exterior Water Spigot WS16	7/4/16 1:35	12-Jul-16	38447	Lead	3	15	ppb
037-365A Exterior Water Spigot WS17	7/4/16 1:39	12-Jul-16	38448	Copper	ND	1.3	ppm
037-365A Exterior Water Spigot WS17	7/4/16 1:39	12-Jul-16	38448	Lead	20	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marshall High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
037-366A Exterior Water Spigot WS18	7/4/16 1:43	12-Jul-16	38449	Copper	ND	1.3	ppm
037-366A Exterior Water Spigot WS18	7/4/16 1:43	12-Jul-16	38449	Lead	26	15	ppb
037-367A Exterior Water Spigot WS19	7/4/16 1:47	12-Jul-16	38450	Copper	ND	1.3	ppm
037-367A Exterior Water Spigot WS19	7/4/16 1:47	12-Jul-16	38450	Lead	30	15	ppb
037-368A A4 Drinking Fountain	7/4/16 1:10	12-Jul-16	38451	Copper	ND	1.3	ppm
037-368A A4 Drinking Fountain	7/4/16 1:10	12-Jul-16	38451	Lead	19	15	ppb
037-369A Field House Drinking Fountain	7/4/16 1:51	12-Jul-16	38452	Copper	0.4	1.3	ppm
037-369A Field House Drinking Fountain	7/4/16 1:51	12-Jul-16	38452	Lead	4	15	ppb
037-370A Field House Boys Bathroom Sink Faucet #1	7/4/16 1:54	12-Jul-16	38453	Copper	0.2	1.3	ppm
037-370A Field House Boys Bathroom Sink Faucet #1	7/4/16 1:54	12-Jul-16	38453	Lead	22	15	ppb
037-371A Field House Boys Bathroom Sink Faucet #2	7/4/16 1:57	12-Jul-16	38454	Copper	0.3	1.3	ppm
037-371A Field House Boys Bathroom Sink Faucet #2	7/4/16 1:57	12-Jul-16	38454	Lead	16	15	ppb
037-372A Field House Drinking Fountain by Girls RR #1	7/4/16 1:59	12-Jul-16	38455	Copper	0.3	1.3	ppm
037-372A Field House Drinking Fountain by Girls RR #1	7/4/16 1:59	12-Jul-16	38455	Lead	5	15	ppb
037-373A Field House Sink Faucet In Snack Shack	7/4/16 2:03	12-Jul-16	38456	Copper	0.5	1.3	ppm
037-373A Field House Sink Faucet In Snack Shack	7/4/16 2:03	12-Jul-16	38456	Lead	6	15	ppb
037-374A Field House Girls Bathroom Sink Faucet	7/4/16 2:06	14-Jul-16	38457	Copper	0.2	1.3	ppm
037-374A Field House Girls Bathroom Sink Faucet	7/4/16 2:06	14-Jul-16	38457	Lead	10	15	ppb
037-375A Field House Water Spigot Handicap Bathroom	7/4/16 2:11	14-Jul-16	38458	Copper	0.2	1.3	ppm
037-375A Field House Water Spigot Handicap Bathroom	7/4/16 2:11	14-Jul-16	38458	Lead	8	15	ppb
EPA Action Level for Lead of 15 ppb					ND = Non detect		
EPA Action Level for Copper of 1.3 ppm							
Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.							