

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Penninsula Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
067-LOCK-01A Boys Locker Room Sink Faucet	6/16/2016 14:55	6/21/2016 17:11	606170201	Copper	0.0	1.3	ppm
067-LOCK-01A Boys Locker Room Sink Faucet	6/16/2016 14:55	6/21/2016 17:11	606170201	Lead	35	15	ppb
067-LOCK-02A Boys Locker Room Water Spigot	6/16/2016 15:09	6/21/2016 17:11	606170202	Copper	0.0	1.3	ppm
067-LOCK-02A Boys Locker Room Water Spigot	6/16/2016 15:09	6/21/2016 17:11	606170202	Lead	5	15	ppb
067-LOCK-03A Boys Locker Room Sink Faucet	6/16/2016 14:57	6/21/2016 17:14	606170203	Copper	0.0	1.3	ppm
067-LOCK-03A Boys Locker Room Sink Faucet	6/16/2016 14:57	6/21/2016 17:14	606170203	Lead	45	15	ppb
067-DIR-04A Directors Office BR Sink Faucet	6/16/2016 15:11	6/21/2016 17:14	606170204	Copper	0.0	1.3	ppm
067-DIR-04A Directors Office BR Sink Faucet	6/16/2016 15:11	6/21/2016 17:14	606170204	Lead	19	15	ppb
067-DIR-05A Directors Office BR Shower	6/16/2016 15:13	6/21/2016 17:14	606170205	Copper	0.0	1.3	ppm
067-DIR-05A Directors Office BR Shower	6/16/2016 15:13	6/21/2016 17:14	606170205	Lead	10	15	ppb
067-GYM-06A Gym Hand Washing Fountain	6/16/2016 15:15	6/21/2016 17:14	606170206	Lead	1	15	ppb
067-GYM-07A Gym Drinking Fountain	6/16/2016 15:17	6/22/2016 13:42	606170207	Copper	0.0	1.3	ppm
067-GYM-07A Gym Drinking Fountain	6/16/2016 15:17	6/22/2016 13:42	606170207	Lead	1	15	ppb
067-LOCK-09A Girls Locker Water Spigot	6/16/2016 15:21	6/22/2016 13:42	606170209	Copper	0.1	1.3	ppm
067-LOCK-09A Girls Locker Water Spigot	6/16/2016 15:21	6/22/2016 13:42	606170209	Lead	17	15	ppb
067-Kitchen Bath-11A Kitchen Bathroom Faucet	6/16/2016 15:12	6/22/2016 13:42	606170211	Copper	0.1	1.3	ppm
067-Kitchen Bath-11A Kitchen Bathroom Faucet	6/16/2016 15:12	6/22/2016 13:42	606170211	Lead	2	15	ppb
067-Kitchen-12A Kitchen Food Prep Sink	6/16/2016 14:55	6/22/2016 13:43	606170212	Copper	0.1	1.3	ppm
067-Kitchen-12A Kitchen Food Prep Sink	6/16/2016 14:55	6/22/2016 13:43	606170212	Lead	2	15	ppb
067-Kitchen-13A Kitchen Food Prep Sink	6/16/2016 14:57	6/22/2016 13:43	606170213	Copper	0.1	1.3	ppm
067-Kitchen-13A Kitchen Food Prep Sink	6/16/2016 14:57	6/22/2016 13:43	606170213	Lead	2	15	ppb
067-Kitchen-14A Kitchen Food Prep Sink	6/16/2016 14:59	6/22/2016 13:43	606170214	Copper	0.1	1.3	ppm
067-Kitchen-14A Kitchen Food Prep Sink	6/16/2016 14:59	6/22/2016 13:43	606170214	Lead	1	15	ppb
067-Kitchen-15A Kitchen Food Prep Sink	6/16/2016 15:01	6/22/2016 13:43	606170215	Copper	0.1	1.3	ppm
067-Kitchen-15A Kitchen Food Prep Sink	6/16/2016 15:01	6/22/2016 13:43	606170215	Lead	16	15	ppb
067-Lunch-16A Cafeteria Drinking Fountain	6/16/2016 15:17	6/22/2016 13:43	606170216	Copper	0.2	1.3	ppm
067-Lunch-16A Cafeteria Drinking Fountain	6/16/2016 15:17	6/22/2016 13:43	606170216	Lead	9	15	ppb
067-HALL-17A Drinking Fountain Outside Cafeteria	6/16/2016 15:19	6/22/2016 13:44	606170217	Copper	0.2	1.3	ppm
067-HALL-17A Drinking Fountain Outside Cafeteria	6/16/2016 15:19	6/22/2016 13:44	606170217	Lead	2	15	ppb
067-WB-19A Women Bathroom Faucet	6/16/2016 15:13	6/22/2016 13:57	606170219	Lead	4	15	ppb
067-MB-20A Men Bathroom Faucet	6/16/2016 15:16	6/22/2016 13:57	606170220	Copper	0.3	1.3	ppm
067-MB-20A Men Bathroom Faucet	6/16/2016 15:16	6/22/2016 13:58	606170220	Lead	2	15	ppb
067-Boys-21A Boys Bathroom Faucet 1	6/16/2016 15:18	6/22/2016 13:58	606170221	Copper	0.3	1.3	ppm
067-Boys-21A Boys Bathroom Faucet 1	6/16/2016 15:18	6/22/2016 13:58	606170221	Lead	2	15	ppb
067-Boys-22A Boys Bathroom Faucet 2	6/16/2016 15:20	6/22/2016 13:58	606170222	Copper	0.3	1.3	ppm
067-Boys-22A Boys Bathroom Faucet 2	6/16/2016 15:20	6/22/2016 13:58	606170222	Lead	3	15	ppb
067-Boys-23A Boys Bathroom Faucet 3	6/16/2016 15:22	6/22/2016 13:58	606170223	Copper	0.4	1.3	ppm
067-Boys-23A Boys Bathroom Faucet 3	6/16/2016 15:22	6/22/2016 13:58	606170223	Lead	2	15	ppb
067-Cust-24A Custodial Sink	6/16/2016 15:36	6/22/2016 14:00	606170224	Copper	0.4	1.3	ppm
067-Cust-24A Custodial Sink	6/16/2016 15:36	6/22/2016 14:00	606170224	Lead	8	15	ppb
067-Girls-25A Girls Bathroom Faucet 1	6/16/2016 15:38	6/22/2016 14:02	606170225	Copper	0.4	1.3	ppm
067-Girls-25A Girls Bathroom Faucet 1	6/16/2016 15:38	6/22/2016 14:02	606170225	Lead	1	15	ppb
067-Girls-26A Girls Bathroom Faucet 2	6/16/2016 15:40	6/22/2016 14:02	606170226	Copper	0.4	1.3	ppm
067-Girls-26A Girls Bathroom Faucet 2	6/16/2016 15:40	6/22/2016 14:02	606170226	Lead	2	15	ppb
067-Girls-27A Girls Bathroom Faucet 3	6/16/2016 15:42	6/22/2016 14:02	606170227	Copper	0.5	1.3	ppm
067-Girls-27A Girls Bathroom Faucet 3	6/16/2016 15:42	6/22/2016 14:02	606170227	Lead	1	15	ppb
067-Girls-28A Girls Bathroom Water Spigot	6/16/2016 15:44	6/22/2016 14:02	606170228	Lead	35	15	ppb
067-117-29A Classroom 117 Drinking Fountain	6/16/2016 15:29	6/22/2016 14:09	606170229	Copper	0.5	1.3	ppm
067-117-29A Classroom 117 Drinking Fountain	6/16/2016 15:29	6/22/2016 14:09	606170229	Lead	0	15	ppb
067-117-30A Classroom 117 Sink Faucet	6/16/2016 15:31	6/22/2016 14:09	606170230	Copper	0.5	1.3	ppm
067-117-30A Classroom 117 Sink Faucet	6/16/2016 15:31	6/22/2016 14:09	606170230	Lead	2	15	ppb
067-118-31A Classroom 118 Drinking Fountain	6/16/2016 15:33	6/22/2016 14:09	606170231	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Penninsula Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
067-118-31A Classroom 118 Drinking Fountain	6/16/2016 15:33	6/22/2016 14:09	606170231	Lead	1	15	ppb
067-118-32A Classroom 118 Sink Faucet	6/16/2016 15:35	6/22/2016 14:09	606170232	Copper	0.5	1.3	ppm
067-118-32A Classroom 118 Sink Faucet	6/16/2016 15:35	6/22/2016 14:09	606170232	Lead	12	15	ppb
067-120-33A Classroom 120 Sink Faucet	6/16/2016 15:41	6/22/2016 14:10	606170233	Copper	0.5	1.3	ppm
067-120-33A Classroom 120 Sink Faucet	6/16/2016 15:41	6/22/2016 14:10	606170233	Lead	2	15	ppb
067-120-34A Classroom 120 Drinking Fountain	6/16/2016 15:45	6/22/2016 14:10	606170234	Copper	0.5	1.3	ppm
067-120-34A Classroom 120 Drinking Fountain	6/16/2016 15:45	6/22/2016 14:10	606170234	Lead	7	15	ppb
067-119-35A Classroom 119 Drinking Fountain	6/16/2016 15:47	6/22/2016 14:10	606170235	Copper	0.5	1.3	ppm
067-119-35A Classroom 119 Drinking Fountain	6/16/2016 15:47	6/22/2016 14:10	606170235	Lead	0	15	ppb
067-119-36A Classroom 119 Sink Faucet	6/16/2016 15:49	6/22/2016 14:10	606170236	Copper	0.6	1.3	ppm
067-119-36A Classroom 119 Sink Faucet	6/16/2016 15:49	6/22/2016 14:10	606170236	Lead	5	15	ppb
067-121-37A Classroom 121 Drinking Fountain	6/16/2016 15:51	6/22/2016 14:10	606170237	Copper	0.6	1.3	ppm
067-121-37A Classroom 121 Drinking Fountain	6/16/2016 15:51	6/22/2016 14:10	606170237	Lead	0	15	ppb
067-121-38A Classroom 121 Sink Faucet	6/16/2016 15:53	6/22/2016 14:11	606170238	Copper	0.6	1.3	ppm
067-121-38A Classroom 121 Sink Faucet	6/16/2016 15:53	6/22/2016 14:11	606170238	Lead	4	15	ppb
067-122-39A Classroom 122 Sink Faucet 1	6/16/2016 15:55	6/22/2016 14:13	606170239	Copper	0.6	1.3	ppm
067-122-39A Classroom 122 Sink Faucet 1	6/16/2016 15:55	6/22/2016 14:13	606170239	Lead	4	15	ppb
067-122-40A Classroom 122 Sink Faucet 2	6/16/2016 15:57	6/22/2016 14:13	606170240	Lead	5	15	ppb
067-122-41A Classroom 122 Sink Faucet 3	6/16/2016 15:59	6/22/2016 14:13	606170241	Lead	2	15	ppb
067-122-42A Classroom 122 Eyewash	6/16/2016 16:01	6/22/2016 14:13	606170242	Lead	14	15	ppb
067-123-43A Classroom 123 Sink Faucet	6/16/2016 16:08	6/22/2016 14:14	606170243	Lead	6	15	ppb
067-124-44A Classroom 124 Drinking Fountain	6/16/2016 16:10	6/22/2016 14:14	606170244	Lead	1	15	ppb
067-124-45A Classroom 124 Sink Faucet	6/16/2016 16:12	6/22/2016 14:14	606170245	Lead	9	15	ppb
067-125-46A Classroom 125 Sink Faucet	6/16/2016 16:14	6/22/2016 14:14	606170246	Copper	0.6	1.3	ppm
067-125-46A Classroom 125 Sink Faucet	6/16/2016 16:14	6/22/2016 14:14	606170246	Lead	1	15	ppb
067-125-47A Classroom 125 Eyewash	6/16/2016 16:16	6/22/2016 14:14	606170247	Copper	0.6	1.3	ppm
067-125-47A Classroom 125 Eyewash	6/16/2016 16:16	6/22/2016 14:14	606170247	Lead	8	15	ppb
067-125-48A Classroom 125 Sink Faucet	6/16/2016 16:18	6/22/2016 14:14	606170248	Lead	1	15	ppb
067-126-49A Classroom 126 Drinking Fountain	6/16/2016 16:34	6/22/2016 14:17	606170249	Copper	0.7	1.3	ppm
067-126-49A Classroom 126 Drinking Fountain	6/16/2016 16:34	6/22/2016 14:17	606170249	Lead	1	15	ppb
067-126-50A Classroom 126 Sink Faucet	6/16/2016 16:36	6/22/2016 14:17	606170250	Copper	0.7	1.3	ppm
067-126-50A Classroom 126 Sink Faucet	6/16/2016 16:36	6/22/2016 14:17	606170250	Lead	2	15	ppb
067-127-51A Classroom 127 Drinking Fountain	6/16/2016 16:38	6/22/2016 14:17	606170251	Copper	0.7	1.3	ppm
067-127-51A Classroom 127 Drinking Fountain	6/16/2016 16:38	6/22/2016 14:17	606170251	Lead	1	15	ppb
067-127-52A Classroom 127 Sink Faucet	6/16/2016 16:40	6/22/2016 14:17	606170252	Copper	0.7	1.3	ppm
067-127-52A Classroom 127 Sink Faucet	6/16/2016 16:40	6/22/2016 14:17	606170252	Lead	3	15	ppb
067-Girls-53A Girls Bathroom Faucet	6/16/2016 16:36	6/22/2016 14:18	606170253	Copper	0.7	1.3	ppm
067-Girls-53A Girls Bathroom Faucet	6/16/2016 16:36	6/22/2016 14:18	606170253	Lead	0	15	ppb
067-Girls-54A Girls Bathroom Faucet	6/16/2016 16:38	6/22/2016 14:18	606170254	Copper	0.7	1.3	ppm
067-Girls-54A Girls Bathroom Faucet	6/16/2016 16:38	6/22/2016 14:18	606170254	Lead	2	15	ppb
067-CUST-55A Custodial Sink Faucet	6/16/2016 17:52	6/22/2016 14:18	606170255	Copper	0.7	1.3	ppm
067-CUST-55A Custodial Sink Faucet	6/16/2016 17:52	6/22/2016 14:18	606170255	Lead	27	15	ppb
067-Boys-56A Boys Bathroom Faucet	6/16/2016 16:40	6/22/2016 14:18	606170256	Copper	0.7	1.3	ppm
067-Boys-56A Boys Bathroom Faucet	6/16/2016 16:40	6/22/2016 14:18	606170256	Lead	1	15	ppb
067-Boys-57A Boys Bathroom Faucet	6/16/2016 16:42	6/22/2016 14:18	606170257	Copper	0.7	1.3	ppm
067-Boys-57A Boys Bathroom Faucet	6/16/2016 16:42	6/22/2016 14:18	606170257	Lead	2	15	ppb
067-129-58A Classroom 129 Sink Faucet	6/16/2016 16:44	6/22/2016 14:18	606170258	Copper	0.8	1.3	ppm
067-129-58A Classroom 129 Sink Faucet	6/16/2016 16:44	6/22/2016 14:18	606170258	Lead	1	15	ppb
067-129-59A Classroom 129 Eyewash	6/16/2016 16:46	6/22/2016 14:20	606170259	Copper	0.8	1.3	ppm
067-129-59A Classroom 129 Eyewash	6/16/2016 16:46	6/22/2016 14:20	606170259	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Penninsula Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
067-129-60A Classroom 129 Sink Faucet	6/16/2016 16:48	6/22/2016 14:21	606170260	Copper	0.8	1.3	ppm
067-129-60A Classroom 129 Sink Faucet	6/16/2016 16:48	6/22/2016 14:21	606170260	Lead	1	15	ppb
067-Office-61A Office Workroom Sink Faucet	6/16/2016 15:30	6/22/2016 14:21	606170261	Copper	0.8	1.3	ppm
067-Office-61A Office Workroom Sink Faucet	6/16/2016 15:30	6/22/2016 14:21	606170261	Lead	3	15	ppb
067-Office-62A Office Workroom Water Cooler	6/16/2016 16:32	6/22/2016 14:21	606170262	Copper	0.8	1.3	ppm
067-Office-62A Office Workroom Water Cooler	6/16/2016 16:32	6/22/2016 14:21	606170262	Lead	ND	15	ppb
067-Health-63A Health Clinic Sink Faucet	6/16/2016 17:02	6/22/2016 14:21	606170263	Copper	0.9	1.3	ppm
067-Health-63A Health Clinic Sink Faucet	6/16/2016 17:02	6/22/2016 14:21	606170263	Lead	2	15	ppb
067-Health-64A Health Clinic Bathroom Faucet	6/16/2016 17:04	6/22/2016 14:21	606170264	Copper	0.0	1.3	ppm
067-Health-64A Health Clinic Bathroom Faucet	6/16/2016 17:04	6/22/2016 14:21	606170264	Lead	27	15	ppb
067-Health-65A Health Clinic Sink Faucet	6/16/2016 17:06	6/22/2016 14:21	606170265	Copper	0.0	1.3	ppm
067-Health-65A Health Clinic Sink Faucet	6/16/2016 17:06	6/22/2016 14:21	606170265	Lead	14	15	ppb
067-116-66A Library 116 Drinking Fountain	6/16/2016 17:08	6/22/2016 14:21	606170266	Copper	0.0	1.3	ppm
067-116-66A Library 116 Drinking Fountain	6/16/2016 17:08	6/22/2016 14:21	606170266	Lead	0	15	ppb
067-116-67A Library 116 Sink Faucet	6/16/2016 17:10	6/22/2016 14:21	606170267	Copper	0.0	1.3	ppm
067-116-67A Library 116 Sink Faucet	6/16/2016 17:10	6/22/2016 14:21	606170267	Lead	4	15	ppb
067-115-68A Classroom 115 Drinking Fountain	6/16/2016 16:57	6/22/2016 14:22	606170268	Copper	0.0	1.3	ppm
067-115-68A Classroom 115 Drinking Fountain	6/16/2016 16:57	6/22/2016 14:22	606170268	Lead	1	15	ppb
067-115-69A Classroom 115 Sink Faucet	6/16/2016 16:59	6/23/2016 9:05	606170269	Copper	0.0	1.3	ppm
067-115-69A Classroom 115 Sink Faucet	6/16/2016 16:59	6/23/2016 9:05	606170269	Lead	8	15	ppb
067-113-70A Classroom 113 Drinking Fountain	6/16/2016 17:01	6/23/2016 9:05	606170270	Copper	0.0	1.3	ppm
067-113-70A Classroom 113 Drinking Fountain	6/16/2016 17:01	6/23/2016 9:05	606170270	Lead	0	15	ppb
067-113-71A Classroom 113 Sink Faucet	6/16/2016 17:03	6/23/2016 9:06	606170271	Copper	0.0	1.3	ppm
067-113-71A Classroom 113 Sink Faucet	6/16/2016 17:03	6/23/2016 9:06	606170271	Lead	2	15	ppb
067-Girls-72A Girls Bathroom Faucet	6/16/2016 17:05	6/23/2016 9:06	606170272	Copper	0.0	1.3	ppm
067-Girls-72A Girls Bathroom Faucet	6/16/2016 17:05	6/23/2016 9:06	606170272	Lead	1	15	ppb
067-CUST-73A Custodial Sink Faucet	6/16/2016 17:07	6/23/2016 9:06	606170273	Copper	0.0	1.3	ppm
067-CUST-73A Custodial Sink Faucet	6/16/2016 17:07	6/23/2016 9:06	606170273	Lead	11	15	ppb
067-Boys-74A Boys Bathroom Faucet 1	6/16/2016 17:09	6/23/2016 9:06	606170274	Copper	0.0	1.3	ppm
067-Boys-74A Boys Bathroom Faucet 1	6/16/2016 17:09	6/23/2016 9:06	606170274	Lead	2	15	ppb
067-Boys-75A Boys Bathroom Faucet 2	6/16/2016 17:11	6/23/2016 9:07	606170275	Copper	0.0	1.3	ppm
067-Boys-75A Boys Bathroom Faucet 2	6/16/2016 17:11	6/23/2016 9:07	606170275	Lead	0	15	ppb
067-HALL-76A Drinking Fountain Outside 113	6/16/2016 17:15	6/23/2016 9:07	606170276	Copper	0.0	1.3	ppm
067-HALL-76A Drinking Fountain Outside 113	6/16/2016 17:15	6/23/2016 9:07	606170276	Lead	0	15	ppb
067-112-77A Classroom 112 Drinking Fountain	6/16/2016 17:17	6/23/2016 9:07	606170277	Copper	0.0	1.3	ppm
067-112-77A Classroom 112 Drinking Fountain	6/16/2016 17:17	6/23/2016 9:07	606170277	Lead	1	15	ppb
067-112-78A Classroom 112 Sink Faucet	6/16/2016 17:19	6/23/2016 9:07	606170278	Copper	0.0	1.3	ppm
067-112-78A Classroom 112 Sink Faucet	6/16/2016 17:19	6/23/2016 9:07	606170278	Lead	16	15	ppb
067-111-79A Classroom 111 Drinking Fountain	6/16/2016 17:21	6/22/2016 14:36	606170279	Copper	0.0	1.3	ppm
067-111-79A Classroom 111 Drinking Fountain	6/16/2016 17:21	6/22/2016 14:36	606170279	Lead	0	15	ppb
067-111-80A Classroom 111 Sink Faucet	6/16/2016 17:23	6/22/2016 14:49	606170280	Copper	0.0	1.3	ppm
067-111-80A Classroom 111 Sink Faucet	6/16/2016 17:23	6/22/2016 14:49	606170280	Lead	2	15	ppb
067-110-81A Classroom 110 Drinking Fountain	6/16/2016 17:25	6/22/2016 14:49	606170281	Copper	0.0	1.3	ppm
067-110-81A Classroom 110 Drinking Fountain	6/16/2016 17:25	6/22/2016 14:49	606170281	Lead	1	15	ppb
067-110-82A Classroom 110 Sink Faucet	6/16/2016 17:27	6/22/2016 14:49	606170282	Copper	0.0	1.3	ppm
067-110-82A Classroom 110 Sink Faucet	6/16/2016 17:27	6/22/2016 14:49	606170282	Lead	10	15	ppb
067-109-83A Classroom 109 Sink Faucet	6/16/2016 17:15	6/22/2016 14:49	606170283	Copper	0.0	1.3	ppm
067-109-83A Classroom 109 Sink Faucet	6/16/2016 17:15	6/22/2016 14:49	606170283	Lead	2	15	ppb
067-108-84A Classroom 108 Drinking Fountain	6/16/2016 17:17	6/22/2016 14:49	606170284	Copper	0.0	1.3	ppm
067-108-84A Classroom 108 Drinking Fountain	6/16/2016 17:17	6/22/2016 14:49	606170284	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Penninsula Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
067-108-85A Classroom 108 Sink Faucet	6/16/2016 17:19	6/22/2016 14:49	606170285	Copper	0.0	1.3	ppm
067-108-85A Classroom 108 Sink Faucet	6/16/2016 17:19	6/22/2016 14:49	606170285	Lead	4	15	ppb
067-107-86A Classroom 107 Drinking Fountain	6/16/2016 17:21	6/22/2016 14:49	606170286	Copper	0.0	1.3	ppm
067-107-86A Classroom 107 Drinking Fountain	6/16/2016 17:21	6/22/2016 14:49	606170286	Lead	1	15	ppb
067-107-87A Classroom 107 Sink Faucet	6/16/2016 17:23	6/22/2016 14:49	606170287	Copper	0.0	1.3	ppm
067-107-87A Classroom 107 Sink Faucet	6/16/2016 17:23	6/22/2016 14:49	606170287	Lead	4	15	ppb
067-HALL-88A Drinking Fountain Outside 105	6/16/2016 17:25	6/22/2016 14:49	606170288	Copper	0.0	1.3	ppm
067-HALL-88A Drinking Fountain Outside 105	6/16/2016 17:25	6/22/2016 14:49	606170288	Lead	2	15	ppb
067-106-89A Classroom 106 Drinking Fountain	6/16/2016 17:27	6/22/2016 16:21	606170289	Copper	0.0	1.3	ppm
067-106-89A Classroom 106 Drinking Fountain	6/16/2016 17:27	6/22/2016 16:21	606170289	Lead	0	15	ppb
067-106-90A Classroom 106 Sink Faucet	6/16/2016 17:29	6/22/2016 16:21	606170290	Copper	0.0	1.3	ppm
067-106-90A Classroom 106 Sink Faucet	6/16/2016 17:29	6/22/2016 16:21	606170290	Lead	3	15	ppb
067-105-91A Classroom 105 Sink Faucet	6/16/2016 17:39	6/22/2016 16:21	606170291	Copper	0.0	1.3	ppm
067-105-91A Classroom 105 Sink Faucet	6/16/2016 17:39	6/22/2016 16:21	606170291	Lead	14	15	ppb
067-105-92A Classroom 105 Drinking Fountain	6/16/2016 17:41	6/22/2016 16:24	606170292	Copper	0.0	1.3	ppm
067-105-92A Classroom 105 Drinking Fountain	6/16/2016 17:41	6/22/2016 16:24	606170292	Lead	2	15	ppb
067-105B-93A Classroom 105 Bathroom Sink	6/16/2016 17:43	6/22/2016 16:24	606170293	Copper	0.0	1.3	ppm
067-105B-93A Classroom 105 Bathroom Sink	6/16/2016 17:43	6/22/2016 16:24	606170293	Lead	4	15	ppb
067-105B-95A Classroom 105 Bathroom Sink	6/16/2016 17:47	6/22/2016 16:24	606170295	Copper	0.0	1.3	ppm
067-105B-95A Classroom 105 Bathroom Sink	6/16/2016 17:47	6/22/2016 16:24	606170295	Lead	5	15	ppb
067-104-96A Classroom 104 Drinking Fountain	6/16/2016 17:49	6/22/2016 16:24	606170296	Copper	0.0	1.3	ppm
067-104-96A Classroom 104 Drinking Fountain	6/16/2016 17:49	6/22/2016 16:24	606170296	Lead	2	15	ppb
067-104-97A Classroom 104 Sink Faucet	6/16/2016 17:51	6/22/2016 16:24	606170297	Copper	0.0	1.3	ppm
067-104-97A Classroom 104 Sink Faucet	6/16/2016 17:51	6/22/2016 16:24	606170297	Lead	6	15	ppb
067-103-98A Classroom 103 Drinking Fountain	6/16/2016 17:53	6/22/2016 16:24	606170298	Copper	0.0	1.3	ppm
067-103-98A Classroom 103 Drinking Fountain	6/16/2016 17:53	6/22/2016 16:24	606170298	Lead	1	15	ppb
067-103-99A Classroom 103 Sink Faucet	6/16/2016 17:55	6/22/2016 16:24	606170299	Copper	0.0	1.3	ppm
067-103-99A Classroom 103 Sink Faucet	6/16/2016 17:55	6/22/2016 16:24	606170299	Lead	5	15	ppb
067-Boys-100A Boys Bathroom Sink Faucet 1	6/16/2016 16:21	6/22/2016 16:25	6061702100	Copper	0.0	1.3	ppm
067-Boys-100A Boys Bathroom Sink Faucet 1	6/16/2016 16:21	6/22/2016 16:25	6061702100	Lead	0	15	ppb
067-Boys-101A Boys Bathroom Faucet 2	6/16/2016 16:23	6/22/2016 16:25	6061702101	Copper	0.0	1.3	ppm
067-Boys-101A Boys Bathroom Faucet 2	6/16/2016 16:23	6/22/2016 16:25	6061702101	Lead	1	15	ppb
067-Boys-102A Boys Bathroom Faucet 3	6/16/2016 16:25	6/22/2016 16:26	6061702102	Copper	0.0	1.3	ppm
067-Boys-102A Boys Bathroom Faucet 3	6/16/2016 16:25	6/22/2016 16:26	6061702102	Lead	0	15	ppb
067-102-103A Classroom 102 Drinking Fountain	6/16/2016 16:27	6/22/2016 16:26	6061702103	Copper	0.0	1.3	ppm
067-102-103A Classroom 102 Drinking Fountain	6/16/2016 16:27	6/22/2016 16:26	6061702103	Lead	0	15	ppb
067-102-104A Classroom 102 Sink Faucet	6/16/2016 16:29	6/22/2016 16:26	6061702104	Copper	0.0	1.3	ppm
067-102-104A Classroom 102 Sink Faucet	6/16/2016 16:29	6/22/2016 16:26	6061702104	Lead	3	15	ppb
067-100-105A Classroom 100 Sink Faucet	6/16/2016 16:21	6/22/2016 16:26	6061702105	Copper	0.0	1.3	ppm
067-100-105A Classroom 100 Sink Faucet	6/16/2016 16:21	6/22/2016 16:26	6061702105	Lead	3	15	ppb
067-100-106A Classroom 100 Drinking Fountain	6/16/2016 16:33	6/22/2016 16:26	6061702106	Copper	0.0	1.3	ppm
067-100-106A Classroom 100 Drinking Fountain	6/16/2016 16:33	6/22/2016 16:26	6061702106	Lead	2	15	ppb
067-Girls-107A Girls Bathroom Faucet 1	6/16/2016 16:35	6/22/2016 16:26	6061702107	Copper	0.0	1.3	ppm
067-Girls-107A Girls Bathroom Faucet 1	6/16/2016 16:35	6/22/2016 16:26	6061702107	Lead	1	15	ppb
067-Girls-108A Girls Bathroom Faucet 2	6/16/2016 16:37	6/22/2016 16:26	6061702108	Copper	0.0	1.3	ppm
067-Girls-108A Girls Bathroom Faucet 2	6/16/2016 16:37	6/22/2016 16:26	6061702108	Lead	2	15	ppb
067-Girls-109A Girls Bathroom Faucet 3	6/16/2016 16:39	6/22/2016 16:26	6061702109	Copper	0.0	1.3	ppm
067-Girls-109A Girls Bathroom Faucet 3	6/16/2016 16:39	6/22/2016 16:26	6061702109	Lead	1	15	ppb
067-OUT-110A Outdoor Courtyard Water Spigot 1	6/16/2016 18:19	6/22/2016 16:27	6061702110	Copper	0.0	1.3	ppm
067-OUT-110A Outdoor Courtyard Water Spigot 1	6/16/2016 18:19	6/22/2016 16:27	6061702110	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Penninsula Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
067-OUT-111A Outdoor Courtyard Water Spigot 2	6/16/2016 18:21	6/22/2016 16:27	6061702111	Copper	0.0	1.3	ppm
067-OUT-111A Outdoor Courtyard Water Spigot 2	6/16/2016 18:21	6/22/2016 16:27	6061702111	Lead	0	15	ppb
067-OUT-112A Outdoor Courtyard Water Spigot 3	6/16/2016 18:23	6/22/2016 16:27	6061702112	Copper	0.0	1.3	ppm
067-OUT-112A Outdoor Courtyard Water Spigot 3	6/16/2016 18:23	6/22/2016 16:27	6061702112	Lead	1	15	ppb
067-OUT-113A Outdoor Water Spigot 4	6/16/2016 18:37	6/22/2016 16:32	6061702113	Copper	0.0	1.3	ppm
067-OUT-114A Outdoor Water Spigot 5	6/16/2016 18:39	6/22/2016 16:28	6061702114	Copper	0.0	1.3	ppm
067-OUT-114A Outdoor Water Spigot 5	6/16/2016 18:39	6/22/2016 16:28	6061702114	Lead	27	15	ppb
067-OUT-115A Outdoor Water Spigot 6	6/16/2016 18:41	6/22/2016 16:28	6061702115	Copper	0.0	1.3	ppm
067-OUT-115A Outdoor Water Spigot 6	6/16/2016 18:41	6/22/2016 16:28	6061702115	Lead	37	15	ppb
067-OUT-116A Outdoor Water Spigot 7	6/16/2016 18:43	6/22/2016 16:36	6061702116	Copper	0.0	1.3	ppm
067-OUT-117A Outdoor Water Spigot 8	6/16/2016 18:11	6/22/2016 16:36	6061702117	Copper	0.0	1.3	ppm
067-OUT-118A Outdoor Water Spigot 9	6/16/2016 18:13	6/22/2016 16:36	6061702118	Copper	0.0	1.3	ppm
067-OUT-118A Outdoor Water Spigot 9	6/16/2016 18:13	6/22/2016 16:36	6061702118	Lead	40	15	ppb
067-OUT-119A Outdoor Water Spigot 10	6/16/2016 18:15	6/23/2016 9:17	6061702119	Copper	0.0	1.3	ppm
067-OUT-119A Outdoor Water Spigot 10	6/16/2016 18:15	6/23/2016 9:17	6061702119	Lead	23	15	ppb
067-OUT-120A Outdoor Water Spigot 11	6/16/2016 18:17	6/22/2016 16:47	6061702120	Copper	0.0	1.3	ppm
067-OUT-120A Outdoor Water Spigot 11	6/16/2016 18:17	6/22/2016 16:47	6061702120	Lead	20	15	ppb
067-OUT-121A Outdoor Water Spigot 12	6/16/2016 18:35	6/22/2016 16:47	6061702121	Copper	0.0	1.3	ppm
067-101-122A Classroom 101 Sink Faucet	6/16/2016 16:27	6/22/2016 16:47	6061702122	Copper	0.0	1.3	ppm
067-101-122A Classroom 101 Sink Faucet	6/16/2016 16:27	6/22/2016 16:47	6061702122	Lead	2	15	ppb
067-101-123A Classroom 101 Drinking Fountain	6/16/2016 16:29	6/22/2016 16:47	6061702123	Copper	0.0	1.3	ppm
067-101-123A Classroom 101 Drinking Fountain	6/16/2016 16:29	6/22/2016 16:47	6061702123	Lead	0	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance action levels.