

## *Update: Portland Public Schools Radon Testing Program Results*

<i>NAME</i>	<i>Room Number</i>	<i>Start date</i>	<i>Finish date</i>	<i>Result (pCi/l)</i>	<i>Type of Test*</i>	<i>Comments</i>
<i>SYLVAN</i>						
	10	11/21/2001	6/3/2002	0.1	Alpha track	GERMAN AMERICAN SCHOOL
	107	11/21/2001	6/3/2002	0.1	Alpha track	GERMAN AMERICAN SCHOOL
	109	11/21/2001	6/3/2002	0.2	Alpha track	GERMAN AMERICAN SCHOOL
	19	11/21/2001	6/3/2002	0.1	Alpha track	GERMAN AMERICAN SCHOOL
	21	11/21/2001	6/3/2002	0.4	Alpha track	
	9	11/21/2001	6/3/2002	0.1	Alpha track	GERMAN AMERICAN SCHOOL
	Blank	11/9/2001		0.5	Alpha track	
	Common room	11/21/2001	6/3/2002	0.3	Alpha track	GERMAN AMERICAN SCHOOL
	Compressor	11/21/2001	6/17/2002	3.4	Alpha track	GERMAN AMERICAN SCHOOL
	Gym	11/21/2001	6/3/2002	0.4	Alpha track	GERMAN AMERICAN SCHOOL
	Kitchen	11/21/2001	6/3/2002	0.2	Alpha track	GERMAN AMERICAN SCHOOL

*Samples for 2002 Baseline: 11*

### END RESULTS FOR SYLVAN

*\*Alpha Track monitors provide the long term average radon level 24 hours a day, 7 days a week for 6 - 7 months. That includes time when schools are closed and the ventilation system is off (nights, weekends and holidays).*

*\*Continuous monitors provide average hourly radon levels over 3 - 4 days. They allow us to see how the ventilation system affects the radon level. Continuous monitors were placed in all locations where Alpha Track monitors had a result at 4.0 pCi/l or higher.*

---

## *Update: Portland Public Schools Radon Testing Program Results*

<i>NAME</i>	<i>Room Number</i>	<i>Start date</i>	<i>Finish date</i>	<i>Result (pCi/l)</i>	<i>Type of Test*</i>	<i>Comments</i>
-------------	--------------------	-------------------	--------------------	-----------------------	----------------------	-----------------

---

*\*Alpha Track monitors provide the long term average radon level 24 hours a day, 7 days a week for 6 - 7 months. That includes time when schools are closed and the ventilation system is off (nights, weekends and holidays).*

*\*Continuous monitors provide average hourly radon levels over 3 - 4 days. They allow us to see how the ventilation system affects the radon level. Continuous monitors were placed in all locations where Alpha Track monitors had a result at 4.0 pCi/l or higher.*