

Baseline Start	Assigned Date	Task Status	Assign Status	Task Description
07/11/2016 06:23:20	07/11/2016 06:23:20	Completed	Completed	Tubman the door on the generator can be opened even in the locked position-not secured
07/11/2016 13:10:58	07/11/2016 13:10:58	Completed	Completed	Tubman -graffiti on the south side of the roof and on the chimney stack
07/11/2016 13:10:58	07/11/2016 13:10:58	Completed	Completed	Tubman -graffiti on the south side of the roof and on the chimney stack
07/11/2016 13:10:58	07/11/2016 13:10:58	Completed	Completed	Tubman -graffiti on the south side of the roof and on the chimney stack
07/11/2016 13:55:42	07/11/2016 13:55:42	Completed	Completed	Tubman - exit door on the NW side of the building is not locking all the way (north door)
07/12/2016 13:01:59	07/12/2016 13:02:02	Active	Unassigned	Air flow is too weak in room #101. Complaints of being too hot...90's. All the fan rooms are running.
07/19/2016 14:13:57	07/19/2016 14:14:00	Completed	Completed	Sheetmetal - Fabricate expanded metal for Rick Bailey- Tubman Head Start program Rm 118
07/26/2016 10:58:27	07/26/2016 10:58:30	Completed	Completed	Please inspect the records of the following schools to see if there smoke test is up to date my records show: Todd & Bert - 7/26/2016HOLIDAY ANNEX LAST TEST 6/9 /14TUBMAN 8/11/14MADISON 1/12/14SABIN 8/14SELLWOOD 8/27/15FOSREST PARK 10/13/15
07/26/2016 10:58:27	07/26/2016 10:58:30	Completed	Completed	Please inspect the records of the following schools to see if there smoke test is up to date my records show: Todd & Bert - 7/26/2016HOLIDAY ANNEX LAST TEST 6/9 /14TUBMAN 8/11/14MADISON 1/12/14SABIN 8/14SELLWOOD 8/27/15FOSREST PARK 10/13/15
08/01/2016 07:59:23	08/01/2016 07:59:23	Completed	Completed	Tubman - Boys restroom 200C has a leak coming from the ceiling at the northwest part. Ceiling tiles are falling down.For JS
08/04/2016 13:00:51	08/04/2016 12:50:54	Completed	Completed	Please have the fire alarm guys meet with KONE on 8/16/16 at 8 am at Holiday center annex/div st,then Sabin, Tubman, Sellwood or however order they feel is most efficient:this will ensure we are up to date on these schools this year
08/04/2016 13:00:51	08/04/2016 12:50:54	Completed	Completed	Please have the fire alarm guys meet with KONE on 8/16/16 at 8 am at Holiday center annex/div st,then Sabin, Tubman, Sellwood or however order they feel is most efficient:this will ensure we are up to date on these schools this year
08/16/2016 08:00:46	08/16/2016 07:20:50	Retired	Unassigned	Please have the fire alarm guys meet with KONE on 8/16/16 at 8 am at Holiday center annex/div st,then Sabin, Tubman, Sellwood or however order they feel is most efficient:this will ensure we are up to date on these schools this yearfor billing for KY
08/22/2016 14:37:11	08/22/2016 14:37:11	Completed	Completed	Tubman - breaker is out in closet 228A panel box 2-A, breaker 29. There is also one on the 2nd floor in SE hallway breaker is 4-BJae n Sam 8/26/2016 SM
08/22/2016 14:37:11	08/22/2016 14:37:11	Completed	Completed	Tubman - breaker is out in closet 228A panel box 2-A, breaker 29. There is also one on the 2nd floor in SE hallway breaker is 4-BJae n Sam 8/26/2016 SM
08/23/2016 13:33:26	08/23/2016 13:33:26	Completed	Completed	Tubman - The fan in classroom #224 does not turn on with the wall switch or the pull chain.Jae n Sam 8/26/2016 SM
08/23/2016 13:33:26	08/23/2016 13:33:26	Completed	Completed	Tubman - The fan in classroom #224 does not turn on with the wall switch or the pull chain.Jae n Sam 8/26/2016 SM
08/24/2016 08:25:16	08/24/2016 08:25:16	Completed	Completed	Tubman- the hot water for the sink and dishwasher is not working- water not coming out-trickelingFor MM
08/29/2016 14:12:54	08/29/2016 14:12:54	Completed	Completed	Tubman - girls restroom #213 water comes up through the drain when the toilets are flushed Marty
08/30/2016 11:12:04	08/30/2016 11:12:07	Completed	Completed	Tubman- Repair Ceiling Tile in restroom 200C- Oringional W/O for Mech.Tubman - Boys restroom 200C has a leak coming from the ceiling at the northwest part. Ceiling tiles are falling down.
09/06/2016 08:59:58	09/06/2016 08:59:58	Completed	Completed	Tubman -Main office 103A: The northeast of corner of the ceiling is leaking. The leak is contained. See notes roofer says clog drain.
09/06/2016 08:59:58	09/06/2016 08:59:58	Completed	Completed	Tubman -Main office 103A: The northeast of corner of the ceiling is leaking. The leak is contained. See notes roofer says clog drain.
09/14/2016 14:25:54	09/14/2016 14:25:54	Completed	Completed	Tubman - The drain in the kitchen is not draining. This is a floor drain.Dave D 9/15/2016 JJT
09/15/2016 07:00:00	09/15/2016 06:50:08	Completed	Completed	Tubman - Asst plumber with The drain in the kitchen is not draining. This is a floor drain.Doug, 9/15/2016 JJT
09/19/2016 09:39:33	09/19/2016 09:39:33	Completed	Completed	Tubman - There is graffiti on the basketball court wall on the east side of the court. the surface is concrete.
10/03/2016 07:12:43	10/03/2016 07:12:43	Completed	Completed	Tubman - water is gushing out of a drain pipe in the boiler pit Beach
10/04/2016 09:15:46	10/04/2016 09:15:46	Completed	Completed	Tubman -There is a roof leak in the locker room area by the locker baskets. There is a big bubble of water in the plaster that could burst.
10/04/2016 09:15:46	10/04/2016 09:15:46	Completed	Completed	Tubman -There is a roof leak in the locker room area by the locker baskets. There is a big bubble of water in the plaster that could burst.
10/06/2016 08:13:02	10/06/2016 08:13:02	Completed	Completed	Tubman - Pre-K Classrooms 118 & 115 are to hot. The temperature is over 80 degrees.Brian 10/6/2016 ww
10/10/2016 06:29:19	10/10/2016 06:29:19	Completed	Completed	Tubman - the roof drain needs to be snaked above room 103A- creating flooding inside the building Dave D. 10/10/2016 ww
10/10/2016 08:00:46	10/10/2016 07:45:49	Completed	Completed	Assist the plumber at Tubman - the roof drain needs to be snaked above room 103A- creating flooding inside the building Doug 10/10/2016 ww
10/12/2016 11:41:49	10/12/2016 11:41:51	Completed	Completed	FYI, we have some wet and musty smelling carpet squares in the main office at Tubman which need to be removed as soon as possible. I would suggest waiting to replace the tiles until after we are sure the leak is repaired. Thanks,Joel
10/13/2016 11:43:18	10/13/2016 11:43:18	Completed	Completed	Tubman - roof leak in a classroom in the library on the north side and also in the boy's locker room #162A And in boys restroom 200C located in the NW corner of the restroom
10/13/2016 11:43:18	10/13/2016 11:43:18	Completed	Completed	Tubman - roof leak in a classroom in the library on the north side and also in the boy's locker room #162A And in boys restroom 200C located in the NW corner of the restroom
10/17/2016 10:06:28	10/17/2016 10:06:32	Active	Assigned	Custodial closet door #108-A, plaster crumbling from inside of door. This door has been worked on in the past. Screws were driven in the side paneling to hold in place. Was told would get a new door. High priority
10/17/2016 10:06:28	10/17/2016 10:06:32	Active	Assigned	Custodial closet door #108-A, plaster crumbling from inside of door. This door has been worked on in the past. Screws were driven in the side paneling to hold in place. Was told would get a new door. High priority
10/25/2016 09:50:29	10/25/2016 09:50:32	Active	Assigned	Fix handrail.
10/25/2016 09:50:29	10/25/2016 09:50:32	Active	Assigned	Fix handrail.
10/28/2016 09:28:40	10/28/2016 09:28:40	Completed	Completed	Tubman - ADA exterior door is not working. You can hear it trying to work, but it will not open.I opened the operator and found a broken drive chain. SM
11/01/2016 11:12:23	11/01/2016 11:12:26	Active	Assigned	Please patch/repair plaster hole in ceiling of boiler room, approximately 18" X 9". Tested negative for asbestos.
11/15/2016 08:32:18	11/15/2016 08:32:18	Completed	Completed	Tubman the doors on the elevator will not open Kone called on the 11/15/2016 9:35 AM REQ 12027206 JJT
11/18/2016 14:52:45	11/18/2016 14:52:48	Active	Unassigned	drinking fountain across from hallway custodial closet #177, is coming apart from the wall. Plaster from the right side is coming apart.
11/21/2016 07:59:05	11/21/2016 07:59:05	Completed	Completed	Tubman - shut off valve above the door of classroom 119 is dripping-dark brown syrupy substance (no odor)Cliff 11/22/2016 ww
11/21/2016 10:11:48	11/21/2016 10:11:48	Active	Assigned	Tubman /Faubion- pipe burst inside room 153 in the ceilingJason w , Bill 11/21/2016 JJT
11/30/2016 10:34:08	11/30/2016 10:34:08	Completed	Completed	Tubman- pipe leak in room 153 contained with a bucketBrad 11/30/2016 ww
12/06/2016 07:44:44	12/06/2016 07:44:44	Retired	Unassigned	Tubman -The fans in fan room #2 next to room #153 are not running.

12/06/2016 09:44:45	12/06/2016 09:44:45	Completed	Completed	Tubman - air damper in the loft of the library is stuck open making the library very cold (room 100) Newt 12/12/2016 ww
12/07/2016 08:00:20	12/07/2016 05:45:22	Completed	Completed	Boiler #1 won't turn on.bridger,brooklyn, reike,woodlawn ,tubman Cliff,newt,12/09/2016 JJT
12/07/2016 08:00:20	12/07/2016 05:45:22	Completed	Completed	Boiler #1 won't turn on.bridger,brooklyn, reike,woodlawn ,tubman Cliff,newt,12/09/2016 JJT
12/12/2016 09:01:46	12/12/2016 09:01:46	Retired	Unassigned	Tubman - The fans in the gym keep turning on and off for not known reason. Tubman - There is a pipe leak on the right side of boiler #2 Danny 12/14/2016 JJT
12/16/2016 11:30:27	12/16/2016 11:30:29	Active	Unassigned	Need "PPS parking only" sign to be reinforced on concrete pole with black tie reinforcers. This is on the Tubman parking lot across the street from the main building on Flint street. Tubman - The outlet to the cooler to the left of the stage in the cafeteria is not working.
12/19/2016 10:06:13	12/19/2016 10:06:13	Completed	Completed	John 1-5-2017
01/03/2017 09:55:53	01/03/2017 09:55:53	Completed	Completed	Tubman - Pipe leak in room 217 (ceiling tiles fell) - the Custodian has it contained. Shuan 04/26/2017 JJT
01/03/2017 09:55:53	01/03/2017 09:55:53	Completed	Completed	Tubman - Pipe leak in room 217 (ceiling tiles fell) - the Custodian has it contained. Shuan 04/26/2017 JJT
01/04/2017 15:08:20	01/04/2017 15:08:20	Completed	Completed	Tubman - Water is leaking form a hole in the ceiling. The light in classroom 217 has water leaking into it and is not working properly. WO#1176121 was sent to the electricians to address the light issue.
01/04/2017 15:08:20	01/04/2017 15:08:20	Completed	Completed	Tubman - Water is leaking form a hole in the ceiling. The light in classroom 217 has water leaking into it and is not working properly. WO#1176121 was sent to the electricians to address the light issue.
01/04/2017 15:10:55	01/04/2017 15:10:55	Completed	Completed	Tubman - The light in classroom 217 has water leaking into it and is not working properly. The water is leaking form a hole in the ceiling. John 1-5-2017
01/09/2017 13:14:08	01/09/2017 13:14:08	Completed	Completed	John 1-5-2017
01/09/2017 13:14:08	01/09/2017 13:14:08	Completed	Completed	Tubman - 105A has ceiling leak in the North East corner. Custodian is able to contain at the moment.
01/09/2017 13:14:08	01/09/2017 13:14:08	Completed	Completed	Tubman - 105A has ceiling leak in the North East corner. Custodian is able to contain at the moment.
01/17/2017 08:00:02	01/17/2017 08:00:04	Active	Assigned	Back paneling by sink #1 as you enter staff room #159-D, is falling apart. Need to be repaired or replaced.
01/17/2017 08:00:02	01/17/2017 08:00:04	Active	Assigned	Back paneling by sink #1 as you enter staff room #159-D, is falling apart. Need to be repaired or replaced.
01/17/2017 09:03:12	01/17/2017 09:03:13	Active	Unassigned	Fan room #2 not working in office space #154. High priority, this feeds to the gym, which is very cold.
01/17/2017 13:55:04	01/17/2017 13:55:05	Active	Unassigned	North hallway by the breezeway and the gym, is too cold. In the 50's.
01/18/2017 10:27:37	01/18/2017 10:27:37	Completed	Completed	Tubman-Roof leak in room 103A (part of the office)- classroom in the library has a ceiling leak, and girls locker room shower area has a ceiling leak (room 164)
01/18/2017 10:27:37	01/18/2017 10:27:37	Completed	Completed	Tubman-Roof leak in room 103A (part of the office)- classroom in the library has a ceiling leak, and girls locker room shower area has a ceiling leak (room 164)
01/18/2017 14:30:00	01/19/2017 14:51:14	Completed	Completed	Tubman:clear rain drain to remove water from roof Eric, jerry 01/18/2017 JJT
01/18/2017 14:30:00	01/19/2017 14:51:14	Completed	Completed	Tubman:clear rain drain to remove water from roof Eric, jerry 01/18/2017 JJT
01/18/2017 14:30:00	01/19/2017 14:51:14	Completed	Completed	Tubman:clear rain drain to remove water from roof Eric, jerry 01/18/2017 JJT
01/26/2017 06:41:30	01/26/2017 06:41:30	Completed	Completed	Tubman - There is a leak coming from the ceiling in the southeast area of the library. The leak is contained.Also, leak in the tech lab in the library. Leak is contained.
01/26/2017 06:41:30	01/26/2017 06:41:30	Completed	Completed	Tubman - There is a leak coming from the ceiling in the southeast area of the library. The leak is contained.Also, leak in the tech lab in the library. Leak is contained.
01/27/2017 13:35:47	01/27/2017 13:35:49	Completed	Completed	Tubman - roof leak in a classroom in the library on the north side and also in the boy's locker room #162A And in boys restroom 200C located in the NW corner of the restroom Eric 1/27/2017 ww
02/06/2017 07:37:12	02/06/2017 07:37:12	Completed	Completed	Tubman - roof leak in room 105A and room 184 of the PIL building
02/06/2017 07:37:12	02/06/2017 07:37:12	Completed	Completed	Tubman - roof leak in room 105A and room 184 of the PIL building
02/06/2017 09:47:36	02/06/2017 09:47:37	Completed	Completed	Graffiti in Tubman parking lot across the street, on Flint street. Approximately 20 feet by 10 feet. Tubman:clear rain drain to remove water from roof for D Minch 2/7/17 KY
02/07/2017 09:17:16	02/07/2017 09:17:17	Completed	Completed	Tubman:clear rain drain to remove water from roof for D Minch 2/7/17 KY
02/08/2017 08:36:48	02/08/2017 08:36:50	Active	Unassigned	Classroom #120, temperature in the 70's but requesting to have the room re-calibrated to 68 degrees.
02/08/2017 08:39:14	02/08/2017 08:39:15	Active	Unassigned	North hallway by the gym is too cold, in the 50's. Please re-calibrate to about 68 degrees.
02/09/2017 13:59:47	02/09/2017 13:59:47	Completed	Completed	Tubman - roof leaks in the hallway by custodial closet 126, library 100 leaking from skylight, room 132C & the kitchen have water coming in the window
02/09/2017 13:59:47	02/09/2017 13:59:47	Completed	Completed	Tubman - roof leaks in the hallway by custodial closet 126, library 100 leaking from skylight, room 132C & the kitchen have water coming in the window
02/09/2017 13:59:47	02/09/2017 13:59:47	Completed	Completed	Tubman - roof leaks in the hallway by custodial closet 126, library 100 leaking from skylight, room 132C & the kitchen have water coming in the window
02/16/2017 07:34:42	02/16/2017 07:34:42	Completed	Completed	Tubman- sump by the breezeway annex needs to be unplugged
02/16/2017 07:34:42	02/16/2017 07:34:42	Completed	Completed	Tubman- sump by the breezeway annex needs to be unplugged
02/16/2017 13:35:12	02/16/2017 13:35:12	Completed	Completed	Tubman - ceiling leak in the girls locker room 164
02/16/2017 13:35:12	02/16/2017 13:35:12	Completed	Completed	Tubman - ceiling leak in the girls locker room 164
02/28/2017 09:28:09	02/28/2017 09:28:09	Completed	Completed	Tubman- the mechanism (square push button) that opens the handicapped door is broken- only works sporadically- door is by the breezeway- the only handicapped entrance door they have- Timofey 3/3/17 BT + Adam

02/28/2017 09:28:09	02/28/2017 09:28:09	Completed	Completed	Tubman- the mechanism (square push button) that opens the handicapped door is broken- only works sporadically- door is by the breezeway- the only handicapped entrance door they have- Timofey 3/3/17 BT + Adam
03/06/2017 07:19:48	03/06/2017 07:19:48	Closed	Completed	Tubman - The dishwasher is not getting water. Jim 03/06/2017 JJT
03/13/2017 09:39:34	03/13/2017 09:39:35	Active	Unassigned	oil leak from compressor in boiler/custodial room #175. Low on oil. Added oil.
03/14/2017 11:00:00	03/15/2017 14:24:29	Active	Assigned	Asst n.w. gas with gas sizing for new meter set at Tubman, Madison, Alameda, Jefferson, Besc. Chuck, brain 03/15/2017 JJT
03/14/2017 11:00:00	03/15/2017 14:24:29	Active	Assigned	Asst n.w. gas with gas sizing for new meter set at Tubman, Madison, Alameda, Jefferson, Besc. Chuck, brain 03/15/2017 JJT
03/16/2017 08:00:47	03/16/2017 07:58:49	Active	Assigned	6 floor tiles in cafeteria becoming loose. Also, 6 floor tiles loose in hallway by custodial closet #145.
03/17/2017 08:00:06	03/17/2017 06:12:08	Completed	Completed	Tubman- Replace Auto Opener in Breezeway
03/20/2017 08:08:36	03/20/2017 08:08:40	Active	Assigned	Volleyball pole holes missing special bolts to hold metal covers down from the gym floor.
03/20/2017 08:08:36	03/20/2017 08:08:40	Active	Assigned	Volleyball pole holes missing special bolts to hold metal covers down from the gym floor.
03/23/2017 09:17:12	03/23/2017 09:17:13	Completed	Completed	Please re-attach "Unauthorized vehicles will be towed" signage that was ripped off concrete pole from Tubman parking lot on Flint street. the sign is in the custodial/boiler room #175.
03/27/2017 09:31:47	03/27/2017 09:31:47	Completed	Completed	Tubman - There is graffiti on the basket court wall on concrete. (2) AND Flint St parking lot wall and chain post on concrete. (3) AND on a tree by the front entrance.
04/07/2017 07:52:04	04/07/2017 07:52:04	Completed	Completed	Tubman - broken window in the custodial office 175B -exterior dimensions are 45" x 14" EM Culver 4/7/17 Inv 5/17
04/11/2017 08:19:10	04/11/2017 08:19:10	Completed	Completed	Tubman - The pipe in nurse's station room #103 is leaking. Contained Bill 04/10/2017 JJT
04/11/2017 08:23:20	04/11/2017 08:23:20	Completed	Completed	Tubman - The sink in the boy's restroom (#220-C) is leaking from the P-trap underneath it. The water supply has been shut off. Bill 04/10/2017 JJT
04/12/2017 11:22:25	04/12/2017 11:22:25	Completed	Completed	Tubman - The roof in classroom 224 is leaking. Contained.
04/12/2017 11:22:25	04/12/2017 11:22:25	Completed	Completed	Tubman - The roof in classroom 224 is leaking. Contained.
04/14/2017 10:13:37	04/14/2017 10:13:37	Completed	Completed	Tubman - pipe leak in classroom 119 contained- custodian has no idea what the pipe goes to Bill 04/17/2017 JJT
04/14/2017 11:45:08	04/14/2017 11:45:08	Completed	Completed	Tubman - The lock on the exit door near the music room (#144) is loose.
04/18/2017 07:53:05	04/18/2017 07:53:05	Completed	Completed	Tubman -steady roof leak by the entrance between rooms 101 & 103 (main entrance) leaking from a skylight
04/19/2017 12:28:17	04/19/2017 12:28:17	Completed	Completed	Tubman - The overhead pipe in nurses's office (#103) is leaking. Contained. Jason B. 4/20/2017 ww Jason found this to be a hydronic sytem leak Cliff 4/20/2017 ww
04/19/2017 12:28:17	04/19/2017 12:28:17	Completed	Completed	Tubman - The overhead pipe in nurses's office (#103) is leaking. Contained. Jason B. 4/20/2017 ww Jason found this to be a hydronic sytem leak Cliff 4/20/2017 ww
04/20/2017 11:00:00	04/20/2017 10:46:40	Completed	Completed	Tubman Repair R.P. devices Jason B 04/20/2017 JJT
04/26/2017 11:57:30	04/26/2017 11:57:30	Completed	Completed	Tubman - There is a pipe leak on the right side of boiler #2 Dan 4/27/2017 ww
04/27/2017 09:08:48	04/27/2017 09:08:48	Completed	Completed	Tubman - The washing machine in area 130 is broken. It will not drain the water inside of it. Billy 5/5/2017 ww
04/27/2017 09:36:06	04/27/2017 09:36:06	Completed	Completed	Tubman - The p-trap on the sink in the boy's restroom (200-C) is leaking. Contained. Marty, 05/01/2017 JJT
04/28/2017 12:01:29	04/28/2017 12:01:29	Retired	Unassigned	Tubman - There is graffiti on the southwest side of the roof on the wall of the fan room on metal. See #1168714
05/04/2017 16:51:20	05/04/2017 16:51:20	Completed	Completed	Tubman-Dishwasher needs to be repaired in room #155. It's got standing water in the dishwasher and will not run. Stetson reported this. Billy 5/5/2017 ww
05/08/2017 12:31:23	05/08/2017 12:31:23	Completed	Completed	Tubman - The front entrance door is not opening when people use their cards on the card reader. The door can be opened manually. The problem may be with the door? This has been submitted to I.T. BLK
05/09/2017 14:21:14	05/09/2017 14:21:14	Completed	Completed	Tubman - doors not shutting properly (not latching all the way) door B in the front. SE door E and on the West side door I by the custodial closet 125 - all outside doors
05/12/2017 08:29:30	05/12/2017 08:29:32	Active	Assigned	Cabinet door (26.5" X 22.5") broken off from the hinges of the display case in the hall by conference room #104. The door is in Custodial room #175.
05/12/2017 08:29:30	05/12/2017 08:29:32	Active	Assigned	Cabinet door (26.5" X 22.5") broken off from the hinges of the display case in the hall by conference room #104. The door is in Custodial room #175.
05/16/2017 07:46:18	05/16/2017 07:46:18	Completed	Completed	Tubman - graffiti on the basketball court one on the backboard and on on a wall on concrete
05/16/2017 09:38:54	05/16/2017 09:38:54	Completed	Completed	Tubman-pipe leak to the right of boiler #2 -water going down a drain Dan 5/22/2017 ww
05/19/2017 12:40:59	05/19/2017 12:40:59	Completed	Completed	Tubman - POWER OUTAGE reported. Phone and computers were without power.-Tony/Maggie 5/19/17 BT

05/19/2017 12:40:59	05/19/2017 12:40:59	Completed	Completed	Tubman - POWER OUTAGE reported. Phone and computers were without power.-Tony/Maggie 5/19/17 BT
05/19/2017 13:21:26	05/19/2017 13:21:26	Completed	Completed	Tubman - Power outage reported. See notes Perform PM on motors.
05/22/2017 06:37:46	05/22/2017 06:37:46	Active	Assigned	Jay - 5/22/2017 BLK
05/22/2017 08:00:01	05/22/2017 06:32:03	Active	Assigned	Respond to fire alarm beeping after partial power outage.
05/23/2017 07:59:58	05/23/2017 07:59:58	Completed	Completed	Tubman - The fan in room #2 in the counselling area is not working. Dan 5/24/2017 ww
05/24/2017 09:28:57	05/24/2017 09:28:59	Active	Unassigned	Separate bike rack, one of 4 in a row, the first one is bent back and about to break off, needs to be reinforced. The rack is on the NW side of the school building. Update: The rack is completely busted off and the rack is now in the custodial office Room 175.
05/30/2017 07:49:31	05/30/2017 07:49:31	Completed	Completed	Tubman- the handicapped door by room 177 will not close all the way- won't latch unless manually pulled shut
06/02/2017 11:56:51	06/02/2017 11:56:51	Completed	Completed	Tubman - two pipe leaks - one is in the boys restroom 200C in the NW corner (dripping into a urinal) and one in the Boiler room to the left of boiler #1 (contained with a bucket) For MM & BW 6/5/17
06/02/2017 11:56:51	06/02/2017 11:56:51	Completed	Completed	Tubman - two pipe leaks - one is in the boys restroom 200C in the NW corner (dripping into a urinal) and one in the Boiler room to the left of boiler #1 (contained with a bucket) For MM & BW 6/5/17
06/06/2017 08:51:33	06/06/2017 08:51:34	Active	Unassigned	Weed problem. Please pull the weeds around the perimeter of the main building and PIL building. leak in Boiler room to the left of boiler #1 (contained with a bucket)
06/07/2017 08:15:07	06/07/2017 08:15:07	Active	Assigned	Dan 6/21/2017 ww
06/07/2017 08:17:21	06/07/2017 08:17:21	Active	Unassigned	Roof leak in the boys restroom 200C in the NW corner (dripping into a urinal)
06/08/2017 07:38:05	06/08/2017 07:38:05	Completed	Completed	Tubman - The ceiling is leaking coming from the skylight by the main entrance door. The leak is contained.
06/08/2017 07:38:05	06/08/2017 07:38:05	Completed	Completed	Tubman - The ceiling is leaking coming from the skylight by the main entrance door. The leak is contained.
06/08/2017 07:38:05	06/08/2017 07:38:05	Completed	Completed	Tubman - The ceiling is leaking coming from the skylight by the main entrance door. The leak is contained.
06/12/2017 11:55:14	06/12/2017 11:55:14	Completed	Completed	Tubman - The glass on the fire extinguisher box in the hallway near room 221 is broken. EM Culver 6/16/17 Inv
06/13/2017 07:58:44	06/13/2017 07:58:44	Active	Assigned	Tubman - The handicapped door is not opening intermittently.
06/14/2017 14:23:50	06/14/2017 14:24:05	Active	Assigned	Perform PM for boiler safety relief valves per ACME CSD 1. This is a preventive maintenance work task.
06/14/2017 14:23:50	06/14/2017 14:24:05	Active	Assigned	Perform PM for boiler safety relief valves per ACME CSD 1. This is a preventive maintenance work task.
06/23/2017 09:35:01	06/23/2017 09:35:01	Completed	Completed	Tubman- main front door on the north side does not close all the way by itself-it can be secured
08/03/2017 09:11:34	08/03/2017 09:11:34	Completed	Completed	Tubman - There is graffiti on the first garbage and dumpsters on the metal front and on the third garbage dumpster on the rubber lid.
08/28/2017 16:32:46	08/28/2017 16:32:46	Retired	Unassigned	Tubman-Repair swipe card reader on the west side next to the boiler room. Called in by Stetson-Created IT request #R297677 8/29/17 BT
08/30/2017 08:00:03	08/30/2017 06:30:04	Completed	Completed	TUBMAN please R/R the backflow devices For JB 8/30/17 KY
09/08/2017 08:00:21	09/08/2017 07:17:22	Active	Unassigned	Make up water supply line to boiler feed water tank is leaking. The pipe is rotted and needs to be re-piped.
09/20/2017 13:36:44	09/20/2017 13:36:46	Active	Unassigned	Reinstall relief valves and start boilers.
10/02/2017 08:00:25	09/30/2017 07:35:26	Completed	Completed	3 replacement schlage locks for tubman give to kerry
10/02/2017 13:00:26	10/02/2017 12:25:27	Active	Assigned	Need AWP in cafeteria for lighting repair. Contact Brian when delivered at 503-916-3146
10/02/2017 13:00:26	10/02/2017 12:25:27	Active	Assigned	Need AWP in cafeteria for lighting repair. Contact Brian when delivered at 503-916-3146
10/03/2017 14:49:28	10/03/2017 14:49:28	Completed	Completed	Tubman - The electrical box above the PIL building is being vandalised by transients. They are hooking their electronic equipment up to it. Jae - 10/19/2017 BLK Tubman: Electrical box at the old PIL building has been broken into by transients. Fire marshall has cited us for this electrical box. Called in by Stetson.
10/18/2017 16:30:19	10/18/2017 16:30:19	Retired	Unassigned	Duplicate of 1188027. BLK The upper level outdoor basketball court at Harriet Tubman School has an electrical outlet box that has been broken into. PPS should have it fixed soon because it is attracting homeless individuals to utilize the power.
10/18/2017 16:31:59	10/18/2017 16:32:00	Retired	Unassigned	Duplicate of 1188027. BLK
10/20/2017 13:53:02	10/20/2017 13:53:02	Active	Assigned	Tubman - graffiti on the metal doors facing the west side of the building
10/23/2017 08:00:23	10/23/2017 06:56:54	Active	Assigned	check and clear roof drains on the roof above room #110 Jim, Mark 10/23/2017 JJT
10/23/2017 08:00:23	10/23/2017 06:56:54	Active	Assigned	check and clear roof drains on the roof above room #110 Jim, Mark 10/23/2017 JJT
10/24/2017 07:00:36	10/24/2017 07:00:36	Active	Assigned	Tubman - no heat no boiler working Dan 10/24/2017

10/24/2017 09:14:39	10/24/2017 09:14:41	Active	Assigned	Leaking pipe needs to be addressed in the hall by custodians office. Ceiling is ready to fall down. Contact Tony for more details Gabe 10/24/2017
---------------------	---------------------	--------	----------	---