

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Harrison Park K-8 School - Test 6**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
236-DF-5837-N/A-006-A	Kitchen	9/29/2021	10/5/2021	A1J0003-02	Lead	0.338	0.2	15	ppb

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb