



January 31, 2017

Joe Crelier  
Director of Risk Management  
Portland Public Schools  
501 N Dixon Street  
Portland, Oregon 97227

Via email: jcrelier@pps.net

Regarding: Continuous Radon Monitor Measurement Report  
Five Locations at Peninsula, Ockley Green, Jefferson, and Skyline  
Portland, Oregon  
PBS Project No. 06500.618, Phase 0002

Dear Mr. Crelier:

From January 10 to January 18, 2017, PBS Engineering and Environmental Inc. (PBS) conducted continuous radon monitor (CRM) measurements at four Portland Public Schools (PPS) sites in five unique locations. These measurements were performed in response to elevated radon levels identified during previous short term radon monitoring. Locations tested are identified in the following table:

Site	Building	Room
Peninsula	Main	Boiler Room
Ockley Green	Main	ym
Jefferson	Main	A75
Jefferson	Main	A36 South Office
Skyline	Main	105A

This testing was performed with Sun Nuclear Model 1027 continuous radon monitors, EPA- and industry-approved testing devices. CRM monitors were placed on desk or table tops in rooms identified for testing. Devices were placed on the morning of January 10, 2017, and collected January 18, 2017. The devices recorded radon levels and tilts (an anti-tampering indication) data for 90 hours. Closed building conditions were not verified during the course of this testing.

The following table summarizes radon data collected:

Test Location	Start Time	Stop Time	Total Time*	Average Radon Concentration (pCi/L = picocuries per liter)
Peninsula – Boiler Room	01/10/2017 10:00 AM	01/18/2017 10:00 AM	90 Hours	8.0 pCi/l
Ockley Green – Gym	01/10/2017 8:30 AM	01/18/2017 11:00 AM	90 Hours	11.0 pCi/l
Jefferson – A36 South Office	01/10/2017 9:05 AM	01/18/2017 11:22 AM	90 Hours	10.7 pCi/l
Jefferson – A75	01/10/2017 9:15 AM	01/18/2017 11:28 AM	90 Hours	7.9 pCi/l
Skyline – 105A	01/10/2017 11:00 AM	01/18/2017 1:16 PM	90 Hours	10.9 pCi/l

\* Units log data once per hour for a maximum of the first 90 hours. Data for all hours between start and stop times may not be logged.

For more detail, please see the Report Graphs with Detailed Hourly Data for each test location (attached).

Please feel free to contact me at 503.417.7694 or [chris.boyce@pbsusa.com](mailto:chris.boyce@pbsusa.com) with any questions or comments.

Sincerely,




Chris Boyce  
 Project Manager

Attachments: Report Graphs with Detailed Hourly Data (5)  
 CRM Statements of Calibration (Serial Numbers: 1407171, 1407175, 1407185, 1407187, 1407188)

CB::lkn

Unit Type: Sun Nuclear Model 1027  
 Serial Number: 1407185




Date:	Time:	Radon (pCi/l)
January 10, 2017	11:00 AM	6.0
January 10, 2017	12:00 PM	9.6
January 10, 2017	1:00 PM	14.6
January 10, 2017	2:00 PM	13.2
January 10, 2017	3:00 PM	15.0
January 10, 2017	4:00 PM	17.0
January 10, 2017	5:00 PM	12.0
January 10, 2017	6:00 PM	12.6
January 10, 2017	7:00 PM	12.0
January 10, 2017	8:00 PM	18.6
January 10, 2017	9:00 PM	9.0
January 10, 2017	10:00 PM	9.6
January 10, 2017	11:00 PM	9.0
January 11, 2017	12:00 AM	13.2
January 11, 2017	1:00 AM	10.0
January 11, 2017	2:00 AM	9.2
January 11, 2017	3:00 AM	8.2

January 11, 2017	4:00 AM	3.6
January 11, 2017	5:00 AM	6.2
January 11, 2017	6:00 AM	6.2
January 11, 2017	7:00 AM	8.2
January 11, 2017	8:00 AM	4.2
January 11, 2017	9:00 AM	2.6
January 11, 2017	10:00 AM	1.6
January 11, 2017	11:00 AM	4.0
January 11, 2017	12:00 PM	5.2
January 11, 2017	1:00 PM	3.6
January 11, 2017	2:00 PM	5.2
January 11, 2017	3:00 PM	5.6
January 11, 2017	4:00 PM	6.0
January 11, 2017	5:00 PM	8.0
January 11, 2017	6:00 PM	9.0
January 11, 2017	7:00 PM	7.0
January 11, 2017	8:00 PM	6.6
January 11, 2017	9:00 PM	1.2
January 11, 2017	10:00 PM	5.0
January 11, 2017	11:00 PM	3.6
January 12, 2017	12:00 AM	7.6
January 12, 2017	1:00 AM	9.0
January 12, 2017	2:00 AM	5.6
January 12, 2017	3:00 AM	7.2
January 12, 2017	4:00 AM	7.2
January 12, 2017	5:00 AM	5.6
January 12, 2017	6:00 AM	6.0
January 12, 2017	7:00 AM	7.0
January 12, 2017	8:00 AM	10.6
January 12, 2017	9:00 AM	4.0
January 12, 2017	10:00 AM	5.0
January 12, 2017	11:00 AM	8.0
January 12, 2017	12:00 PM	8.2
January 12, 2017	1:00 PM	8.2
January 12, 2017	2:00 PM	11.6
January 12, 2017	3:00 PM	7.6
January 12, 2017	4:00 PM	7.0
January 12, 2017	5:00 PM	11.6
January 12, 2017	6:00 PM	6.0
January 12, 2017	7:00 PM	9.0
January 12, 2017	8:00 PM	5.2

January 12, 2017	9:00 PM	7.0
January 12, 2017	10:00 PM	5.6
January 12, 2017	11:00 PM	6.6
January 13, 2017	12:00 AM	6.0
January 13, 2017	1:00 AM	9.2
January 13, 2017	2:00 AM	10.0
January 13, 2017	3:00 AM	9.2
January 13, 2017	4:00 AM	8.2
January 13, 2017	5:00 AM	9.6
January 13, 2017	6:00 AM	11.0
January 13, 2017	7:00 AM	6.6
January 13, 2017	8:00 AM	3.2
January 13, 2017	9:00 AM	1.2
January 13, 2017	10:00 AM	2.0
January 13, 2017	11:00 AM	3.0
January 13, 2017	12:00 PM	3.6
January 13, 2017	1:00 PM	4.0
January 13, 2017	2:00 PM	8.0
January 13, 2017	3:00 PM	7.0
January 13, 2017	4:00 PM	10.2
January 13, 2017	5:00 PM	10.2
January 13, 2017	6:00 PM	10.6
January 13, 2017	7:00 PM	13.6
January 13, 2017	8:00 PM	9.0
January 13, 2017	9:00 PM	11.6
January 13, 2017	10:00 PM	10.0
January 13, 2017	11:00 PM	11.6
January 14, 2017	12:00 AM	12.6
January 14, 2017	1:00 AM	7.0
January 14, 2017	2:00 AM	9.6
January 14, 2017	3:00 AM	10.6
January 14, 2017	4:00 AM	14.2

Unit Type: Sun Nuclear Model 1027  
 Serial Number: 1407188




Date:	Time:	Radon (pCi/l)
January 10, 2017	9:00 AM	5.0
January 10, 2017	10:00 AM	7.0
January 10, 2017	11:00 AM	10.2
January 10, 2017	12:00 PM	10.0
January 10, 2017	1:00 PM	9.6
January 10, 2017	2:00 PM	8.0
January 10, 2017	3:00 PM	6.0
January 10, 2017	4:00 PM	11.6
January 10, 2017	5:00 PM	15.0
January 10, 2017	6:00 PM	12.2
January 10, 2017	7:00 PM	7.2
January 10, 2017	8:00 PM	9.6
January 10, 2017	9:00 PM	5.6
January 10, 2017	10:00 PM	8.0
January 10, 2017	11:00 PM	9.6

January 11, 2017	12:00 AM	8.2
January 11, 2017	1:00 AM	5.2
January 11, 2017	2:00 AM	7.0
January 11, 2017	3:00 AM	6.6
January 11, 2017	4:00 AM	10.2
January 11, 2017	5:00 AM	4.0
January 11, 2017	6:00 AM	7.6
January 11, 2017	7:00 AM	10.6
January 11, 2017	8:00 AM	14.0
January 11, 2017	9:00 AM	19.6
January 11, 2017	10:00 AM	17.0
January 11, 2017	11:00 AM	15.6
January 11, 2017	12:00 PM	16.0
January 11, 2017	1:00 PM	17.0
January 11, 2017	2:00 PM	20.0
January 11, 2017	3:00 PM	12.0
January 11, 2017	4:00 PM	18.2
January 11, 2017	5:00 PM	11.2
January 11, 2017	6:00 PM	11.2
January 11, 2017	7:00 PM	8.2
January 11, 2017	8:00 PM	9.2
January 11, 2017	9:00 PM	7.0
January 11, 2017	10:00 PM	7.6
January 11, 2017	11:00 PM	8.0
January 12, 2017	12:00 AM	6.0
January 12, 2017	1:00 AM	8.6
January 12, 2017	2:00 AM	8.0
January 12, 2017	3:00 AM	4.6
January 12, 2017	4:00 AM	7.6
January 12, 2017	5:00 AM	9.0
January 12, 2017	6:00 AM	13.2
January 12, 2017	7:00 AM	12.0
January 12, 2017	8:00 AM	14.6
January 12, 2017	9:00 AM	14.2
January 12, 2017	10:00 AM	12.2
January 12, 2017	11:00 AM	16.6
January 12, 2017	12:00 PM	12.6
January 12, 2017	1:00 PM	17.2
January 12, 2017	2:00 PM	20.2
January 12, 2017	3:00 PM	15.6
January 12, 2017	4:00 PM	16.6

January 12, 2017	5:00 PM	16.0
January 12, 2017	6:00 PM	11.2
January 12, 2017	7:00 PM	7.0
January 12, 2017	8:00 PM	10.2
January 12, 2017	9:00 PM	7.2
January 12, 2017	10:00 PM	6.2
January 12, 2017	11:00 PM	8.2
January 12, 2017	12:00 AM	9.0
January 13, 2017	1:00 AM	9.6
January 13, 2017	2:00 AM	7.6
January 13, 2017	3:00 AM	5.0
January 13, 2017	4:00 AM	10.2
January 13, 2017	5:00 AM	10.0
January 13, 2017	6:00 AM	13.6
January 13, 2017	7:00 AM	16.0
January 13, 2017	8:00 AM	10.6
January 13, 2017	9:00 AM	14.2
January 13, 2017	10:00 AM	13.6
January 13, 2017	11:00 AM	12.6
January 13, 2017	12:00 PM	14.0
January 13, 2017	1:00 PM	16.2
January 13, 2017	2:00 PM	14.0
January 13, 2017	3:00 PM	15.0
January 13, 2017	4:00 PM	14.6
January 13, 2017	5:00 PM	14.6
January 13, 2017	6:00 PM	19.0
January 13, 2017	7:00 PM	11.6
January 13, 2017	8:00 PM	8.0
January 13, 2017	9:00 PM	10.2
January 13, 2017	10:00 PM	8.0
January 13, 2017	11:00 PM	7.6
January 14, 2017	12:00 AM	7.0
January 14, 2017	1:00 AM	10.0
January 14, 2017	2:00 AM	7.6



Unit Type: Sun Nuclear Model 1027  
 Serial Number: 1407187




Date:	Time:	Radon (pCi/l)
January 10, 2017	10:00 AM	3.2
January 10, 2017	11:00 AM	8.6
January 10, 2017	12:00 PM	13.2
January 10, 2017	1:00 PM	12.2
January 10, 2017	2:00 PM	14.6
January 10, 2017	3:00 PM	11.2
January 10, 2017	4:00 PM	8.2
January 10, 2017	5:00 PM	13.0
January 10, 2017	6:00 PM	18.0
January 10, 2017	7:00 PM	12.0
January 10, 2017	8:00 PM	13.6
January 10, 2017	9:00 PM	13.2
January 10, 2017	10:00 PM	15.0
January 10, 2017	11:00 PM	10.2
January 11, 2017	12:00 AM	12.0

January 11, 2017	1:00 AM	10.2
January 11, 2017	2:00 AM	9.6
January 11, 2017	3:00 AM	11.6
January 11, 2017	4:00 AM	8.2
January 11, 2017	5:00 AM	12.0
January 11, 2017	6:00 AM	8.0
January 11, 2017	7:00 AM	7.2
January 11, 2017	8:00 AM	6.6
January 11, 2017	9:00 AM	10.2
January 11, 2017	10:00 AM	9.0
January 11, 2017	11:00 AM	13.2
January 11, 2017	12:00 PM	10.2
January 11, 2017	1:00 PM	9.6
January 11, 2017	2:00 PM	11.6
January 11, 2017	3:00 PM	9.2
January 11, 2017	4:00 PM	9.0
January 11, 2017	5:00 PM	10.2
January 11, 2017	6:00 PM	9.6
January 11, 2017	7:00 PM	13.2
January 11, 2017	8:00 PM	6.2
January 11, 2017	9:00 PM	8.2
January 11, 2017	10:00 PM	9.2
January 11, 2017	11:00 PM	7.6
January 12, 2017	12:00 AM	6.6
January 12, 2017	1:00 AM	3.6
January 12, 2017	2:00 AM	9.0
January 12, 2017	3:00 AM	6.2
January 12, 2017	4:00 AM	7.0
January 12, 2017	5:00 AM	10.0
January 12, 2017	6:00 AM	11.0
January 12, 2017	7:00 AM	7.2
January 12, 2017	8:00 AM	7.0
January 12, 2017	9:00 AM	8.2
January 12, 2017	10:00 AM	10.2
January 12, 2017	11:00 AM	12.0
January 12, 2017	12:00 PM	12.0
January 12, 2017	1:00 PM	12.6
January 12, 2017	2:00 PM	8.2
January 12, 2017	3:00 PM	14.0
January 12, 2017	4:00 PM	12.6
January 12, 2017	5:00 PM	17.6

January 12, 2017	6:00 PM	14.6
January 12, 2017	7:00 PM	11.2
January 12, 2017	8:00 PM	8.6
January 12, 2017	9:00 PM	13.2
January 12, 2017	10:00 PM	8.0
January 12, 2017	11:00 PM	8.2
January 13, 2017	12:00 AM	10.0
January 13, 2017	1:00 AM	11.0
January 13, 2017	2:00 AM	15.0
January 13, 2017	3:00 AM	7.2
January 13, 2017	4:00 AM	9.6
January 13, 2017	5:00 AM	7.2
January 13, 2017	6:00 AM	10.0
January 13, 2017	7:00 AM	7.2
January 13, 2017	8:00 AM	11.2
January 13, 2017	9:00 AM	12.2
January 13, 2017	10:00 AM	12.6
January 13, 2017	11:00 AM	11.2
January 13, 2017	12:00 PM	12.0
January 13, 2017	1:00 PM	14.0
January 13, 2017	2:00 PM	15.2
January 13, 2017	3:00 PM	20.2
January 13, 2017	4:00 PM	14.0
January 13, 2017	5:00 PM	12.0
January 13, 2017	6:00 PM	14.2
January 13, 2017	7:00 PM	14.2
January 13, 2017	8:00 PM	11.6
January 13, 2017	9:00 PM	10.6
January 13, 2017	10:00 PM	11.0
January 13, 2017	11:00 PM	7.2
January 14, 2017	12:00 AM	11.0
January 14, 2017	1:00 AM	12.2
January 14, 2017	2:00 AM	9.0
January 14, 2017	3:00 AM	10.6

Unit Type: Sun Nuclear Model 1027  
 Serial Number: 1407171




Date:	Time:	Radon (pCi/l)
January 10, 2017	10:00 AM	3.0
January 10, 2017	11:00 AM	3.6
January 10, 2017	12:00 PM	4.0
January 10, 2017	1:00 PM	7.0
January 10, 2017	2:00 PM	5.2
January 10, 2017	3:00 PM	2.6
January 10, 2017	4:00 PM	3.2
January 10, 2017	5:00 PM	7.0
January 10, 2017	6:00 PM	12.6
January 10, 2017	7:00 PM	9.6
January 10, 2017	8:00 PM	7.6
January 10, 2017	9:00 PM	12.2
January 10, 2017	10:00 PM	11.6
January 10, 2017	11:00 PM	15.0
January 11, 2017	12:00 AM	10.6

January 11, 2017	1:00 AM	11.0
January 11, 2017	2:00 AM	12.6
January 11, 2017	3:00 AM	13.0
January 11, 2017	4:00 AM	12.0
January 11, 2017	5:00 AM	10.0
January 11, 2017	6:00 AM	10.2
January 11, 2017	7:00 AM	5.0
January 11, 2017	8:00 AM	9.0
January 11, 2017	9:00 AM	7.2
January 11, 2017	10:00 AM	8.0
January 11, 2017	11:00 AM	2.6
January 11, 2017	12:00 PM	4.6
January 11, 2017	1:00 PM	5.2
January 11, 2017	2:00 PM	5.0
January 11, 2017	3:00 PM	5.0
January 11, 2017	4:00 PM	5.0
January 11, 2017	5:00 PM	5.6
January 11, 2017	6:00 PM	5.6
January 11, 2017	7:00 PM	10.0
January 11, 2017	8:00 PM	8.2
January 11, 2017	9:00 PM	12.0
January 11, 2017	10:00 PM	8.6
January 11, 2017	11:00 PM	10.6
January 12, 2017	12:00 AM	12.2
January 12, 2017	1:00 AM	12.2
January 12, 2017	2:00 AM	8.0
January 12, 2017	3:00 AM	11.2
January 12, 2017	4:00 AM	11.2
January 12, 2017	5:00 AM	10.2
January 12, 2017	6:00 AM	6.6
January 12, 2017	7:00 AM	9.6
January 12, 2017	8:00 AM	8.2
January 12, 2017	9:00 AM	9.0
January 12, 2017	10:00 AM	5.6
January 12, 2017	11:00 AM	7.2
January 12, 2017	12:00 PM	4.0
January 12, 2017	1:00 PM	6.6
January 12, 2017	2:00 PM	1.6
January 12, 2017	3:00 PM	2.2
January 12, 2017	4:00 PM	1.0
January 12, 2017	5:00 PM	6.0

January 12, 2017	6:00 PM	4.0
January 12, 2017	7:00 PM	7.6
January 12, 2017	8:00 PM	7.0
January 12, 2017	9:00 PM	5.6
January 12, 2017	10:00 PM	7.2
January 12, 2017	11:00 PM	6.2
January 13, 2017	12:00 AM	7.2
January 13, 2017	1:00 AM	7.6
January 13, 2017	2:00 AM	8.6
January 13, 2017	3:00 AM	9.2
January 13, 2017	4:00 AM	7.2
January 13, 2017	5:00 AM	9.6
January 13, 2017	6:00 AM	9.2
January 13, 2017	7:00 AM	9.6
January 13, 2017	8:00 AM	7.0
January 13, 2017	9:00 AM	4.6
January 13, 2017	10:00 AM	5.6
January 13, 2017	11:00 AM	6.2
January 13, 2017	12:00 PM	6.2
January 13, 2017	1:00 PM	6.2
January 13, 2017	2:00 PM	4.2
January 13, 2017	3:00 PM	4.2
January 13, 2017	4:00 PM	5.2
January 13, 2017	5:00 PM	7.0
January 13, 2017	6:00 PM	7.0
January 13, 2017	7:00 PM	11.6
January 13, 2017	8:00 PM	7.6
January 13, 2017	9:00 PM	11.6
January 13, 2017	10:00 PM	14.0
January 13, 2017	11:00 PM	11.6
January 14, 2017	12:00 AM	10.2
January 14, 2017	1:00 AM	12.2
January 14, 2017	2:00 AM	16.2
January 14, 2017	3:00 AM	14.6

Unit Type: Sun Nuclear Model 1027  
 Serial Number: 1407175



Date:	Time:	Radon (pCi/l)
January 10, 2017	11:00 AM	1.6
January 10, 2017	12:00 PM	1.2
January 10, 2017	1:00 PM	1.2
January 10, 2017	2:00 PM	3.0
January 10, 2017	3:00 PM	4.6
January 10, 2017	4:00 PM	4.0
January 10, 2017	5:00 PM	5.6
January 10, 2017	6:00 PM	4.0
January 10, 2017	7:00 PM	3.6
January 10, 2017	8:00 PM	4.2
January 10, 2017	9:00 PM	12.2
January 10, 2017	10:00 PM	10.6
January 10, 2017	11:00 PM	18.2
January 11, 2017	12:00 AM	12.2

January 11, 2017	1:00 AM	13.2
January 11, 2017	2:00 AM	17.2
January 11, 2017	3:00 AM	17.6
January 11, 2017	4:00 AM	13.2
January 11, 2017	5:00 AM	9.6
January 11, 2017	6:00 AM	12.6
January 11, 2017	7:00 AM	14.0
January 11, 2017	8:00 AM	10.6
January 11, 2017	9:00 AM	14.6
January 11, 2017	10:00 AM	11.0
January 11, 2017	11:00 AM	10.0
January 11, 2017	12:00 PM	10.0
January 11, 2017	1:00 PM	10.6
January 11, 2017	2:00 PM	17.6
January 11, 2017	3:00 PM	14.6
January 11, 2017	4:00 PM	13.2
January 11, 2017	5:00 PM	10.2
January 11, 2017	6:00 PM	12.2
January 11, 2017	7:00 PM	11.2
January 11, 2017	8:00 PM	10.2
January 11, 2017	9:00 PM	11.0
January 11, 2017	10:00 PM	11.2
January 11, 2017	11:00 PM	12.2
January 12, 2017	12:00 AM	15.6
January 12, 2017	1:00 AM	13.0
January 12, 2017	2:00 AM	12.6
January 12, 2017	3:00 AM	12.2
January 12, 2017	4:00 AM	8.0
January 12, 2017	5:00 AM	9.6
January 12, 2017	6:00 AM	12.6
January 12, 2017	7:00 AM	7.6
January 12, 2017	8:00 AM	9.2
January 12, 2017	9:00 AM	12.0
January 12, 2017	10:00 AM	9.6
January 12, 2017	11:00 AM	10.0
January 12, 2017	12:00 PM	10.2
January 12, 2017	1:00 PM	13.2
January 12, 2017	2:00 PM	13.6
January 12, 2017	3:00 PM	11.2
January 12, 2017	4:00 PM	11.0
January 12, 2017	5:00 PM	16.6



January 12, 2017	6:00 PM	10.2
January 12, 2017	7:00 PM	8.2
January 12, 2017	8:00 PM	14.0
January 12, 2017	9:00 PM	14.6
January 12, 2017	10:00 PM	14.6
January 12, 2017	11:00 PM	13.0
January 13, 2017	12:00 AM	15.0
January 13, 2017	1:00 AM	10.2
January 13, 2017	2:00 AM	14.0
January 13, 2017	3:00 AM	13.0
January 13, 2017	4:00 AM	14.6
January 13, 2017	5:00 AM	10.2
January 13, 2017	6:00 AM	9.6
January 13, 2017	7:00 AM	9.0
January 13, 2017	8:00 AM	13.2
January 13, 2017	9:00 AM	9.0
January 13, 2017	10:00 AM	12.0
January 13, 2017	11:00 AM	10.6
January 13, 2017	12:00 PM	14.2
January 13, 2017	1:00 PM	11.0
January 13, 2017	2:00 PM	12.2
January 13, 2017	3:00 PM	11.0
January 13, 2017	4:00 PM	10.6
January 13, 2017	5:00 PM	12.2
January 13, 2017	6:00 PM	11.2
January 13, 2017	7:00 PM	12.2
January 13, 2017	8:00 PM	10.2
January 13, 2017	9:00 PM	6.6
January 13, 2017	10:00 PM	10.6
January 13, 2017	11:00 PM	6.0
January 14, 2017	12:00 AM	13.2
January 14, 2017	1:00 AM	9.0
January 14, 2017	2:00 AM	12.2
January 14, 2017	3:00 AM	10.6
January 14, 2017	4:00 AM	9.2



# RADON REFERENCE LABORATORY

## STATEMENT OF CALIBRATION

**Client Information:**

PBS Engineering & Environmental Inc.  
4412 Southwest Corbett Avenue  
Portland, Oregon 97239  
Attn: Chris Boyce

**BMI Control Information:**

Statement No.: 17581709  
Issue Date: July 25, 2016  
Calibrated on: July 25, 2016  
Calibrated by: JPN  
Calibration site: BMI Dayton

**Description of Continuous Radon Monitor:**

**Manufacturer:** Sun Nuclear **Model:** 1027 **Serial No.:** 1407171

The monitor was found to be in good physical condition. No power adapter was received with the monitor. The calibration was conducted using an adapter belonging to Bowser-Morner.

**Initial Checks:**

<u>Visual Inspection</u>	<u>Batteries</u>	<u>Power Adapter</u>	<u>High Voltage</u>	<u>Software Version</u>
Ok	Ok	See above	1199 VDC (Ok)	N5A

**Result of Background Exposure (16 hr):** 0.2 pCi/liter

**Radon Chamber Conditions:**

<u>Exposure Duration</u>	<u>Radon Concentration</u>	<u>Relative Humidity</u>	<u>Temperature</u>
48 hr	25.8 ± 0.5 pCi/liter	49.9 ± 0.5 %	70.0 ± 0.1 °F

The values listed above for the radon concentration, relative humidity and temperature are the means and standard deviations of the hourly average measurements of these parameters. The calibration of Bowser-Morner's Radon Monitoring System is maintained through comparisons with the USEPA radon laboratory in Las Vegas using a NIST traceable radium standard. The estimated total uncertainty of Bowser-Morner's average chamber concentration is ± 6.4% at the 95% confidence level.

**Results of Calibration:**

<u>Average Monitor Reading</u>	<u>Relative Error As Received</u>	<u>Relative Error After Change of Calibration Factor</u>
27.7 pCi/liter	6.6%	-3.1%

Based on the results of the calibration, the monitor's internal calibration factor was changed to the most accurate available setting. The background value listed above should be subtracted from the radon measurement and the result multiplied by the correction factor of 1.032.

The calibration was performed using BMI procedure number 42-001.

Authorized Signature *Jill P. Newton*, Manager Radon Reference Lab

*All Reports Remain The Confidential Property of Bowser-Morner and No Publication Or Distribution Of Reports May be Made Without Our Express Written Consent, Except As Authorized by Contract. Results contained in this Report are Reflective Only of the Items Calibrated or Tested.*



# RADON REFERENCE LABORATORY

## STATEMENT OF CALIBRATION

**BOWSER  
MORNER**®

**Client Information:**

PBS Engineering & Environmental Inc.  
4412 Southwest Corbett Avenue  
Portland, Oregon 97239  
Attn: Chris Boyce

**BMI Control Information:**

Statement No.: 17581704  
Issue Date: July 25, 2016  
Calibrated on: July 25, 2016  
Calibrated by: JPN  
Calibration site: BMI Dayton

**Description of Continuous Radon Monitor:**

**Manufacturer:** Sun Nuclear **Model:** 1027

**Serial No.:** 1407175

The monitor was found to be in good physical condition.

**Initial Checks:**

<b><u>Visual Inspection</u></b>	<b><u>Batteries</u></b>	<b><u>Power Adapter</u></b>	<b><u>High Voltage</u></b>	<b><u>Software Version</u></b>
Ok	Replaced	11.1 VDC (Ok)	1114 VDC (Ok)	N5A

**Result of Background Exposure (16 hr):** 0.2 pCi/liter

**Radon Chamber Conditions:**

<b><u>Exposure Duration</u></b>	<b><u>Radon Concentration</u></b>	<b><u>Relative Humidity</u></b>	<b><u>Temperature</u></b>
48 hr	25.8 ± 0.5 pCi/liter	49.9 ± 0.5 %	70.0 ± 0.1 °F

The values listed above for the radon concentration, relative humidity and temperature are the means and standard deviations of the hourly average measurements of these parameters. The calibration of Bowser-Morner's Radon Monitoring System is maintained through comparisons with the USEPA radon laboratory in Las Vegas using a NIST traceable radium standard. The estimated total uncertainty of Bowser-Morner's average chamber concentration is ± 6.4% at the 95% confidence level.

**Results of Calibration:**

<b><u>Average Monitor Reading</u></b>	<b><u>Relative Error As Received</u></b>	<b><u>Relative Error After Change of Calibration Factor</u></b>
29.0 pCi/liter	11.6%	1.5%

Based on the results of the calibration, the monitor's internal calibration factor was changed to the most accurate available setting. The background value listed above should be subtracted from the radon measurement and the result multiplied by the correction factor of 0.986.

The calibration was performed using BMI procedure number 42-001.

Authorized Signature *Jill P. Newton*, Manager Radon Reference Lab

*All Reports Remain The Confidential Property of Bowser-Morner and No Publication Or Distribution Of Reports May be Made Without Our Express Written Consent, Except As Authorized by Contract. Results contained in this Report are Reflective Only of the Items Calibrated or Tested.*



# RADON REFERENCE LABORATORY

## STATEMENT OF CALIBRATION

**BOWSER MORNER**®

**Client Information:**

PBS Engineering & Environmental Inc.  
4412 Southwest Corbett Avenue  
Portland, Oregon 97239  
Attn: Chris Boyce

**BMI Control Information:**

Statement No.: 17581701  
Issue Date: July 25, 2016  
Calibrated on: July 25, 2016  
Calibrated by: JPN  
Calibration site: BMI Dayton

**Description of Continuous Radon Monitor:**

**Manufacturer:** Sun Nuclear **Model:** 1027 **Serial No.:** 1407185

The monitor was found to be in good physical condition. No power adapter was received with the monitor. The calibration was conducted using an adapter belonging to Bowser-Morner.

**Initial Checks:**

<u>Visual Inspection</u> Ok	<u>Batteries</u> Ok	<u>Power Adapter</u> See above	<u>High Voltage</u> 1118 VDC (Ok)	<u>Software Version</u> N5A
--------------------------------	------------------------	-----------------------------------	--------------------------------------	--------------------------------

**Result of Background Exposure (18 hr):** 0.1 pCi/liter

**Radon Chamber Conditions:**

<u>Exposure Duration</u> 48 hr	<u>Radon Concentration</u> 26.0 ± 0.3 pCi/liter	<u>Relative Humidity</u> 48.9 ± 0.6 %	<u>Temperature</u> 70.0 ± 0.1 °F
-----------------------------------	--	--	-------------------------------------

The values listed above for the radon concentration, relative humidity and temperature are the means and standard deviations of the hourly average measurements of these parameters. The calibration of Bowser-Morner's Radon Monitoring System is maintained through comparisons with the USEPA radon laboratory in Las Vegas using a NIST traceable radium standard. The estimated total uncertainty of Bowser-Morner's average chamber concentration is ± 6.4% at the 95% confidence level.

**Results of Calibration:**

<u>Average Monitor Reading</u> 29.7 pCi/liter	<u>Relative Error As Received</u> 13.8%	<u>Relative Error After Change of Calibration Factor</u> 3.5%
--	--	--

Based on the results of the calibration, the monitor's internal calibration factor was changed to the most accurate available setting. The background value listed above should be subtracted from the radon measurement and the result multiplied by the correction factor of 0.966.

The calibration was performed using BMI procedure number 42-001.

Authorized Signature *Gill P. Newton*, Manager Radon Reference Lab

*All Reports Remain The Confidential Property of Bowser-Morner and No Publication Or Distribution Of Reports May be Made Without Our Express Written Consent, Except As Authorized by Contract. Results contained in this Report are Reflective Only of the Items Calibrated or Tested.*



## STATEMENT OF CALIBRATION

**Client Information:**

PBS Engineering & Environmental Inc.  
4412 Southwest Corbett Avenue  
Portland, Oregon 97239  
Attn: Chris Boyce

**BMI Control Information:**

Statement No.: 17581707  
Issue Date: July 25, 2016  
Calibrated on: July 25, 2016  
Calibrated by: JPN  
Calibration site: BMI Dayton

**Description of Continuous Radon Monitor:**

**Manufacturer:** Sun Nuclear **Model:** 1027 **Serial No.:** 1407187

The monitor was found to be in good physical condition.

**Initial Checks:**

<b><u>Visual Inspection</u></b>	<b><u>Batteries</u></b>	<b><u>Power Adapter</u></b>	<b><u>High Voltage</u></b>	<b><u>Software Version</u></b>
Ok	Replaced	11.1 VDC (Ok)	1130 VDC (Ok)	N5A

**Result of Background Exposure (16 hr):** 0.0 pCi/liter

**Radon Chamber Conditions:**

<b><u>Exposure Duration</u></b>	<b><u>Radon Concentration</u></b>	<b><u>Relative Humidity</u></b>	<b><u>Temperature</u></b>
48 hr	25.8 ± 0.5 pCi/liter	49.9 ± 0.5 %	70.0 ± 0.1 °F

The values listed above for the radon concentration, relative humidity and temperature are the means and standard deviations of the hourly average measurements of these parameters. The calibration of Bowser-Morner's Radon Monitoring System is maintained through comparisons with the USEPA radon laboratory in Las Vegas using a NIST traceable radium standard. The estimated total uncertainty of Bowser-Morner's average chamber concentration is ± 6.4% at the 95% confidence level.

**Results of Calibration:**

<b><u>Average Monitor Reading</u></b>	<b><u>Relative Error As Received</u></b>	<b><u>Relative Error After Change of Calibration Factor</u></b>
28.6 pCi/liter	10.9%	0.8%

Based on the results of the calibration, the monitor's internal calibration factor was changed to the most accurate available setting. The radon measurement should be multiplied by the correction factor of 0.992.

The calibration was performed using BMI procedure number 42-001.

Authorized Signature *Gill P. Newton*, Manager Radon Reference Lab

*All Reports Remain The Confidential Property of Bowser-Morner and No Publication Or Distribution Of Reports May be Made Without Our Express Written Consent, Except As Authorized by Contract. Results contained in this Report are Reflective Only of the Items Calibrated or Tested.*



# RADON REFERENCE LABORATORY

## STATEMENT OF CALIBRATION



**Client Information:**

PBS Engineering & Environmental Inc.  
4412 Southwest Corbett Avenue  
Portland, Oregon 97239  
Attn: Chris Boyce

**BMI Control Information:**

Statement No.: 17581703  
Issue Date: July 25, 2016  
Calibrated on: July 25, 2016  
Calibrated by: JPN  
Calibration site: BMI Dayton

**Description of Continuous Radon Monitor:**

**Manufacturer:** Sun Nuclear **Model:** 1027 **Serial No.:** 1407188

The monitor was found to be in good physical condition.

**Initial Checks:**

<u>Visual Inspection</u>	<u>Batteries</u>	<u>Power Adapter</u>	<u>High Voltage</u>	<u>Software Version</u>
Ok	Replaced	11.1 VDC (Ok)	1103 VDC (Ok)	N5A

**Result of Background Exposure (16 hr):** 0.1 pCi/liter

**Radon Chamber Conditions:**

<u>Exposure Duration</u>	<u>Radon Concentration</u>	<u>Relative Humidity</u>	<u>Temperature</u>
48 hr	25.8 ± 0.5 pCi/liter	49.9 ± 0.5 %	70.0 ± 0.1 °F

The values listed above for the radon concentration, relative humidity and temperature are the means and standard deviations of the hourly average measurements of these parameters. The calibration of Bowser-Morner's Radon Monitoring System is maintained through comparisons with the USEPA radon laboratory in Las Vegas using a NIST traceable radium standard. The estimated total uncertainty of Bowser-Morner's average chamber concentration is ± 6.4% at the 95% confidence level.

**Results of Calibration:**

<u>Average Monitor Reading</u>	<u>Relative Error As Received</u>	<u>Relative Error After Change of Calibration Factor</u>
27.9 pCi/liter	7.8%	-2.1%

Based on the results of the calibration, the monitor's internal calibration factor was changed to the most accurate available setting. The background value listed above should be subtracted from the radon measurement and the result multiplied by the correction factor of 1.021.

The calibration was performed using BMI procedure number 42-001.

Authorized Signature *Jill P. Newton*, Manager Radon Reference Lab

*All Reports Remain The Confidential Property of Bowser-Morner and No Publication Or Distribution Of Reports May be Made Without Our Express Written Consent, Except As Authorized by Contract. Results contained in this Report are Reflective Only of the Items Calibrated or Tested.*