

**Portland Public Schools  
Lead and Copper Water Sampling Results  
Initial Draw Sample Data  
Hayhurst Elementary**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
160-CH4356-N/A-001-A	Cafeteria Bubblers	10/10/2017 6:37	10/23/2017	V7J0355-05	Copper	<0.020	0.0023	1.3	ppm
160-CH4356-N/A-001-A	Cafeteria Bubblers	10/10/2017 6:37	10/23/2017	V7J0355-05	Lead	10	0.45	15	ppb
160-CH4359-N/A-001-A	Hallway Bubblers	10/10/2017 6:51	10/23/2017	V7J0355-09	Copper	0.062	0.0023	1.3	ppm
160-CH4359-N/A-001-A	Hallway Bubblers	10/10/2017 6:51	10/23/2017	V7J0355-09	Lead	2	0.45	15	ppb
160-CH4362-N/A-001-A	Kitchen Prep Sink	10/10/2017 6:20	10/23/2017	V7J0355-01	Copper	0.056	0.0023	1.3	ppm
160-CH4362-N/A-001-A	Kitchen Prep Sink	10/10/2017 6:20	10/23/2017	V7J0355-01	Lead	<1	0.45	15	ppb
160-CH4364-N/A-001-A	Hallway Bubblers	10/10/2017 6:30	10/23/2017	V7J0355-03	Copper	<0.020	0.0023	1.3	ppm
160-CH4364-N/A-001-A	Hallway Bubblers	10/10/2017 6:30	10/23/2017	V7J0355-03	Lead	13	0.45	15	ppb
160-CH7376-N/A-001-A	Hallway Bubblers	10/10/2017 6:44	10/23/2017	V7J0355-07	Copper	<0.020	0.0023	1.3	ppm
160-CH7376-N/A-001-A	Hallway Bubblers	10/10/2017 6:44	10/23/2017	V7J0355-07	Lead	10	0.45	15	ppb

Analyzed by: BSK Associates Laboratory  
Reviewed by: PBS Engineering and Environmental

\*EPA action level for lead is 20 ppb and 1.3 ppm for copper