

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Applegate School Family & Early Childhood Center
August 31, 2009

Site Accessibility

Parking	On-site parking is adjacent to Cafeteria and Gym. Restripe (1) van accessible stall with access aisle. Per PPS notes, it may be helpful to relocate the accessible parking stall and signage west, closer to the accessible portable and north entry.
---------	---

Accessible Route & Features

Entry, Center South Front Doors	Verify pair doors are compliant width with pull handles, no thumb latch, panic bars at interior, and allowed closer pressures.
Entry, North	Provide accessible hardware.
Common Space Rooms	Provide all common space rooms with lever handle hardware.
Classroom doors	Provide all classrooms with lever handle hardware.

Plumbing Elements

Restroom, Boys east end	Provide accessible toilet stall, clearances, lavatory and accessories within reach ranges. Replace door with compliant entry for width and clearances.
Drinking Fountains	Verify that drinking fountain outside Classroom 2 complies with accessibility standards.

Communication Elements

Multi-Purpose 13	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage at new accessible restroom. Where signage is provided, provide accessible signage at common rooms and classrooms.

Special Spaces, Built-in Elements & Recreational Facilities

Office 24	Revise counter to include a 36" wide section at +34" AFF.
-----------	---

Field Notes:

1. No on-site play area. Limited off-site play area shared with Farragut Park.

