

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Astor School K-8
August 31, 2009

Site Accessibility

Parking	(1) On-site parking stall available at northwest parking lot. Verify signage for one van accessible stall and an 8 ft min. access aisle.
Exterior Building Ramps and Stairs	Existing access entry path/ramp from sidewalk at west main front entry is compliant with compliant handrails.

Accessible Route & Features

Stage	Add a fixed location lift at the northeast side stage room to provide accessibility for the raised stage area. Alternate location would be in the room behind the stage and accessed from the northeast middle corridor.
Special Education	Provide door hardware with lever handles.
Classroom doors	Provide all classrooms with lever handle hardware.

Plumbing Elements

Drinking Fountain	Verify that drinking fountain complies with revised accessibility standards. Verify outside Classroom 16.
Main Office	Provide an accessible sink.
Faculty 51	Provide an accessible sink.
Girls & Boys Locker Rooms	If these rooms are still being used for this function, provide accessible showers, restrooms and accessories.

Communication Elements

Multi-Purpose 44	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage at new accessible common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Boys Gym Locker	Verify if these rooms are still used for this function. If they are, then upgrade (1) locker bench to compliant requirements.
Girls Gym Locker	Verify if these rooms are still used for this function. If they are, then upgrade (1) locker bench to compliant requirements.
Office 1	Revise office counter with a fixed 36" section at + 34" AFF for accessibility. Remove existing retractable counter that does not meet Code.
Cafeteria	Verify that the serving line height is accessible.
Play Surface	There is (1) soft play area at the outside play area. Verify and test existing play structure safety surfacing at these areas. Mulch/ground cover must be solid enough to allow wheelchair access.



Play Structure	Verify that the existing play structure meets accessibility requirements, and modify if needed.
----------------	---

