

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Beaumont 6-8
August 31, 2009

Site Accessibility

West Parking	Repaint striped access aisle at ADA parking and add sign at second ADA space.
--------------	---

Accessible Route & Features

North Stair	Provide accessible handrails with extensions (approximately 120 lf of rail.)
Stage 26B	Provide power door opener at hallway to lift where clearance at the push side of the door is less than 12".
Art 119	Provide lever hardware.
Music 140	Provide lever hardware.
Home Economics 104	Provide lever hardware.
Sun Office	Provide lever hardware.
Ind Art 3	Provide a door with lever hardware from the accessible classroom to corridor in Ind Art building. Provide levers on remaining doors into any specialized classroom spaces.
Library 210	If the latches are thumb latches, replace the hardware at the corridor side with pulls or levers.
Faculty 101	Provide lever hardware.
Classrooms	Provide lever hardware as requested for program access by students and staff.

Plumbing Elements

Basement	Provide an accessible drinking fountain.
Science 134	If sinks are provided, provide one at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Home Economics 104	If sinks are provided, provide one at 34" high.
Art 119	If sinks are provided, provide one at 34" high.
Main Office	If a sink is provided, provide one at 34" high.
Locker Room 113	Provide an accessible shower with grab bars. If restrooms are provided within the locker room, provide one accessible toilet with grab bars, lavatory and accessories within reach range.
Locker Room 107	Provide an accessible shower with grab bars. If restrooms are provided within the locker room, provide one accessible toilet with grab bars, lavatory and accessories within reach range.

Communication Elements

Gym 26A (Auditorium)	Provide assisted listening devices.
Signage	Review the interior building signage. Provide accessible signs (using 60" max to bottom of the top line of text and 48" max to the bottom of Braille) at



	new accessible spaces and permanent signage at common areas where is not already provided. If signage is provided at classrooms, provide accessible signage.
--	--

Special Spaces, Built-in Elements & Recreational Facilities

Home Economics 104	Provide a sink base cabinet at 34" with either parallel approach clearance of knee clearance for forward approach. Provide a work counter 34" high and 30" beside the accessible sink counter.
Locker rooms 113 & 107	Provide one bench in each locker room with seat 20-inches deep and 42-inches long with back support.
Play Fields	Provide one bench with seat 20-inches deep and 42-inches long with back support at each sports field where benches are provided, with priority at the southeast sports field with bleachers.

