PORTLAND PUBLIC SCHOOLS - FACILITY ADA ASSESSMENT

Bridlemile School K-5 August 31, 2009

Site Accessibility

Accessible Parking	2 existing compliant parking stalls.
Portable	Add ramp and compliant stairs to portable entry door.
Classroom	

Accessible Route & Features

Cafeteria/Auditorium	Add a lift for stage access.
48	
Classroom doors	Provide all classrooms with lever handle hardware.
Exterior Doors	Provide lever hardware or pulls on exterior pair of doors next to Gym for
	access to covered play shed.

Plumbing Elements

Drinking Fountains	Verify that Gym drinking fountain complies with accessibility standards.
Office 4	Provide an accessible sink.

Communication Elements

Cafeteria/Auditorium 48	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage to common spaces. If signage is provided for classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Play Fields	Where benches are provided at play fields, provide an accessible bench.
Play Surface	Verify and test existing play structure safety surfacing. Mulch must be solid
	enough for wheelchair access.
Play Structures	Verify

Field Notes:

1. Verify that Gym shower/restrooms probably used for storage.