



CLARK

ACCESSIBILITY SUMMARY



Clark Creative Science School
1231 SE 92nd Avenue
Portland, OR 97216

SUMMARY

All common areas at Clark Creative Science are located on the ground floor. Priority should be given to providing a lift to access the stage, assisted listening devices in common rooms and classroom door lever hardware. The major accessibility upgrades for Clark Creative Science are summarized on this sheet.

ACCESSIBILITY UPGRADES TO MEET 2008 ADA GUIDELINES

| | |
|---------------------------------|--|
| Site Elements | Accessible route striping |
| Accessible Route & Reach Ranges | Classroom lever handle hardware Lift for stage access |
| Plumbing Elements | Verify gymnasium drinking fountain is fully compliant Accessible locker rooms |
| Communication Elements | Assisted listening devices in cafetorium Signage |
| Built-in Elements | Accessible benches |
| Recreational Facilities | Accessible play area soft surfacing & structure |

COST BREAKDOWN

Cost information provided is based on 2009 estimated unit costs for direct construction including general contractor overhead. Additionally, estimated hard costs and soft costs provided by PPS have been included.

| | |
|---------------------------------|------------------|
| Site Elements | \$15,032 |
| Accessible Route & Reach Ranges | \$97,152 |
| Plumbing Elements | \$39,972 |
| Communication Elements | \$8,199 |
| Special Spaces | \$0 |
| Built-In Elements | \$6,150 |
| Recreational Facilities | \$14,697 |
| Special Education | \$2,340 |
| Total | \$183,542 |