PORTLAND PUBLIC SCHOOLS - FACILITY ADA ASSESSMENT

Edwards School August 31, 2009 (K-5, Closed 2005, leased to MESD)

Site Accessibility

Parking	No on-site parking. (1) curb side accessible parking stall on SE Market St. near SE 32 nd Place. Corner curb cut is available to access the sidewalk and main entry on the east end of the building. Existing curbside parking signage.
East Entry	Main entry with step up to covered porch. Short ramp on north with non-compliant railing on outside. Single step (painted yellow) with no handrails. Provide accessible double handrails at ramp and step (approximately 40 lf of rail.)

Accessible Route & Features

East Entry	Power door operator at main front doors. Verify operation speed and timing
	with current compliance requirements.
Exterior doors to	Provide lever or pull handles on the exterior side of this pair of doors.
Play Yard	
Faculty Work	Provide lever hardware on the door.
Room	
Classroom doors	Provide all classrooms with lever handle hardware.

Plumbing Elements

	<u> </u>
Girls Restroom 11	Provide accessible toilet stall, clearances, grab bars, lavatory and accessories within children's reach ranges. Verify and modify entry door for compliant width and clearances.
Boys Restroom 12	Provide accessible toilet stall, clearances, grab bars, lavatory and accessories within children's reach ranges. Verify and modify entry door for compliant width and clearances.
Drinking Fountain	Add a new dual height drinking fountain that complies with revised accessibility standards for children and adults at existing corridor fountain location.
Workroom 1B	Provide an accessible sink.

Communication Elements

Play room 17/18	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage on new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Play Structures

Portland Public Schools October 30, 2009 Page 2