

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Forest Park K-5
August 31, 2009

Site Accessibility

n/a	
-----	--

Accessible Route & Features

Portable Classrooms	Provide lever door hardware at the three classrooms with door knobs.
---------------------	--

Plumbing Elements

n/a	
-----	--

Communication Elements

Gym 113	Provide assisted listening devices.
Signage	Provide accessible signage at common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Play Pit	Review the play area structures for compliance, and modify if needed.
Play Pit	Review the play pit surface material, and provide an accessible route to the play structures (approximately 1,200 sf.)
Play Pit	Provide an accessible bench with seat 20-inches deep and 42-inches long and with back support at the play area.

