

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Foster (Mt.Scott Learning Center MS Program, leased)
August 31, 2009

Site Accessibility

North Parking	(1) accessible stall with accessible aisle at north parking by building. Restripe stall and access aisle.
East Parking	No accessible stalls at east parking next to building.

Accessible Route & Features

Cafeteria 06	Exterior access entry door. Verify for threshold compliance and compliant door handle hardware.
Rooms 01, 02, Office	Interior room access entry's from common corridor. Verify for compliant door handle hardware.
Reading Rec 17, Play 16, Rooms 04, 05	Exterior access entry doors. Verify for threshold compliance and compliant door handle hardware.
Minor Rooms 03, 12, 13, 15, 18	Verify for threshold compliance and compliant door handle hardware
Portable Classroom	Add compliant ramp (approximately 30lf) and stairs (approximately 5R) up to single portable classroom entry.
Classrooms	Provide lever handle hardware at all classroom entry doors.

Plumbing Elements

Boys Restroom 10	Provide an accessible toilet stall, clearances, toilet, grab bars, lavatory and accessories within reach ranges. Verify or replace entry doors for compliant width and clearances.
Girls Restroom 11	Provide an accessible toilet stall, clearances, toilet, grab bars, lavatory and accessories within reach ranges. Verify or replace entry doors for compliant width and clearances.
Adult Unisex Restroom 12	Provide an accessible toilet, clearances, grab bars, lavatory and accessories within adult reach ranges. Verify or replace entry doors for compliant width and clearances.
Drinking Fountain	One compliant height drinking fountain on the main floor.
Office/Faculty	If a sink is provided, provide an accessible sink.

Communication Elements

Signage	Provide accessible signage at new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.
---------	---

Special Spaces, Built-in Elements & Recreational Facilities

Play Areas	There are (0) soft surfacing play areas at this school.
------------	---



Field Notes:

1. All exterior paving striping, either for parking or play areas, is invisible and not maintained. Paved areas have overgrown grasses and weeds between paving cracks. Lawn/landscape areas are kept mowed.

