

# PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

George 6-8  
August 31, 2009

## Site Accessibility

n/a	
-----	--

## Accessible Route & Features

Stage 111	Reconfigure the doors and walls at rooms 112 and 112A to allow a ramp with handrails to be provided instead of the 3-riser stair leading to the backstage/stage level (approximately 20 lf of ramp.)
Auditorium 110	Provide a replacement pair of doors with one 3 foot leaf, and provide lever hardware.
Sun Office	Provide lever hardware.
Computer Room	Provide lever hardware.
Heath Room	Provide lever hardware.
Home Economics 206	Provide lever hardware.
Fine Art 100	Provide lever hardware.
Science	Provide lever hardware.
Industrial Art 123	Provide lever hardware.
Faculty 303	Provide lever hardware.
Courtyards	Provide lever hardware on one door to each of the four courtyards.
Classrooms	Provide lever hardware as requested for program access by students and staff (approximately 23 classrooms.)

## Plumbing Elements

Boys Locker 127	Provide an accessible shower with grab bars. Provide one accessible toilet with grab bars, lavatory and accessories within reach range.
Girls Locker 134	Provide an accessible shower with grab bars. Provide one accessible toilet with grab bars, lavatory and accessories within reach range.
Office 105	Provide a sink at 34" high.
Home Economics 206	Provide a sink at 34" high.
Fine Art 100	Provide a sink at 34" high.
Science	Provide a sink at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Industrial Art 123	Provide a sink at 34" high.
Faculty 303	Provide a sink at 34" high.

## Communication Elements

Auditorium 110	Provide assisted listening devices.
Signage	Review the interior building signage. Provide accessible signs (using 60" max to bottom of the top line of text and 48" max to the bottom of Braille) at new accessible spaces and permanent signage at common areas where is not already provided. If signage is provided at classrooms, provide



	accessible signage.
--	---------------------

Special Spaces, Built-in Elements & Recreational Facilities

Home Economics 206	Provide a work counter 34" high and 30" beside the accessible sink counter.
Auditorium 110	Provide four wheelchair and companion seats where the floor is, or can be remodeled to be level, and out of the aisles.
Boys Locker 127	Provide one bench in the locker room with seat 20-inches deep and 42-inches long with back support.
Girls Locker 134	Provide one bench in the locker room with seat 20-inches deep and 42-inches long with back support.

