

# PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Green Thumb  
August 31, 2009

## Site Accessibility

Parking	(2) existing accessible stalls with access aisle at the east parking lot.
Signage	Add directional signage from accessible stalls to various buildings and areas.

## Accessible Route & Features

Portable Classrooms	Add a compliant ramp and stairs to access each class from one common landing.
Auxiliary Buildings	Verify that door thresholds and door hardware are accessibility compliant.

## Plumbing Elements

Unisex Restroom	Add an accessible unisex restroom available for adults and students.
Shower/ Changing Rooms	If shower facilities are provided, provide accessible men's and women's shower. They can be unisex lockable.
Exterior Wash Down	Provide accessible exterior wash down areas to remove mud from boots and shoes and rainwear.

## Communication Elements

Signage	Provide accessible signage for accessible and common use areas.
Classrooms / Outside Work areas	If sound amplifying equipment is used for this program, Any need availability for assisted listening devices in the classrooms, different outdoor areas or indoor greenhouse areas.

## Special Spaces, Built-in Elements & Recreational Facilities

Exterior Bench	Provide an accessible bench near existing picnic table location.
Changing room Bench	If a changing room with a bench is provided in this program, provide an accessible bench.

