PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Gregory Heights (Roseway Heights) K-8 August 31, 2009

Site Accessibility

· · · · · · · · ·	
West Parking	Provide curb ramps from the two striped areas onto sidewalk, and verify that
	curb ramps exist on either side of the vehicular crossing. (This is high traffic
	crossing area with relatively low visibility because of the tree growth.)

Stair at Room 190	Provide double height handrails with extensions (approximately 96 lf.)	
Health Center	Provide lever door hardware.	
Faculty 122	Provide lever door hardware.	
Ind Arts 129	Provide lever door hardware.	
Girls Locker 145	Provide lever door hardware or pulls.	
Boys Locker 155	Provide lever door hardware or pulls.	
Art 185	Provide lever door hardware.	
Science 168	Provide lever door hardware.	
Music	Provide lever door hardware.	
Home Economics	Provide lever door hardware.	
Room 137	Provide lever hardware on door to stage of Multi-Purpose room.	
Classrooms	Provide lever hardware as requested for program access by students and	
	staff (approximately 33 classrooms.)	

Accessible Route & Features

Plumbing Elements

Training Elementa	
Girls Locker 145	Provide an accessible shower with grab bars.
Boys Locker 155	Provide an accessible shower with grab bars.
Office 101	Provide a sink at 34" high.
Faculty 122	Provide a sink at 34" high.
Ind Arts 129	Provide a sink at 34" high.
Art 185	Provide a sink at 34" high.
Science 168	Provide a sink at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Home Economics	Provide a sink at 34" high.
182?	

Communication Elements

West Entry	Add visual two-way communications with either an added for replacement	
	device at this locked ADA entry.	
Multi-Purpose	Provide assisted listening devices.	
Room 196		
Big Gym 159	Provide assisted listening devices.	
Signage	Review the interior building signage. Provide accessible signs (using 60"	
	max to bottom of the top line of test and 48" max to the bottom of Braille) at	
	new accessible spaces and permanent signage at common areas where is	
	not already provided. If signage is provided at classrooms, provide	

ANKROM MOISAN ARCHITECTURE INTERIORS PLANNING

PORTLAND: 6720 SW MACADAM, PORTLAND, OREGON 97219 | 503-245-7100 SEATTLE: 117 S MAIN STREET, SUITE 400, SEATTLE, WASHINGTON 98104 | 206-576-1600

accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Home Economics	Provide a work counter 34" high and 30" beside the accessible sink
182?	counter.
Girls Locker 145	Provide a bench with seat 20-inches deep and 42-inches long with back
	support at each sports field where benches are provided.
Boys Locker 155	Provide a bench with seat 20-inches deep and 42-inches long with back
	support at each sports field where benches are provided.
Play Fields	Provide a bench with seat 20-inches deep and 42-inches long with back
	support at each sports field where benches are provided.