

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Hayhurst School K-5
August 31, 2009

Site Accessibility

Parking	(3) accessible spaces at east parking lot. Mark crosswalk across vehicle route to curbcut and accessible sidewalk.
South Entry	Double pair entry doors. One door leaf has a power operator.

Accessible Route & Features

Cafeteria/Auditorium 31	Provide a lift for access to the stage.
Cafeteria/Auditorium 31	Verify size and clearances on northwest pair of entrance doors. Update for required clearances, and update with lever handle hardware on the pull side. Interior should be panic hardware.
Gymnasium 27	Verify size and clearances on southwest pair of entrance doors. Update for required clearances, and update with lever handle hardware on the pull side. Interior should be panic hardware. No thumb latch hardware.
Computer Room	Provide lever hardware on the door.
Classroom doors	Provide all classrooms with lever handle hardware.
Girls 13C	Provide an automatic door operator on the pull side of the door where pull side clearance is negligible.

Plumbing Elements

Girls 13C	Verify that the fixtures in the room have already been updated to be accessible, as shown in the facility plan, and modify if needed.
Adult Unisex 8C	Convert Room 8C to comply with current accessibility standards for use as an adult accessible restroom (former staff unisex restroom, currently used for storage).
Drinking Fountains	Replace drinking fountain outside Classroom 14 in main N/S corridor with a dual height fountain for children and adults.
Girls Locker	If this room is being used for this function, provide an accessible toilet, stall, grab bars, lavatory, accessories and shower.
Boys Locker	If this room is being used for this function, provide an accessible toilet, stall, grab bars, lavatory, accessories and shower.
Office/Faculty	Provide an accessible sink.

Communication Elements

Cafeteria/Auditorium 31	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage at new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.



Special Spaces, Built-in Elements & Recreational Facilities

Office	Provide an accessible section of lowered counter.
Girls Locker	Provide an accessible bench.
Boys Locker	Provide an accessible bench.
Play Fields	At fields where benches are provided, provide an accessible bench.
Play Surface	There are (2) soft play areas at the outside play area. Verify and test the play structure safety surfacing. Mulch/ground cover must be solid enough to allow wheelchair access.
Play Structure	Verify that one play structure is accessible, and modify if needed.

