

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Jackson 6-8
August 31, 2009

Site Accessibility

n/a	
-----	--

Accessible Route & Features

Elevator	Provide an elevator to provide access from the first floor gymnasium to the locker rooms and team rooms on the basement level. One possible location for the elevator would be on the west wall of the apparatus room. A door would also need to be added to provide access to the girls locker room from the apparatus room. (Alternatively, the elevator could be located west of the gymnasium building if approximately 100 lf of new corridor were added to the first floor and basement.)
Ramp	Confirm accessible interior ramp slopes and handrails from the corridor outside Choral C121 to Home Economics Room C135, and modify the ramps, floor and handrails if needed to reach compliance.
Handrails to 2 nd Floor	Verify handrails at both stairs to the second floor, and provide accessible handrails with extensions if needed for compliance (approximately 96lf of rail.)
Handrails to Basement	Verify handrails at both stairs to the basement, and provide accessible handrails with extensions if needed for compliance (approximately 104lf of rail.)
Sun Office 125	Provide lever door hardware.
Choral Room C121	Provide lever door hardware.
Dark Room D129	Provide lever door hardware.
Home Economics C135	Provide lever door hardware.
Art C138	Provide lever door hardware.
Faculty Dining D147	Provide lever door hardware.
Store D124	Provide lever door hardware.
Telev D164	Provide lever door hardware.
Band Room	Provide lever door hardware.
Shop Building	If program is provided in this building, provide lever door hardware.
Apparatus Room	Provide lever door hardware of pulls on two pairs of doors.
Boys Locker Room	Provide lever door hardware or pulls.
Girls Locker Room	Provide lever door hardware or pulls.
Classrooms	Provide lever door hardware as requested for program access by students and staff (approximately 40 classrooms.)

Plumbing Elements

Basement	Provide an accessible drinking fountain.
Science	If sinks are provided, provide one at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.



Home Economics C135	If sinks are provided, provide one at 34" high.
Art C138	If sinks are provided, provide one at 34" high.
Main Office/Unit Office	If a sink is provided, provide one at 34" high.
Boys Locker Room	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Girls Locker Room	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.

Communication Elements

Signage	Provide ADA parking signs at three stalls, and provide wheelchair only signage at ADA Van parking stalls.
Signage	Review the interior building signage. Provide accessible signs (using 60" max to bottom of the top line of text and 48" max to the bottom of Braille) at new accessible spaces and permanent signage at common areas where is not already provided. If signage is provided at classrooms, provide accessible signage.
Auditorium / Multi-Purpose	Provide assisted listening devices.

Special Spaces, Built-in Elements & Recreational Facilities

Home Economics C135	Provide a work counter 34" beside the accessible sink.
Girls Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Boys Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Play Fields	Provide a bench with seat 20-inches deep and 42-inches long with back support at each sports field where benches are provided.

