

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Kellogg 6-8
August 31, 2009

Site Accessibility

Parking	Re-paint ADA parking stall indicators and striping.
Handrails	Provide handrails with extensions at east exterior stairs of the main building (approximately 18 lf of rail.)

Accessible Route & Features

Elevator	Provide a 4-stop elevator to allow access to both ground levels of main and north buildings, and first and second floors of the main building. One possible location for the elevator is in place of the existing northwest stair in the main building. The floor-level transition stair from the north building would also need to be removed and rebuilt clear of the elevator door. The elevator addition would also include adjacent corridor remodel (approximately 30 lf.)
Stair	Provide stair with accessible handrails at floor transitions from main to north building (approximately 6R.)
3 rd Floor Corridor	Remodel classroom 307 and 327 walls on the third floor to allow access to the new elevator from the east half of the third floor, and to allow emergency egress from more than one stair at the west half of the third floor (approximately 70 lf of corridor.)
Lift	Provide a lift for access from the ground floor level to the cafeteria.
Handrails	Provide accessible handrails with extensions at the southwest stair (approximately 128 lf of rail.)
Office 217	Provide lever door hardware.
Faculty 126	Provide lever door hardware.
Cafeteria 122	Provide lever door hardware.
Library/Media Center 230	Provide 2 sets lever door hardware.
Title 1 240	Provide lever door hardware.
Computer Lab 242	Provide 2 sets lever door hardware.
Music 160	Provide lever door hardware.
Science Lab 118	Provide lever door hardware.
Home Economics 120?	Provide lever door hardware.
Art 112?	Provide lever door hardware.
Boys Locker Room 146	Provide 4 sets lever door hardware or pulls.
Girls Locker Room 155	Provide 4 sets lever door hardware or pulls.
Ind Arts 413	Provide lever door hardware.
S.A.I. 400	Provide lever door hardware.
Girls RR 401	Provide lever door hardware or pulls.
Boys RR 402	Provide lever door hardware or pulls.
Staff RR (next to 404)	Provide lever door hardware.



Classrooms	Provide lever door hardware as requested for program access by students and staff (approximately 30 classrooms.)
------------	--

Plumbing Elements

Drinking Fountains	Provide accessible drinking fountains on the second floor, third floor, and in the east building.
Staff Restroom	Provide one staff restroom, potentially either west of 111, or between 228 and 229 near the office.
Girls & Boys Restrooms on 2 nd & 3 rd Floors 208, 235, 318, 319	Provide an accessible toilet with grab bars, lavatory and accessories within reach range for each of 4 rooms.
Boys Locker Room 146	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Girls Locker Room 155	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Girls RR 401	Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Boys RR 402	Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Staff RR (next to 404)	Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Office 217	If sinks are provided, provide one at 34" high.
Science Lab 118	If sinks are provided, provide one at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Art 112?	If sinks are provided, provide one at 34" high.
Faculty 126	If sinks are provided, provide one at 34" high.
Home Economics 120?	If sinks are provided, provide one at 34" high.

Communication Elements

Main Entry (North wing from 69 th Ave)	Provide a two-way audio/visual communications device to the office.)
Signage	Provide accessible signage at Stage/Lift.
Signage	Provide accessible signage at new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.
Gymnasium 2	Provide assisted listening devices.

Special Spaces, Built-in Elements & Recreational Facilities

Boys Locker Room 146	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Girls Locker Room 155	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Home Economics	Provide a work counter 34" high and 30" beside the accessible sink



120?	counter.
Office 217	Provide a lowered transaction counter at 34".
Library/Media Center 230	Provide a lowered transaction counter at 34".
Cafeteria 122	Confirm the height of the serving line is accessible, and lower if needed.
Play Fields	Provide a bench with seat 20-inches deep and 42-inches long with back support at each sports field where benches are provided.

