

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Mt. Tabor School 6-8
August 31, 2009

Site Accessibility

South Parking	(2) existing accessible stalls and related access aisles. Verify van parking access aisle is 8 ft wide. Provide striped crosswalk connector from access aisle to paved entry walk.
---------------	--

Accessible Route & Features

North Front Entry (stair access only)	Verify front pair doors have 32" clear opening. Verify panic bars inside, pull on exterior, no thumb latches. Adjust closer pressures to 8 lbs maximum for exterior doors.
Stage	Add lift within north back stage room. Add new lift access door directly to Media Center 121 behind.
Classroom doors	Provide all classrooms not already updated with lever handle hardware.

Plumbing Elements

Drinking Fountains	Verify that Cafeteria/Auditorium drinking fountain complies with accessibility standards.
Boys Lockers (off Gym 114)	Provide an accessible toilet, stall, grab bars, lavatory, accessories, and shower.
Girls Lockers (off Gym 114)	Provide an accessible toilet, stall, grab bars, lavatory, accessories, and shower.
Classroom sinks	At one of each type of classroom where sink are used for that program (science, industrial arts, home economics) provide an accessible sink.
Office/Faculty	If a sink is provided, provide an accessible sink.

Communication Elements

Cafeteria/Auditorium 123	Provide assisted listening devices.
Multi-Purpose 137	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide signage at new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Home Economics	Provide an accessible work surface adjacent to the accessible sink.
Boys Lockers (off Gym 114)	Provide compliant bench with backrest at one existing bench (verify if benches still exist, or have been removed)
Girls Lockers (off Gym 114)	Provide compliant bench with backrest at one existing bench.

