

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Rosa Parks School K-5
 August 31, 2009

Site Accessibility

Parking	No on-site parking spaces. Site has shared parking.
---------	---

Accessible Route & Features

	No accessible route items
--	---------------------------

Plumbing Elements

	No plumbing items
--	-------------------

Communication Elements

Media Center/Library B122	Provide assisted listening devices.
Cafeteria Commons A123	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Verify accessible signage is provided at accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Weight Room	Verify that accessible clearance is provided around at least one of each type of exercise equipment.
Play Surface	There is (1) soft play area at the shared outside play area. Verify and test existing play structure safety surfacing at this area. Mulch/ground cover must be solid enough to allow wheelchair access.
Play Structure	Verify that the existing play structure is accessible, and modify if needed.

