

# PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Scott School K-7  
August 31, 2009

## Site Accessibility

West Parking	2 accessible stalls available. Verify size and spacing of stalls and aisles per compliant guidelines.
Prescott Front Stairs	Add handrails at building 4-step grand entry stairs leading to north front doors (approximately 24 lf of handrail.) Although not required, it would improve accessibility to add ramp access at same location (approximately 24 lf of ramp.)
Entry from Play Yard to Multi-Purpose Room	Provide accessible double handrails (approximately 44 lf of rail.)

## Accessible Route & Features

Elevator	Add 3 stop elevator to access basement Cafeteria, main building level and upper level Gym/Multi-Purpose. Possible location would be from the south portion of the staff office 209 behind the Unisex restroom. Access would be from Corridor C202 leading to the east playground. Basement access would require below grade excavation, and would open to the larger storage room 85 at the northeast corner of the Cafeteria. Upper access to the Gym/Multipurpose would enter at the northeast corner of the Gym.
Stage	Provide a lift to access the stage.
Front Entry Corridor Stairs	Verify for compliant double handrails at the interior front entry stairs, and stair to basement. Modify or replace if required (approximately 80 lf of rail.)
Ramp at Mid-N-S Corridor	Verify the slope of the existing corridor ramp to the Media Center. If the slope is less than 1:10 then verify accessible double handrails. If slope is greater than 1:10, provide a replacement accessible ramp (approximately 80 lf of ramp or 320 lf of rail?)
Classroom doors	Provide all classrooms with lever handle hardware.
Cafeteria	Replace (2) 2-8 doors with an unequal 3-0/2-4 pair with lever hardware.
Multi-purpose Room	Provide lever door hardware.
PTA Workshop	Provide lever door hardware.
Classroom Building	Provide lever door hardware.
Classroom Building	Provide a ramp or lift in place of the 4 north interior steps (approximately 24 lf of ramp).

## Plumbing Elements

Boys 655, East Classroom Bldg	Modify toilet partition to provide accessible stall, and provide accessible toilet, grab bars, lavatory and accessories. Verify entry door for width and required clearances.
Girls 657, East	Modify toilet partition to provide accessible stall, and provide accessible



Classroom Bldg	toilet, grab bars, lavatory and accessories. Verify entry door for width and required clearances.
Drinking Fountain, East Classroom Building	If a drinking fountain is provided, provide an accessible drinking fountain.
Office/Faculty	Provide an accessible sink.
Art	If a sink is provided, provide an accessible sink.

Communication Elements

Entry, West	If this entry is locked during school hours, provide 2-way communications at this door located closest to the accessible parking
Multi-Purpose Room/Gym	Provide assisted listening devices.
Cafeteria	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage	Provide accessible signage at new accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Play Surface	There is one play structure area at this school. Verify and test existing play structure safety surfacing. Surface must be solid enough to allow wheelchair access, and still fulfill impact fall standards for the specific installed equipment.
Play Structure	Verify that the existing play structure is accessible, and modify if needed.

Field Notes:

1. If ramp cannot be updated to full compliance, additional Boys and Girls restrooms should be updated for accessibility at the Media Center lower level (Rooms 450 & 453) to improve accessibility.

