PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Sitton School K-5
August 31, 2009

Site Accessibility

Northeast Parking		2 accessible stalls available. Verify size and spacing of stalls and aisles per compliant guidelines.

Accessible Route & Features

Classroom doors		Provide all classrooms with lever handle hardware.
Stage		Provide a lift to access the stage.

Plumbing Elements

Drinking Fountains		Upgrading the existing fountain outside Media Center to provide a dual height fountain at compliant heights for children and adults is recommended for use by the gym.
Office/Faculty		If a sink is provided, provide an accessible sink.
Art		If a sink is provided, provide an accessible sink.
Boys Lockers		If this room is still used for this function (as opposed to storage in many K-5 facilities) then provide an accessible toilet, stall, grab bars, lavatory, accessories, and shower.
Girls Lockers		If this room is still used for this function (as opposed to storage in many K-5 facilities) then provide an accessible toilet, stall, grab bars, lavatory, accessories, and shower.

Communication Elements

Cafeteria/Auditorium		Provide assisted listening devices.
Classrooms		Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Signage		Verify that accessible signage is provided at accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Boys Lockers		Provide compliant bench with backrest at portion of one existing bench.
Girls Lockers		Provide compliant bench with backrest at portion of one existing bench.
Play Surface		There is one multi-structure play area at this school. Verify and test existing play structure safety surfacing. Surface must be solid enough to allow wheelchair access, and still fulfill impact fall standards for the specific installed equipment.
Play Structure		Verify that the existing play structure is accessible, and modify if needed.