

# PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Tubman 6-10  
August 31, 2009

## Site Accessibility

West Parking	Review the three ADA parking spaces in the west parking lot. The access aisle between two of the spaces is shaped in a triangle. However, if access to the sidewalk/entry is available without travel back into the parking lot, the aisle configuration will function as intended.
--------------	---

## Accessible Route & Features

Stair at N Flint Entry	Verify that accessible handrails with extensions are provided, and replace if needed (approximately 52 lf.)
Library	Provide lever hardware on the pair of doors.
Girls Locker Room	Provide lever door hardware or pulls.
Boys Locker Room	Provide lever door hardware or pulls.
ERC 125	Provide lever door hardware.
Art 156	Provide lever door hardware.
Home Economics 155	Provide lever door hardware.
Faculty (next to 156)	Provide lever door hardware.
AV 214	Provide lever door hardware.
Science 215	Provide lever door hardware.
Photography 132	Provide lever door hardware.
Classrooms	Provide lever door hardware as requested for program access by students and staff (approximately 32 classrooms.)
Handrails	Verify that accessible handrails are provided to at least one stair to the mezzanine (approximately 30 lf of rail.)

## Plumbing Elements

Office	Provide a sink at 34" high.
Art 156	Provide a sink at 34" high.
Home Economics 155	Provide a sink at 34" high.
Science 215	Provide a sink at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Photography 132	Provide a sink at 34" high.

## Communication Elements

Commons AV Room 130 AV Room 214	Provide assisted listening devices.
Signage	Verify that accessible signage is provided at accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.



Special Spaces, Built-in Elements & Recreational Facilities

Girls Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Boys Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Home Economics 155	Provide a work counter 34" high and 30" beside the accessible sink counter.

