

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

West Sylvan 7-8
August 31, 2009

Site Accessibility

n/a	
-----	--

Accessible Route & Features

Elevator	Provide an elevator for access to the second floor classrooms. One possible location for the elevator is adjacent to classroom 20 opening to the corridor.
Handrails	Provide accessible handrails with extensions at the stair beside classroom 20 (approximately 48 lf of rail.)
Handrails	Provide accessible handrails with extensions at the stairs at the north end of Gym 2 (approximately 36 lf of rail.)
Lift	Provide a lift to the M.P. room 196 stage (6R approximately 3 feet.)
Girls Locker Room	Provide lever door hardware.
Boys Locker Room	Provide lever door hardware.
Staff Lounge (Faculty 27?)	Provide lever door hardware.
M.P. 196	Provide lever door hardware.
Shop 130	Provide lever door hardware.
Home Economics 134	Provide lever door hardware.
Choir	Provide lever door hardware.
Band 140	Provide lever door hardware.
Science (126?)	Provide lever door hardware.
Health Center	Provide lever door hardware.
Courtyard	Provide lever door hardware.
Classrooms	Provide lever hardware as requested for program access by students and staff (approximately 37 classrooms.)

Plumbing Elements

Drinking Fountains	Provide an accessible drinking fountain on the basement and 2 nd floor levels.
Girls Locker Room	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Boys Locker Room	Provide an accessible shower with grab bars. Provide an accessible toilet with grab bars, lavatory and accessories within reach range.
Office	If a sink is provided, provide a sink at 34" high.
Staff Lounge (Faculty 27?)	If a sink is provided, provide a sink at 34" high.
Home Economics 134	Provide a sink at 34" high.
Science (126?)	Provide a sink at 34" high. If gases are provided, provide one at 34" high counter and within accessible reach ranges.
Shop 130	Provide a sink at 34" high.



Communication Elements

M.P. 196	Provide assisted listening devices.
Gym 2/Stage	Provide assisted listening devices.
Signage	Review the interior building signage. Provide accessible signs (using 60" max to bottom of the top line of text and 48" max to the bottom of Braille) at new accessible spaces and permanent signage at common areas where is not already provided. If signage is provided at classrooms, provide accessible signage.

Special Spaces, Built-in Elements & Recreational Facilities

Girls Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Boys Locker Room	Provide a bench with seat 20-inches deep and 42-inches long with back support.
Home Economics 134	Provide a work counter 34" high and 30" beside the accessible sink counter.
Play Area Equipment	Review the play area structures for compliance.
Play Area Surface	Provide an accessible surface material at play area structures (approximately 800 sf.)

