

PORTLAND PUBLIC SCHOOLS – FACILITY ADA ASSESSMENT

Whitman School
August 31, 2009

K-5

Site Accessibility

Parking	(2) accessible on-site parking spaces marked and striped. No pathway marked from parking spaces to front entry. Provide striped path across vehicular way, and detectable warnings.
Main North Entry	Verify entry (1) pair of doors has minimum 32-inch swing requirement and compliant accessible hardware. Otherwise, replace one set of double doors with (1) 3-0 compliant door.

Accessible Route & Features

Stage 31A	Add a lift to northeast side of backstage area adjacent to the corridor to provide accessibility for the raised stage area.
Gym 35	Revise (1) north pair of entry doors with swing clear hinges and appropriate closers to ensure minimum 32-inch single door clearances. (Doors are existing 2'-8" pairs.) Otherwise, replace with 3-0/2-4 unequal pair doors for compliance.
Cafe 31	Verify (1) south pair of entry doors has swing clear hinges and appropriate closers to ensure minimum 32-inch single door clearances. (Doors are existing 2'-8" pairs.) Otherwise, replace with 3-0/2-4 unequal pair doors for compliance. Verify doors to serving are 32" clear with lever hardware.
Sun Office	Provide lever door hardware.
Classroom doors	Provide all classrooms with lever handle hardware. (26) classrooms.

Plumbing Elements

Office	Provide an accessible sink.
Art	Provide an accessible sink.
Boys Locker Room	If this space is still used for this function (as opposed to storage etc) then provide an accessible toilet, stall, grab bars, lavatory, accessories and shower.
Girls Locker Room	If this space is still used for this function (as opposed to storage etc) then provide an accessible toilet, stall, grab bars, lavatory, accessories and shower.

Communication Elements

Cafetorium 14	Provide assisted listening devices.
Classrooms	Any need for assisted listening devices in programs at this school? Or within SPED classrooms?
Interior Signage	Verify accessible signage at accessible restrooms and common spaces. If signage is provided at classrooms, provide accessible signage.



Special Spaces, Built-in Elements & Recreational Facilities

Cafeteria Serving	Verify serving counter height is max 30" per PPS requirements, and that width is accessible.
Boys Locker Room	If this space is still used for this function then provide an accessible bench.
Girls Locker Room	If this space is still used for this function then provide an accessible bench.
Play Surfaces	There are (2) soft play areas at the outside play areas. Verify and test existing play structure safety surfacing at these areas. Mulch/ground cover must be solid enough to allow wheelchair access.
Play Structures	Verify that at least one of the existing play structures is accessible, and modify if needed.

