



ABERNETHY

ACCESSIBILITY SUMMARY



Abernethy School
2421 SE Orange Avenue
Portland, OR 97214

SUMMARY

Most common areas at Abernethy are located on the main floor. Priority should be given to providing an elevator for second floor classroom access at this school. The elevator, door hardware and plumbing on floors other than the main level comprise the majority of the upgrade work. The major accessibility upgrades for Abernethy are summarized on this sheet.

ACCESSIBILITY UPGRADES TO MEET 2008 ADA GUIDELINES

Site Elements	On-street accessible parking
Accessible Route & Reach Ranges	Elevator for access to second floor classrooms Lift or ramp for access to stage Replacement handrails in one main stairway Lever hardware on doors
Plumbing Elements	Accessible student restrooms on second floor Accessible staff restroom on second floor
Communication Elements	Interior signage at upgraded accessible rooms Assisted listening devices Signage
Recreational Facilities	Play area soft surfacing

COST BREAKDOWN

Site Elements	\$0
Accessible Route & Reach Ranges	\$527,324
Plumbing Elements	\$33,484
Communication Elements	\$9,110
Special Spaces	\$0
Built-In Elements	\$0
Recreational Facilities	\$42,402
Special Education	\$0
Total	\$612,320