



FRANKLIN

ACCESSIBILITY SUMMARY



Franklin High School
5405 SE Woodward Street
Portland, OR 97206

SUMMARY

Most common facilities at Franklin are located on the round floor, and Franklin has one existing elevator. Priority should be given to providing additional elevators and lifts for access to the basement cafeteria and gym locker levels. The elevators, ramp, door hardware and plumbing on floors other than the main level comprise the majority of the upgrade work. The major accessibility upgrades for Franklin are summarized on this sheet.

This recreational seating at Franklin is a good example which illustrates a situation where compliance with the new requirement for wheelchair and companion seating may involve modifications to existing bleachers.



Accessible Seating Requirements

ACCESSIBILITY UPGRADES TO MEET 2008 ADA GUIDELINES

Site Elements	Restripe accessible stall and aisle at east parking lot Restripe accessible stalls and aisle at west parking lot Accessible route striping Accessible ramp at main building entry Accessible exterior handrails at exterior stadium stairs
Accessible Route & Reach Ranges	Southwest entry directional signage Classroom lever handle hardware Guardrails & handrails at interior central stairs Accessible handrails Elevator for access to cafeteria, auditorium and balcony Elevator and lifts for access to gymnasium and lower exercise and apparatus rooms
Plumbing Elements	Accessible boys and girls restrooms at first floor, southwest building Accessible boys and girls restrooms at field house Accessible boys and girls restrooms at auto shop Accessible drinking fountains on each floor
Special Spaces	Wheelchair and companion seating in auditorium
Built-In Elements	Accessible benches Accessible service counter
Communication Elements	Assisted listening devices in auditorium and cafeteria Signage
Recreational Facilities	Accessible clearance at exercise equipment

COST BREAKDOWN

Cost information provided is based on 2009 estimated unit costs for direct construction including general contractor overhead. Additionally, estimated hard costs and soft costs provided by PPS have been included.

Site Elements	\$79,750
Accessible Route & Reach Ranges	\$1,564,176
Plumbing Elements	\$99,576
Communication Elements	\$28,584
Special Spaces	\$0
Built-In Elements	\$13,210
Recreational Facilities	\$4,555
Special Education	\$9,360
Total	\$1,799,212