



# MADISON

## ACCESSIBILITY SUMMARY



Madison High School  
2735 NE 82nd Avenue  
Portland, OR 97220

### SUMMARY

Most common facilities at Madison are located on accessible floors, but common areas and specialized classrooms are also located in inaccessible areas of the basement. Priority should be given to providing an elevator for basement apparatus room access at this school. The elevator, door hardware and plumbing on floors other than the main level comprise the majority of the upgrade work. The major accessibility upgrades for Madison are summarized on this sheet.

### ACCESSIBILITY UPGRADES TO MEET 2008 ADA GUIDELINES

Site Elements	Restriped accessible parking stalls and pedestrian route Accessible curb cuts
Accessible Route & Reach Ranges	Elevator for gymnasium and basement access Accessible 2 pairs of gymnasium entry doors Accessible handrails Accessible doors and hardware at NW cafeteria entry Classroom lever door hardware
Plumbing Elements	Accessible boys and girls restrooms at locker rooms Accessible showers at boys A-7 and girls A-6 Accessible sinks
Communication Elements	Assisted listening devices at auditorium and cafeteria Signage
Special Spaces	6 wheelchair spaces and companion seating at auditorium
Built-In Elements	Accessible benches at boys, girls locker and team locker rooms
Recreational Facilities	Accessible clearances at exercise equipment

### COST BREAKDOWN

Cost information provided is based on 2009 estimated unit costs for direct construction including general contractor overhead. Additionally, estimated hard costs and soft costs provided by PPS have been included.

Site Elements	\$37,509
Accessible Route & Reach Ranges	\$645,395
Plumbing Elements	\$47,444
Communication Elements	\$33,471
Special Spaces	\$0
Built-In Elements	\$20,498
Recreational Facilities	\$4,555
Special Education	\$7,020
Total	\$795,893