




# Airflow Testing Report

Prepared for

Portland Public Schools

August 2021





9700 SW Capitol Hwy, Suite 110  
Portland, OR 97219  
ameresco.com

## PROJECT OVERVIEW

As part of the continuing process to ensure a safe return to in-person learning, Portland Public Schools has contracted with Ameresco to test the airflow and ventilation of all educational and office spaces in each school. The data is reviewed by both Ameresco and PPS personnel to identify any potential shortcomings in the airflow from the HVAC systems. To accomplish this task, Ameresco has partnered with a local NEBB certified Test-Adjust-Balance (TAB) firm, Neudorfer Engineers, who will measure the airflow to each zone with calibrated measurement equipment in accordance with current testing standards and procedures. As part of this effort, HVAC professionals will review the operation of the HVAC equipment serving every educational and office space in each school.

Ameresco is pleased to have partnered with PPS over the last decade as the district's Energy Services Company (ESCO) on six energy efficiency construction projects, four service projects, and numerous energy audits. Our partnership has resulted in reducing over 3,000 tons of CO<sub>2</sub> and other GHG emissions and over \$1,000,000 in utility cost savings per year. Ameresco appreciates this opportunity to play a small role in the safe reopening of schools.

### About Ameresco, Inc.

Founded in 2000, Ameresco, Inc. (NYSE:AMRC) is a leading cleantech integrator and renewable energy asset developer, owner and operator. Our comprehensive portfolio includes energy efficiency, infrastructure upgrades, asset sustainability and renewable energy solutions delivered to clients throughout North America and the United Kingdom. Ameresco's sustainability services in support of clients' pursuit of Net Zero include upgrades to a facility's energy infrastructure and the development, construction, and operation of distributed energy resources. Ameresco has successfully completed energy saving, environmentally responsible projects with Federal, state and local governments, healthcare and educational institutions, housing authorities, and commercial and industrial customers. With its corporate headquarters in Framingham, MA, Ameresco has more than 1,000 employees providing local expertise in the United States, Canada, and the United Kingdom. For more information, visit [www.ameresco.com](http://www.ameresco.com).

## Explanation of ASHRAE Total Effective Air Changes per Hour (ACH<sub>e</sub>) Calculation

ASHRAE has been updating their Building Readiness document to reflect the most current understanding in the engineering community for how to operate and maintain buildings during the pandemic. Their update on 4/27/2021 provided an explanation of the impact air filters and air cleaning devices have on the air in buildings. They provided the methodology, formulas, and an Excel-based tool for determining the equivalent outside air a space is receiving by having a mix of outside air, filtered recirculated air, and additional air filtration or cleaning devices in the room. Here is the explanation from ASHRAE:

### Epidemic Conditions in Place



#### Equivalent Outdoor Air:

The equivalent outdoor air calculation indicates that the outdoor air can be calculated by using the combination of the actual outdoor air, impact of filtration or air cleaning technologies on recirculated air, and the impact of air cleaning technologies in the space.

This is using the principal of filters in series and the effectiveness at reducing particles. For items in series, the initial item would see the recirculated airflow to clean. The second item in the series would see the “cleaned” air from Item 1 and so the impact of Item 1 must be accounted for in Item 2.

As part of the airflow testing project that Portland Public Schools has partnered with Ameresco to complete, we are including the calculation of the Total Effective Air Changes per Hour (ACH<sub>e</sub>) to show the impact of the air filtration that is active in nearly all spaces in the PPS schools. The formula for doing so is:

$$ACH_e = (ACH_{oa} + ACH_f) * E_z + ACH_{ir}$$

where:

- $ACH_{oa}$  = air changes per hour of outside air = outside airflow in cubic feet per minute \* 60 minutes per hour / room volume in cubic feet
- $ACH_f$  = air changes per hour of clean air from filtered recirculated air with filters of the specified MERV rating as determined by ASHRAE
- $E_z$  = Zone Air Distribution Effectiveness = how effective the HVAC system is at circulating and mixing the air to distribute the clean air throughout the room
- $ACH_{ir}$  = the air changes per hour of clean air from portable air filters in the room = number of filters \* CADR \* 60 minutes per hour / room volume in cubic feet
  - CADR = Clear Air Delivery Rate = the CFM of clean air as specified by the manufacturer of the air filter

In order to include these calculations in the airflow testing reports, Ameresco and PPS have made the following assumptions as not all the variables are known:

1. PPS is in process of upgrading the air filters in their HVAC systems to MERV 13 and plans to be complete with that project for the start of the '21-'22 school year. In this report and for the sake of the ACH<sub>e</sub> calculation, we are using the filters that are in place at the time of the measurements, so some of them are still MERV 8.
2. ASHRAE has guidelines for what should be used for the Zone Air Distribution Effectiveness ( $E_z$ ) based on the HVAC system configuration, but they do not provide a value for every HVAC system and room configuration. For the majority of PPS rooms, an  $E_z$  of 0.8 – 1.0 would be most appropriate, so we have made the conservative assumption of using 0.8 for every space as that yields the lower ACH<sub>e</sub>.
3. The CADR for a given air filter is from manufacturer ratings and is based on certain conditions (fan speed, particulate size, filter cleanliness, etc.) that change with operating conditions.



# ***NEUDORFER ENGINEERS INC.***

**TEST REPORT TYPE:  
SURVEY REPORT**

## **Portland Public Schools Airflow Testing Scott ES**

Job Number: 2021-0297



**Project Completion Date: October 2021**

**Revision Date:**

-

**Revision Number:**

-



### ***SEATTLE***

5516 1<sup>st</sup> Avenue South  
Seattle, Washington 98108  
Phone (206) 621-1810  
Fax (206) 343-9820

### ***PORTLAND***

2501 SE Columbia Way, Suite 230  
Vancouver, Washington 98661  
Phone (503) 235-8924  
Fax (503) 235-8925



**Neudorfer Engineers, Inc.**

Consulting Engineers Seattle, Washington - Portland, Oregon



[www.NeudorferEngineers.com](http://www.NeudorferEngineers.com)

**Portland Public Schools Airflow Testing  
Scott ES**

**TABLE OF CONTENTS**

Title Sheet	3
Report Certification	4
Terms	5
Instrument Calibration	6
Report Summary	7
Airflow Survey Report	8
TAB Notes	11
Floor Layout	12



**Neudorfer Engineers, Inc.**

Consulting Engineers Seattle, Washington - Portland, Oregon



[www.NeudorferEngineers.com](http://www.NeudorferEngineers.com)

## REPORT TITLE

### CERTIFIED TEST: SURVEY REPORT

---

**Project:** Portland Public Schools Airflow Testing  
Scott ES


**NEI Job#:** 2021-0297

**Mechanical Engineer:** NA


**Architect:** NA

**HVAC Contractor:** NA

**TAB Firm:** Neudorfer Engineers Inc  
**Test Engineer:** Zach Mayer



5516 1<sup>st</sup> Ave South  
Seattle, Washington 98108  
Phone (206) 621-1810  
Fax (206) 343-9820



2501 SE Columbia Way, Suite 230  
Vancouver, Washington 98661  
Phone (503) 235-8924  
Fax (503) 235-8925

## CERTIFICATION

### Portland Public Schools Airflow Testing

The data presented in this report is a record of system measurements and final adjustments that have been obtained in accordance with the current edition of the NEBB Procedural Standards for Testing, Adjusting, and Balancing of Environmental Systems. Any variances from design quantities, which exceed NEBB tolerances, are noted in the Test-Adjust-Balance Report Project Summary.

Significant / Noteworthy Remarks are noted on the General Remarks and General Field Notes pages. Other remarks are noted on individual test sheets.

Noted deficiencies are not the TAB firms responsibility to repair. Prior to issuance of this report, Deficiency Reports are forwarded to our contracted agent.

Warranty is limited to one year from date of this report. Within that time, any discrepancies, ambiguities, or omissions found in this report will be retested, adjusted, or balanced as needed. A written notification will be required.

#### Submitted and Certified by:

NEBB TAB Firm: **Neudorfer Engineers Inc**

Certification No: **3414**


Expiration Date: **March 31, 2023**

Certification Date: **March 31, 2021**

*(Date completed)* Signed and Sealed by:

NEBB Supervisor: **Mike Vawter P.E.**

NEBB Supervisor: **Eric Stotts**





# Neudorfer Engineers, Inc.

Consulting Engineers Seattle, Washington - Portland, Oregon



www.NeudorferEngineers.com

## TERMS AND ABBREVIATIONS

**Project:** **Portland Public Schools Airflow Testing**

**AC or ACU** Air Conditioner or Air Conditioning Unit

**AH or AHU** Air Handler or Air Handling Unit

**ACH** Air Changes per Hour

**AVG** Average

**BHP** Brake Horsepower

**CAV** Constant Air Volume

**CBV** Calibrated Balancing Valve  
(Circuit Setter)

**CC** Cooling Coil

**CD** Ceiling Diffuser

**CFM** Cubic Feet per Minute

**CH** Chiller

**CHWS** Chilled Water Supply

**CHWR** Chilled Water Return

**CP** Circulating Pump

**CR** Ceiling Register

**CRAC** Computer Room Air Conditioner

**CRU** Computer Room Unit

**CT** Cooling Tower

**CU** Condenser Unit

**CUH** Cabinet Unit Heater

**CWS** Condenser Water Supply

**CWR** Condenser Water Return

**DAT** Discharge Air Temperature

**DB** Dry Bulb

**DD** Direct Drive

**DDC** Direct Digital Controls: EMS Control  
System for the HVAC

**Des.** Design

**Dia.** Diameter

**Disch.** Discharge

**EA** Exhaust Air

**EAT** Entering Air Temperature

**Economizer** Controls and components that allow an  
air handler to logically utilize outdoor air  
for cooling as opposed to the use of  
mechanical cooling.

**EF** Exhaust Fan

**EG** Exhaust Grille

**EMCS** Energy Management Control System

**ERU** Energy Recovery Unit

**E.S.P.** External Static Pressure

**HRC** Heat Recovery Coil

**EWT** Entering Water Temperature

**FCU** Fan Coil Unit

**FD** Fire Damper

**FSD** Fire Smoke Damper

**FLA** Full Load Amperage: Maximum  
amperage a motor can draw.

**Flow Hood** Instrument that captures air and  
converts the reading to CFM.

**FHT** Fume Hood Test

**FPB** Fan Powered Box

**FPM** Feet per Minute

**FR** Field Report

**FT** Foot, Feet

**FTU** Fan Terminal Unit

**GPM** Gallons per Minute

**HC** Heating Coil

**TDH** Pressure Difference across the entering  
and leaving side of a pump.

**HEPA** High Efficiency Particulate Absorbing

**HP** Horsepower

**HVAC** Heating Ventilation and Air Conditioning

**HWS** Heating Water Supply

**HWR** Heating Water Return

**HX** Heat Exchanger

**HZ** Hertz, cycle per second

**in.** inches

**in.w.g.** inches of water gauge

**Kfactor** Correction factor to the free area need to  
calculate CFM.

**KW** Kilowatts

**LAT** Leaving Air Temperature

**LVG** Low Wall Grille

**LWR** Low Wall Register

**LWT** Leaving Water Temperature

**MAU** Make-up Air Handling Unit

**MBH** 1,000 BTUH

**N/A** Not Applicable

**OSA** Outside Air

**OBD** Opposed Blade Damper

**ΔP** Pressure Drop.

**PH** Phase

**PSI** Pounds per Square Inch

**RA** Return Air

**RAT** Return Air Temperature

**RF** Return Fan

**RH** Relative Humidity

**RHC** Reheat Coil

**RPM** Revolutions per Minute

**RTU** Roof Top Unit

**SA** Supply Air

**SAT** Supply Air Temperature

**S.F.** Service Factor

**SF** Supply Fan

**SFD** Smoke/Fire Damper

**SP** Static Pressure

**sq.ft.** square feet

**Suct.** Suction

**SWG** Sidewall Grille

**SWR** Sidewall Register

**TAB** Test; Adjust; and Balance

**TSP** Total Static Pressure: Difference  
between the entering and leaving  
static pressure of a fan.

**UH** Unit Heater

**VAV** Variable Air Volume; box that  
contains a motorized damper that  
modulates airflow.

**VD** Volume Damper

**VFD** Variable Frequency Drive

**Velgrid** Instrument that reads used to read  
velocity in feet per minute.

**VVT** Variable Volume Terminal

**WC** Water Column

**W.G.** Water Gauge

**WB** Wet Bulb

## INSTRUMENT CALIBRATIONS

### Portland Public Schools Airflow Testing

Scott ES

<b>Instrument Type</b>	Air Data Meter with Flowhood	<b>Instrument Serial #</b>	<b>M97410</b>
<b>Instrument Manufacturer</b>	<b>Shortridge</b>	<b>Calibration Date</b>	<b>10/4/2021</b>
<b>Instrument Model Number</b>	<b>ADM 860</b>	<b>Calibration Due</b>	<b>10/4/2022</b>
<b>Instrument Type</b>	Differential Pressure Water Meter	<b>Instrument Serial #</b>	<b>W12178</b>
<b>Instrument Manufacturer</b>	<b>Shortridge</b>	<b>Calibration Date</b>	<b>10/4/2021</b>
<b>Instrument Model Number</b>	<b>HDM-250</b>	<b>Calibration Due</b>	<b>10/4/2022</b>
<b>Instrument Type</b>	Psychrometer	<b>Instrument Serial #</b>	<b>181128924</b>
<b>Instrument Manufacturer</b>	<b>Extech</b>	<b>Calibration Date</b>	<b>10/1/2021</b>
<b>Instrument Model Number</b>	<b>RH390</b>	<b>Calibration Due</b>	<b>10/1/2022</b>
<b>Instrument Type</b>	Tachometer	<b>Instrument Serial #</b>	<b>B185B5022P</b>
<b>Instrument Manufacturer</b>	<b>Nidec</b>	<b>Calibration Date</b>	<b>10/1/2021</b>
<b>Instrument Model Number</b>	<b>MT-200</b>	<b>Calibration Due</b>	<b>10/1/2022</b>
<b>Instrument Type</b>	Amp Probe	<b>Instrument Serial #</b>	<b>33380179WS</b>
<b>Instrument Manufacturer</b>	<b>Fluke</b>	<b>Calibration Date</b>	<b>10/1/2021</b>
<b>Instrument Model Number</b>	<b>323 Clamp Meter</b>	<b>Calibration Due</b>	<b>10/1/2022</b>
<b>Instrument Type</b>	Digital Thermometer	<b>Instrument Serial #</b>	<b>45400509WS</b>
<b>Instrument Manufacturer</b>	<b>Fluke</b>	<b>Calibration Date</b>	<b>10/1/2021</b>
<b>Instrument Model Number</b>	<b>52 II</b>	<b>Calibration Due</b>	<b>10/1/2022</b>
<b>Instrument Type</b>	Manometer	<b>Instrument Serial #</b>	<b>M97410</b>
<b>Instrument Manufacturer</b>	<b>Shortridge</b>	<b>Calibration Date</b>	<b>10/4/2021</b>
<b>Instrument Model Number</b>	<b>ADM 860</b>	<b>Calibration Due</b>	<b>10/4/2022</b>
<b>Instrument Type</b>	Thermal Anemometer	<b>Instrument Serial #</b>	<b>AVM440808002</b>
<b>Instrument Manufacturer</b>	<b>Alnor Instruments</b>	<b>Calibration Date</b>	<b>9/22/2021</b>
<b>Instrument Model Number</b>	<b>AVM 440</b>	<b>Calibration Due</b>	<b>9/22/2022</b>
<b>Instrument Type</b>	Ultrasonic Flow Meter	<b>Instrument Serial #</b>	<b>N1F1823T</b>
<b>Instrument Manufacturer</b>	<b>Fuji</b>	<b>Calibration Date</b>	<b>9/20/2021</b>
<b>Instrument Model Number</b>	<b>Portaflow-C</b>	<b>Calibration Due</b>	<b>9/20/2022</b>



PROJECT	Portland Public Schools Airflow Testing
LOCATION	Scott ES; 6700 NE Prescott St, Portland, OR 97218

## REPORT SUMMARY

This project has been surveyed per plans and specifications using the National Environmental Balancing Bureau (NEBB) standards and procedures.

The scope of work for this project was to assess the current airflows for each classroom, office, and special purpose space. Air changes per hour were calculated along with the % of OSA for the spaces and any deficiencies found for each piece of equipment has been noted in the following report.

All ventilation equipment was commanded to run by the BMS system. Ventilation units were measured with a flowhood on the supply outlets. Outside air was recorded with a flowhood on the OSA louvre where accessible. AK factors were calculated from flowhood readings. The remaining OSA values were recorded with a velgrid. AHU supply air was recorded by a summation of the outlets as recorded by flowhood or velgrid when appropriate. Outside air was recorded with a velgrid or airfoil and calculated by the free area method.

The measured airflows in this report represent the performance of the equipment at the time of measurement, which vary over time based on operating conditions. There are factors outside the control of Neudorfer that impact airflow, and variance in those factors is expected and normal. One significant factor is the MERV rating and condition of the air filters on the equipment. During the summer of 2021, PPS began upgrading the filters on all their fan systems to MERV 13. Those upgraded filters are more effective at capturing particles but also impact the amount of airflow from the equipment. These filter changes were occurring while the airflow measurement project was happening, so some schools had the new filters, and some had the old filters at the time of measurement. On the data page included this report, there is a line stating whether or not the upgraded filters were in place at the time of measurement.



**AIRFLOW SURVEY REPORT**

Project: Portland Public Schools Airflow Testing  
Location: Scott ES; 6700 NE Prescott St, Portland, OR 97218  
Filter Status: Not Upgraded

Room	Equipment Info		Room Dimensions					Airflow Measurements			Calculated ACH					Notes
	Served By	Equipment Type	Room Length	Room Width	Room Area	Room Height	Room Volume	Total CFM Supply	OA CFM Supply	OA %	Air Changes per Hour (supply)	Air Changes per Hour (OA)	# of Portable Filters	Total Effective Air Changes per Hour (ACH_e) with Portable Filter	Total Effective Air Changes per Hour (ACH_e) without Portable Filter	
Lower Level 1																
Cafeteria 02	Café AHU	AHU	56.2	54.1	3,424	9.0	30,816	2,310	2,310	100%	4.5	4.5	1	4.1	3.6	Non-rectangular room.
8	-	-	35.2	15.0	528	8.2	4,330	-	-	-	0	0	1	3.6	0.0	Ventilation provided by adjacent spaces.
9	-	-	5.0	7.9	40	7.0	277	-	-	-	0	0	0	N/A	0.0	Ventilation provided by adjacent spaces.
11	-	-	7.9	5.2	41	8.0	329	-	-	-	0	0	0	N/A	0.0	Ventilation provided by adjacent spaces.
13	Stage #2 FCU	FCU	14.2	20.6	293	7.8	2,282	100	100	100%	2.6	2.6	1	8.9	2.1	
Conf. Room 16	-	-	7.7	11.0	85	7.7	652	-	-	-	0	0	1	23.9	0.0	Ventilation provided by adjacent spaces.
First Floor																
Rm 406	Stage #1 FCU	FCU	35.4	24.6	871	10.0	8,708	887	887	100%	6.1	6.1	1	6.7	4.9	
Rm 405	Stage #1 FCU	FCU	36.9	24.0	886	9.9	8,767	690	690	100%	4.7	4.7	1	5.6	3.8	
Rm 404	Stage #1 FCU	FCU	26.3	24.3	639	10.6	6,774	806	806	100%	7.1	7.1	1	8.0	5.7	
Library 401	Stage #1 FCU	FCU	76.1	24.0	1,826	10.6	19,360	1,600	1,600	100%	5.0	5.0	1	4.8	4.0	
Rm 402	Stage #1 FCU	FCU	36.9	24.6	908	10.7	9,713	730	730	100%	4.5	4.5	1	5.2	3.6	
219	Stage #1 FCU	FCU	25.2	15.2	383	10.0	3,830	340	340	100%	5.3	5.3	1	8.3	4.3	
217E	Stage #1 FCU	FCU	18.6	14.7	273	7.5	2,051	160	160	100%	4.7	4.7	1	11.4	3.7	
217G	-	-	16.6	5.9	98	8.0	784	-	-	-	0	0	1	19.9	0.0	Ventilation provided by adjacent spaces.
Auditorium 217	Gym AHU	AHU	55.9	86.0	4,807	20.0	96,148	9,070	9,070	100%	5.0	5.0	1	4.2	4.0	
Stage 217C	-	-	20.4	34.5	704	17.6	12,387	-	-	-						Open and shared with Auditorium.
Rm 301	Gym AHU	AHU	37.0	23.9	884	10.7	9,462	950	950	100%	6.0	6.0	1	6.5	4.8	
Rm 302	Gym AHU	AHU	39.5	23.7	936	10.8	10,110	850	850	100%	5.0	5.0	1	5.6	4.0	
Rm 303	Gym AHU	AHU	37.0	24.0	888	10.6	9,413	775	775	100%	4.9	4.9	1	5.6	4.0	
Rm 304	Gym AHU	AHU	40.1	23.9	958	10.6	10,159	660	660	100%	3.9	3.9	1	4.7	3.1	
Rm 305	Gym AHU	AHU	36.9	23.7	875	10.7	9,357	785	785	100%	5.0	5.0	1	5.7	4.0	
Rm 306	Gym AHU	AHU	36.9	23.9	882	10.1	8,907	650	650	100%	4.4	4.4	1	5.3	3.5	
Rm 307	Gym AHU	AHU	36.9	24.0	886	10.1	8,945	630	630	100%	4.2	4.2	1	5.1	3.4	

Date: 7/14/2021

Readings By: Mayer



**AIRFLOW SURVEY REPORT**

Project: Portland Public Schools Airflow Testing  
Location: Scott ES; 6700 NE Prescott St, Portland, OR 97218  
Filter Status: Not Upgraded

Room	Equipment Info		Room Dimensions					Airflow Measurements			Calculated ACH					Notes
	Served By	Equipment Type	Room Length	Room Width	Room Area	Room Height	Room Volume	Total CFM Supply	OA CFM Supply	OA %	Air Changes per Hour (supply)	Air Changes per Hour (OA)	# of Portable Filters	Total Effective Air Changes per Hour (ACH_e) with Portable Filter	Total Effective Air Changes per Hour (ACH_e) without Portable Filter	
First Floor																
300	Fan #8	AHU	26.1	20.0	522	10.8	5,638	336	336	100%	3.6	3.6	1	5.6	2.9	
300A	-	-	5.9	6.5	38	7.6	291	-	-	-	0.0	0.0	0	N/A	0.0	This is a vestibule/interstitial.
300E	-	-	8.1	6.5	53	10.8	569	-	-	-	0.0	0.0	1	27.4	0.0	Ventilation provided by adjacent spaces.
300D	Fan #8	AHU	15.6	13.8	215	10.8	2,325	180	180	100%	4.6	4.6	1	10.4	3.7	
300C	Fan #8	AHU	19.9	8.1	161	8.0	1,290	125	125	100%	5.8	5.8	1	16.8	4.7	
300H	Fan #8	AHU	8.1	6.0	49	8.1	394	60	60	100%	9.1	9.1	1	46.9	7.3	
Main Office 214	Fan #8	AHU	12.3	15.5	191	8.0	1,525	180	180	100%	7.1	7.1	1	15.9	5.7	
216	Fan #8	AHU	15.5	12.5	194	10.8	2,093	185	185	100%	5.3	5.3	1	11.7	4.2	
210	Fan #8	AHU	12.1	26.8	324	10.8	3,502	85	85	100%	1.5	1.5	1	5.6	1.2	
Rm 208	Fan #7	AHU	36.0	24.4	878	10.5	9,223	1,220	1,220	100%	7.9	7.9	1	8.0	6.3	
Rm 207	Fan #7	AHU	36.8	24.4	898	10.5	9,428	810	810	100%	5.2	5.2	1	5.8	4.1	
Rm 206	Fan #7	AHU	36.0	24.0	864	10.5	9,072	1,190	1,190	100%	7.9	7.9	1	8.0	6.3	
Rm 205	Fan #7	AHU	36.9	24.0	886	10.5	9,299	1,135	1,135	100%	7.3	7.3	1	7.5	5.9	
Rm 204	Fan #7	AHU	36.9	24.1	889	10.5	9,338	960	960	100%	6.2	6.2	1	6.6	4.9	
Rm 203	Fan #7	AHU	36.9	24.1	889	10.5	9,338	1,110	1,110	100%	7.1	7.1	1	7.4	5.7	
Rm 202	Fan #7	AHU	48.4	25.0	1,210	10.0	12,100	1,035	1,035	100%	5.1	5.1	1	5.4	4.1	
Rm 201	Fan #7	AHU	36.9	24.0	886	10.0	8,856	640	640	100%	4.3	4.3	1	5.2	3.5	
Rm 101	Annex Fan	AHU	31.9	25.0	798	10.0	7,975	190	190	100%	1.4	1.4	1	3.1	1.1	
101C	Annex Fan	AHU	16.0	12.0	192	10.0	1,920	305	305	100%	9.5	9.5	1	15.8	7.6	
Rm 102	Annex Fan	AHU	31.9	25.1	801	10.0	8,007	770	770	100%	5.8	5.8	1	6.6	4.6	
Rm 103	Annex Fan	AHU	33.4	25.0	835	10.0	8,350	775	775	100%	5.6	5.6	1	6.3	4.5	
Rm 104	Annex Fan	AHU	31.1	25.0	0	10.0	0	665	665	100%	0.0	0.0	1	-	0.0	
Rm 105	Annex Fan	AHU	33.9	25.0	848	10.0	8,475	345	345	100%	2.4	2.4	1	3.8	2.0	
Rm 106	Annex Fan	AHU	34.0	24.9	847	9.9	8,381	700	700	100%	5.0	5.0	1	5.9	4.0	

Date: 7/14/2021

Readings By: Mayer



Project:	Portland Public Schools Airflow Testing
Location:	Scott ES; 6700 NE Prescott St, Portland, OR 97218
Filter Status:	Not Upgraded

Date: 7/14/2021

Project:



Portland Public Schools Airflow Testing














Location:

Scott ES; 6700 NE Prescott St, Portland, OR 97218

NOTE #	NOTE DESCRIPTION

SCOTT: Lower Level 1





Space Use		School Grounds	
	Classroom		Campus Footprints
	Office		Athletic Field
	Rest Room		Playground: Paved
	Special Purpose		Playground: Unpaved
	Corridor		Streets
	Other		Doors
	Stairs/Elevator		

**Total Number Of Rooms By Classification**

Classrooms: 0	Special Purpose: 5
Office Spaces: 1	Storage: 7

SCOTT: First Floor



Space Use		School Grounds	
<div></div>	Classroom	<div></div>	Campus Footprints
<div></div>	Office	<div></div>	Athletic Field
<div></div>	Rest Room	<div></div>	Playground: Paved
<div></div>	Special Purpose	<div></div>	Playground: Unpaved
<div></div>	Corridor	<div></div>	Streets
<div></div>	Other	<div></div>	Doors
<div></div>	Stairs/Elevator		

Total Number Of Rooms By Classification

Classrooms: 27	Special Purpose: 10
Office Spaces: 6	Storage: 21