

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Beaumont Elementary School - Test 4**

| Sample Identification # | Location      | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|---------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 235-DF-1662-A-004-A     | Hallway (138) | 05/25/2021          | 05/27/2021    | A1E0985-01 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1666-A-004-A     | Hallway (136) | 05/25/2021          | 05/27/2021    | A1E0985-02 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1649-A-004-A     | Hallway (220) | 05/25/2021          | 05/26/2021    | A1E0985-03 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-5826-A-004-A     | Hallway (203) | 05/25/2021          | 05/27/2021    | A1E0985-04 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1672-A-004-A     | Hallway (102) | 05/25/2021          | 05/27/2021    | A1E0985-05 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1675-A-004-A     | Hallway (112) | 05/25/2021          | 05/27/2021    | A1E0985-06 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1650-A-004-A     | Hallway (136) | 05/25/2021          | 05/26/2021    | A1E0985-07 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1665-A-004-A     | Hallway (14A) | 05/25/2021          | 05/26/2021    | A1E0985-08 | Lead    | ND      | 0.2             | 15                | ppb   |
| 235-DF-1659-NA-004-A    | Staff Room    | 05/25/2021          | 05/26/2021    | A1E0985-09 | Lead    | 0.283   | 0.2             | 15                | ppb   |

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb