

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Bridger Elementary School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
238-DF4645-A-006	Cafeteria	5/18/2021	5/25/2021	A1E0662-01	Lead	ND	0.2	15	ppb
238-DF4642-A-006	Hallway (Cafeteria)	5/18/2021	5/25/2021	A1E0662-02	Lead	ND	0.2	15	ppb
238-DF4626-A-006	Hallway (Classroom 43)	5/18/2021	5/25/2021	A1E0662-03	Lead	ND	0.2	15	ppb
238-DF4972-A-006	Hallway (Classroom 10)	5/18/2021	5/25/2021	A1E0662-04	Lead	ND	0.2	15	ppb
238-DF5947-N/A-006	Kitchen	5/18/2021	5/25/2021	A1E0662-05	Lead	0.329	0.2	15	ppb
238-DF5945-N/A-006	Office Staff Room	5/18/2021	5/25/2021	A1E0662-06	Lead	3.24	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb