

Portland Public Schools
Lead Water Sampling Results
Drinking Fixture Replacement Prgram Sample Data
Martin Luther King Elementary School - Test 7

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
262-DF-1684-N/A-007-A	Kitchen	12/11/2020	12/29/2020	A0L0483-02	Lead	0.450	0.2	15	ppb
262-DF-5785-N/A-007-A	Classroom 140	12/11/2020	12/29/2020	A0L0483-03	Lead	ND	0.2	15	ppb
262-DF-5784-N/A-007-A	Nurse	12/11/2020	12/29/2020	A0L0483-04	Lead	0.710	0.2	15	ppb
262-DF-5783-N/A-007-A	Room 109 Teacher's	12/11/2020	12/29/2020	A0L0483-05	Lead	0.410	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb