

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Laurelhurst K-8 School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
265-DF-5828-N/A-006-A	Staff Room	10/1/2021	10/5/2021	A1J0022-01	Lead	1.37	0.2	15	ppb
265-DF-5830-A-006-A	Portable (114)	10/1/2021	10/5/2021	A1J0022-02	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek