

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Lent Elementary School - Test 5**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
266-DF-5259-A-005-A	Hallway (Classroom 215)	9/29/2021	10/5/2021	A1J0003-0	Lead	ND	0.2	15	ppb
266-DF-5247-A-005-A	Hallway (Classroom 113)	9/29/2021	10/5/2021	A1J0003-04	Lead	ND	0.2	15	ppb
266-DF-5258-A-005-A	Hallway (Classroom 136)	9/29/2021	10/5/2021	A1J0003-06	Lead	ND	0.2	15	ppb
266-DF-5260-A-005-A	Hallway (Entrance)	9/29/2021	10/5/2021	A1J0003-06	Lead	ND	0.2	15	ppb
266-DF-5294-N/A-005-A	Staff Room	9/29/2021	10/5/2021	A1J0003-07	Lead	1.61	0.2	15	ppb
266-DF-5897-N/A-005-A	Kitchen	9/29/2021	10/5/2021	A1J0003-08	Lead	ND	0.2	15	ppb
266-DF-5309-A-005-A	Cafeteria	9/29/2021	10/5/2021	A1J0003-09	Lead	ND	0.2	15	ppb
266-DF-5300-A-005-A	Hallway (Classroom 152)	9/29/2021	10/5/2021	A1J0003-10	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb