

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Peninsula Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
180-DF-5811-N/A-005-A	Health Room	08/12/2021	08/24/2021	A1H0403-26	Lead	1.90	0.2	15	ppb
180-DF-2975-A-005-A	Hallway	08/12/2021	08/24/2021	A1H0403-27	Lead	ND	0.2	15	ppb
180-DF-5810-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-28	Lead	1.12	0.2	15	ppb
180-DF-5815-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-29	Lead	0.997	0.2	15	ppb
180-DF-5814-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-30	Lead	1.23	0.2	15	ppb
180-DF-5813-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-31	Lead	1.31	0.2	15	ppb
180-DF-3020-N/A-005-A	Hallway	08/12/2021	08/24/2021	A1H0403-32	Lead	ND	0.2	15	ppb
180-DF-5812-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-33	Lead	1.22	0.2	15	ppb
180-DF-2926-A-005-A	Cafeteria	08/12/2021	08/24/2021	A1H0403-34	Lead	0.347	0.2	15	ppb
180-DF-2274-N/A-005-A	Kitchen	08/12/2021	08/23/2021	A1H0403-35	Lead	46.3	0.2	15	ppb
180-DF-3021-A-005-A	Hallway	08/12/2021	08/24/2021	A1H0403-36	Lead	ND	0.2	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek