

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Lincoln High School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
120-DF-1960-A-004-A	Hallway (Gym)	11/23/2021	11/29/2021	A1K1078-03	Lead	0.735	0.2	15	ppb
120-DF-1956-A-004-A	Gym	11/23/2021	11/29/2021	A1K1078-04	Lead	ND	0.2	15	ppb
120-DF-1951-A-004-A	Weight Room	11/23/2021	11/29/2021	A1K1078-05	Lead	3.09	0.2	15	ppb
120-DF-1943-A-004-A	Cafeteria	11/23/2021	11/29/2021	A1K1078-06	Lead	ND	0.2	15	ppb
120-DF-1942-A-004-A	Ceramics	11/23/2021	11/29/2021	A1K1078-07	Lead	0.292	0.2	15	ppb
120-DF-1961-A-004-A	Hallway (Metal Art 123)	11/23/2021	11/29/2021	A1K1078-08	Lead	ND	0.2	15	ppb
120-DF-1967-A-004-A	Hallway (Biology 213)	11/23/2021	11/29/2021	A1K1078-09	Lead	0.287	0.2	15	ppb
120-DF-5990-N/A-004-A	Staff Room	11/23/2021	11/29/2021	A1K1078-10	Lead	0.458	0.2	15	ppb
120-DF-1965-A-004-A	Hallway (Upper Auditorium)	11/23/2021	11/29/2021	A1K1078-11	Lead	0.287	0.2	15	ppb
120-DF-1964-A-004-A	Hallway (Classroom 232)	11/23/2021	11/29/2021	A1K1078-12	Lead	0.421	0.2	15	ppb
120-DF-5988-A-004-A	Portable 1	11/23/2021	11/29/2021	A1K1078-13	Lead	ND	0.2	15	ppb
120-DF-1962-A-004-A	Hallway (Auditorium)	11/23/2021	11/29/2021	A1K1078-14	Lead	0.207	0.2	15	ppb