

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Roosevelt Site - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
124-DF-6319-N/A-003-A	Hallway (3D Art 085)	12/1/2022	12/5/2022	A2L0130-02	Lead	0.363	0.200	15	ppb
124-DF-6323-N/A-003-A	Life Skills 057	12/1/2022	12/5/2022	A2L0130-01	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb